

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | 1 | | 1 | | 1 | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 1 | 2 | 1 | 2 | 1 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 3 | | 3 | | 3 | | | |
| 2 | NLG | 144 | 988 | | 5 | | 5 | | 5 | | | |
| 3 | MDK | 107 | 933 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| 4 | SDPT | | | | 3 | | 3 | | 3 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 12 | 1 | 12 | 1 | 12 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 2 | 14 | 2 | 14 | 2 | 14 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 26.10.2019

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MDK | Jogipet | Dakur | 33kv | Jogipet | 16.10 | 18.25 | 02.15 | | BD due to Conductor snapped | Dakur | - |
| 1 | RR N | 132KV DP Pally | 33KV Gowdawelly | 33kv | Medchal | 10.24 | 12.20 | 01.56 | BD | Foreign material fallen on the 33KV line at Dundigal Police Station | 33KV Gowdawelly | - |

TSSPDCL - LMRC / Corporate office

Date: 26.10.2019

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---|
| 1 | MBNR | K V Pet | Bandameedipally | 11kv | Jadcherla | 02.15 | 07.25 | 05.10 | | 11Kv Insulator Failure Near Bandameedipally (Vi) | - |
| 2 | | K V Pet | Bandameedipally | 11kv | Jadcherla | 08.30 | 09.10 | 00.40 | | 11Kv Insulator Failure Near Bandameedipally (Vi) | - |
| 3 | | Donoor | Singamdoddi | 11kv | Jadcherla | 06.30 | 14.00 | 07.30 | | 11Kv Insulator Failure Near Singamdoddi(Vi) Side. | - |
| 1 | NLG | Akaram | Shanthinagar | 11kv | Nalgonda | 08.00 | 12.00 | 04.00 | E/L | 11Kv Jumper Cut | - |
| 2 | | Nuthankal | Yedavelly | 11kv | Suryapet | 03.55 | 07.30 | 03.35 | E/L | 11Kv Insulator failed | - |
| 3 | | Mattapally | Ramachandrapuram | 11kv | Huzurnagar | 03.00 | 06.00 | 03.00 | E/L | 11Kv line cut | - |
| 4 | | Chanupally | Palavaram | 11kv | Huzurnagar | 06.00 | 09.00 | 03.00 | E/L | 11Kv line snapped | - |
| 5 | | Choutuppal | Thangadapally | 11kv | Choutuppal | 10.40 | 14.50 | 04.10 | E/L | 11kv Disc Failed near Thangadapally (V) | - |
| 1 | MDK | Patancheru Town | MIA-II | 11kv | Patancheru | 13.35 | 15.35 | 02.00 | | BD due to Conductor snapped | - |
| 1 | SDPT | Rebarthy | Gagillapur Agl | 11kv | Husnabad | 16.10 | 23.55 | 07.45 | | No visible fault | - |
| 2 | | Katkur | Katkur Rural | 11kv | Husnabad | 12.30 | 16.30 | 04.00 | | BD due to Conductor snapped | - |
| 3 | | Dharmaram | Dharmaram(R.) | 11kv | Husnabad | 19.05 | 19.40 | 00.35 | | BD due to Insulator failure | - |
| 1 | HYD S | Salarjung | Q.Q Stadium | 11kv | III | 08.25 | 10.05 | 01.40 | EL | Cable fault | Arranged B/F on 11KV Petla Burz & 11KV Shah Gunj fdrs |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|--------------------------------------|
| 2 | HYD N | Thirumalgiri | Officers Colony | 11kv | C-VI | 19.05 | 20.27 | 01.22 | EL,OL-Rph | AB Switch sparking at Military Hospital | Arranged B/F on 11KV Nagadevatha fdr |