

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		8		8		8			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	10	1	10	1	10	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.10.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	Jinnaram	33KV	Patancheru	08.55	11.00	02.05		B/D Due to Jumper Cut		-

TSSPDCL - LMRC / Corporate office

Date: 28.10.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aitipamula	Rasoolgudem	11KV	Nalgonda	14.58	16.05	01.07	EL	Insulator failed	-
2		Edulur	Naragudam	11KV	Nalgonda	11.30	12.30	01.00	EL	Jumper cut	-
3		Angadipeta	Gudipally	11KV	Devarakonda	07.00	12.50	05.50	EL	11 kV Line Cutt	-
4		Marrigudam	Vattipally	11KV	Devarakonda	12.50	14.30	01.40	EL	11 Kv Jumper Cutt	-
5		Bopparam	Midthanapally	11KV	Suryapet	06.05	08.40	02.35	EL	Insulator flashover	-
6		Mukundapuram	Mamilamadava	11KV	Suryapet	05.00	07.30	02.30	EL	Disc Flashover	-
7		Gudimalkapuram	Pulicinthla	11KV	Huzurnagar	11.20	12.30	01.10	EL	Due to bird fall on 11kv line	-
8		Panhangi	Panhangi Agl	11KV	Choutuppal	02.04	06.26	04.22	EL	11 kv Line Snapped	-
1	MDK	Waddepally	Industrial	11KV	Jogipet	08.20	09.30	01.10		B/D Due to Insulator Failure	-
1	SDPT	Komuravelly	Komuravelly Agl	11KV	Husnabad	21.30	23.30	02.00		Jumper cut	-