

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044	1	6	1	6	1	6			
	Total	606	3055	1	18	1	18	1	18	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	6	3	6	3	6			
2	NLG	144	988		11		11		11			
3	MDK	107	933		2		2		2			
4	SDPT				12		12		12			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	31	3	31	3	31	0	0	
	Grand Total	1082	6468	4	49	4	49	4	49	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Kollur	33KV	Jadcherla	04.50	05.45	00.55	E/L&O/L	LA Blast at Pitti cast Industrial		NO
2		Maddur	Vepoor	33KV	Narayanapet	17.20	21.30	04.10	E/L	Not Rectified	Vepoor,shervenkata pur,Gocolnagar, Mominapur	Only Vepoor Feeder Supply Alternate Supply Given at 21:30Hrs in Hanwada Feeder
3		Alampur	Shantinagar-1	33KV	Rural	14.22	17.03	02.41	E/L&O/L	Tree Fallen on the Line		NO
1	HYD N	132KV Madhapur	Ven-En-Burg	33KV	Kalyan Ngr	08.50	12.40	03.50	EL,OL	No Visible fault		Pulled out 80MVA PTR-2 in 132KV Madhapur SS

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Annasagar	Annasagar	11KV	Jadcherla	00.30	07.30	07.00		Due to 11 KV insulator fail near Annasagar	-
2		Gangapur	Gangapur	11KV	Jadcherla	00.30	10.20	09.50		Due to tree fallen on 11 kv line at gollapally	-
3		Ponnakal	Rachala	11KV	Jadcherla	06.40	08.20	01.40		Due to 11 KV insulator fail near Rachala.	-
4		Rajapur	Mallepally	11KV	Jadcherla	09.10	13.45	04.35		Due to disk fail near Rajapur and Ibrahim pally.	-
5		Kothamolgara	Kothamolgara	11KV	Jadcherla	04.10	11.20	07.10		Due to 11 KV wire cut near Krushnaiah bai at Kothamolgara.	-
6		Kothamolgara	karvena	11KV	Jadcherla	02.15	08.15	06.00		Due to 11 KV disk fail near swala thanda.	-
1	NLG	Arjalabavi	Arjalabavi	11KV	Nalgonda	07.30	11.40	04.10	E/L	11KV Line Cut	-
2		Eduloor	Naragudem	11KV	Nalgonda	04.30	10.40	06.10	E/L	11KV Line Cut	-
3		Rayanguda	Jangareddygudem	11KV	Nalgonda	11.25	14.00	02.35	E/L	HT/LT Melting	-
4		Arlagaddagudem	Chinnasuraram	11KV	Nalgonda	00.00	07.20	07.20	E/L	11KV Line Insulator Failur	-
5		Thurkapally	M.Gouraram	11KV	Nalgonda	09.20	11.40	02.20	E/L	11KV Jumper Cut	-
6		Palem	Ogodu	11KV	Nalgonda	06.40	10.50	04.10	E/L	11KV Line Disc Failur	-
7		Jammigadda	Kesaram	11KV	Suryapet	12.00	14.20	02.20	E/L	Insulator failed	-
8		Gaddipaly	Medaram	11KV	Huzuragar	06.00	09.00	03.00	E/L	Due to 11Kv line cutted	-
9		Munagala	Lift	11KV	Huzuragar	06.00	08.25	02.25	E/L	Due to 11Kv jumper cutted	-
10		Nadigudem	Lift	11KV	Huzuragar	13.00	16.00	03.00	E/L	Due to 11Kv line cutted	-
11		Rajapet	Pamkunta	11KV	Bhongir	04.40	08.30	03.50	EL	Nature of fault	-
1	MDK	SOL	Markwell	11KV	Patancheru	15.10	16.55	01.45		BD Due to Disk fail	-
2		Hathnoora	Town Ind	11KV	Jogipet	15.40	17.00	01.20		BD Due to Disk fail	-
3		Husnabad	Husnabad town I&II	11KV	Husnabad	00.00	00.10	00.10		Insulator failure	-
4		Akkannapet	Fakkirnayak thanda	11KV	Husnabad	00.00	06.00	06.00		Heavy gale and wind	-
5	SDPT	Gandipally	Nandaram	11KV	Husnabad	01.30	12.50	11.20		Line cut	-
6		Gouravelli	Gudatipally	11KV	Husnabad	11.25	11.55	00.20		Line cut	-
7		Pandilla	Pandilla Rural	11KV	Husnabad	05.30	10.00	04.30		Disk failure	-
8		Pandilla	Pandilla Rural	11KV	Husnabad	16.00	17.00	01.00		Jumper cut	-
9		Komuravelli	Kistampet	11KV	Husnabad	00.00	00.40	00.40		Heavy gale and wind	-
10		Komuravelli	Pochanpally	11KV	Husnabad	08.40	11.55	03.15		Heavy gale and wind	-
11		Guruvannapet	Pochanpally	11KV	Husnabad	00.00	08.50	08.50		Heavy gale and wind(3ph)	-
12		Guruvannapet	Tapasupally	11KV	Husnabad	02.50	03.35	00.45		Heavy gale and wind	-
13		Guruvannapet	Tapasupally	11KV	Husnabad	08.10	17.00	08.50		Heavy gale and wind(3ph)	-
14	Guruvannapet	Pochanpally	11KV	Husnabad	14.40	16.55	02.15		Disk failure	-	
1	RR N	Jeedimetla-I	Vichow	11KV	Jeedimetla	04.35	06.35	02.00	BD	11kv Jumper touched channel At Gem pharama Company	-
2		Jeedimetla-I	Su-Drugs	11KV	Jeedimetla	08.00	09.20	01.20	BD	11kv jumper Cut In sub station	-
3		Jeedimetla-I	Phase-5	11KV	Jeedimetla	09.45	12.15	02.30	BD	Ground Petroling No Fout	-
4		Dulapally	KK Society	11KV	Medchal	16.05	17.30	01.25	BD	11KV Line cut and replaced at Glass Company	-
5		HMT	Qutubullapur	11KV	Medchal	16.25	17.45	01.20	BD	Tree fallen on the 11KV Line at Muncipal Office	-
6		Subhash Nagar	Suchitra	11KV	Medchal	17.50	18.55	01.05	BD	Tree fallen on the 11KV Line at Suchitra	-
1	RR E	Moula-Ali	Gayathri Nagar	11KV	Sainikpuri	02.02	02.48	00.46		Gabbilam touched on 11Kv line at SP Nagar (Artisan Naresh/Bal Narsihma)	-
2		Sainikpuri	Vijay Puri	11KV	Sainikpuri	17.02	19.20	02.18		11Kv Disk failed at Rukminipuri (L.Insp Jagan)	-
3		Saketh	Saketh	11KV	Sainikpuri	16.10	17.30	01.20		11Kv Insulator failed at Sai Ram Nagar (LM Mallesh)	-
4		Uppal	Adarsha Nagar	11KV	Habsiguda	01.45	03.00	01.15		11KV Pin Nsulator failed at Adarsha Nagar Colony	-
5		Singapur	Singapur	11KV	Keesara	02.00	02.45	00.45		Brash patti cut at Block 35	-
6		Singapur	RGK	11KV	Keesara	04.10	08.30	04.20		11KV disk fail at Jillaram modi road	-
1	HYD N	Kundanbagh	SBI Staff Quarters	11KV	Erragadda	14.23	15.45	01.22	EL,OL-Rph	RMU fault at SBI Staff College	Partial fdr charged & remaining loads added on 11KV Ameerpet fdr
2		Muffakamja College	Venkateshwara Hills	11KV	Banjarahills	16.35	17.40	01.05	EL	End Kit failed at Old Andhra Jyothi	-
1	HYD C	Amberpet	6 No. Road	11KV	Azamabad	14.30	15.35	01.05	EL,OL-R&Bph	Pin Insulator flash over at 6No. X Road	-
2		Zamistanpur	L.N. Nagar	11KV	Azamabad	16.42	18.01	01.19	EL	Lizard fallen on DTR at Ashok Nagar Nala	-
3		Bathkamma Kunta	Ayyappa Temple	11KV	Azamabad	16.57	19.45	02.48	OL-Rph	Pin Insulator flash over at Sai Datta Hospital	-
4		Bathkamma Kunta	Saibaba Temple	11KV	Azamabad	16.58	18.30	01.32	OL-Rph	Tree branches fallen on lines at Sri Rama Tower	-