

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		8		8		8			
8	Hyd	194	1044		8		8		8			
	Total	606	3055	0	23	0	23	0	23	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		13		13		13			
3	MDK	107	933		7		7		7			
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	32	1	32	1	32	0	0	
	Grand Total	1082	6468	1	55	1	55	1	55	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	TT Doddi	33KV	Gadwal	20.39	21.07	00.28	E/L	No Visible Fault Due to Rain	leeza	No

TSSPDCL - LMRC / Corporate office

Date: 02.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pedda Revally	Pedda Revally	11KV	Jadcherla	02.00	08.45	06.45		11KV Insulator fail near Devinigutta Thanda	-
2		Mallaboinpally	Mallaboinpally	11KV	Jadcherla	11.00	13.42	02.42		11KV Jumper cut near Komani Konta Thanda	-
3		Karkonda	Rudraram	11KV	Jadcherla	00.00	10.50	10.50		11KV Disk fail near Rudraram	-
1	NLG	Turkapally	M.Gowraram	11KV	Nalgonda	06.35	08.40	02.05	EL	11KV Line Insulator Failur	-
2		Indugula	Kothagudam	11KV	Nalgonda	07.30	10.30	03.00	EL	11KV Jumper Cut	-
3		Rajupeta	Rajupeta	11KV	Nalgonda	03.00	05.00	02.00	EL	HT/LT Melting	-
4		Kethepally	Korlapahad	11KV	Nalgonda	03.30	06.00	02.30	EL	11KV Line Insulator Failur	-
5		Kethepally	Chikatigudem	11KV	Nalgonda	02.30	05.15	02.45	EL	11KV Line Disc Failur	-
6		Matoor	Matoor	11KV	Miryalguda	02.40	03.50	01.10	EL	Tre fallen on 11KV line	-
7		Jammigadda	Town	11KV	Suryapet	13.00	15.00	02.00	EL	Disk failed	-
8		Athmakur(s)	Dacharam	11KV	Suryapet	09.50	10.50	01.00	EL	Insulator failed	-
9		Gaddipally	Kutubshapuram	11KV	Huzuragar	03.00	06.30	03.30	EL	11 KV JUMPER CUT	-
10		Munagala	Tadvai	11KV	Huzuragar	03.50	06.30	02.40	EL	11 KV DISK FALIED	-
11		Dirincherla	Yallapuram	11KV	Huzuragar	04.30	07.00	02.30	EL	11 KV LINE SNAPPED	-
12		Palakeedu	Bothalapalem	11KV	Huzuragar	15.30	17.20	01.50	EL	11 KV LINE SNAPPED	-
13		Datherpally	Mallapuram	11KV	Bhongir	05.00	09.00	04.00	EL	11kv Insulator Failed	-
1	MDK	Bollaram - II	Vipla	11KV	Patancheru	10.30	12.20	01.50		B/D Due to Insulator Failure	-
2		Bollaram - II	Rupa	11KV	Patancheru	00.05	03.45	03.40		B/D Due to tree branches fallen on the line	-
3		Patancheru Town	Town	11KV	Patancheru	18.30	19.30	01.00		B/D Due to Insulator Failure	-
4		Patancheru Town	MIA-I	11KV	Patancheru	00.25	02.30	02.05		B/D Due to Insulator Failure	-
5		Patancheru Town	Allwyn	11KV	Patancheru	02.30	03.25	00.55		B/D Due to Conductor Snapped	-
6		Bollaram - I	Sulaxshana-I	11KV	Patancheru	03.30	05.40	02.10		B/D Due to Jumper Cut	-
7		Anrich Bollaram	Sukaso	11KV	Patancheru	05.45	06.10	00.25		B/D Due to Jumper Cut	-
1	SDPT	Samudrala	Samudrala (R)	11KV	Husnabad	04.30	09.30	05.00		BD,Insulator failure	-
2		Shanigaram	Thangallapally	11KV	Husnabad	00.30	06.30	06.00		BD, Due to rain	-
3		Chityal	Thadoor	11KV	Husnabad	08.50	09.30	00.40		BD, Tree fallen on line	-
4		Guruvannapet	Posanpally	11KV	Husnabad	00.00	06.30	06.30		BD, Insulator failure	-
5		Guruvannapet	Tapaspally	11KV	Husnabad	00.00	10.50	10.50		BD, Conductor snapped	-
6		Gandipally	Ramavaram	11KV	Husnabad	03.30	08.20	04.50		BD, Insulator failure	-
7		Koheda	Theegalakuntapally	11KV	Husnabad	09.00	11.00	02.00		BD, Conductor snapped	-
8		Dhoolmitta	Arjunpatla	11KV	Husnabad	01.00	13.20	12.20		BD, Insulator failure	-
9		Thotapally	Dacharam Rural	11KV	Husnabad	03.50	11.00	07.10		BD, Insulator failure	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Jeedimetla-I	Phase-II	11KV	Jeedimetla	13.30	14.30	01.00	EL/OL	11kv Endy Kit failure At Nakota chemical	-
2		Jeedimetla-III	Pipe Line road	11KV	Jeedimetla	15.35	16.35	01.00	EL/OL	11kv jumper Cut AT vijaya sree chemical	-
3		Jeedimetla-III	FOX Sagar	11KV	Jeedimetla	07.12	08.42	01.30	EL/OL	11kv Pin insulator failure At ram reddy nagar	-
4		Jeedimetla-I	H M T	11KV	Jeedimetla	20.03	21.45	01.42	EL/OL	Heavy rain	-
5		Subhash Nagar	Ramaraj Nagar	11KV	Medchal	17.20	17.50	00.30	EL/OL	11KV Jumper cut and replaced at Prapurna Enclave	-
6		Aliabad	HBL	11KV	Medchal	04.50	06.45	01.55	EL	Tree fallen on the 11KV Line at Nayagara Company	-
7		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	10.30	11.30	01.00	EL	HG Fuse Insulator failed at Chaitanya School	-
1	RR E	Cherlapally-II`	Ghajanna Thamara	11KV	Sainikpuri	01.26	02.40	01.14		11Kv line Patrolling Done But no fault found (AE)	-
2		Kushaiguda	Kapra	11KV	Sainikpuri	07.19	08.15	00.56		11Kv 3 line cut at Parimala Nagar (L Insp Nageshwar Rao)	-
3		Cherlapally-II`	Ghajanna Thamara	11KV	Sainikpuri	20.56	22.30	01.34		11Kv Pin Insulator failed and HG Fuse failed near Iccom Company Phase-I	-
4		Nacharam Indore	Kakathiya Karshak	11KV	Habsiguda	12.22	18.50	06.28		11KV cable fault Consumer side & rectified in Kakathiya Karshak Company near Road No.16 at Nacharam(Dedicated feeder)	-
5		St.No.08	Greenhills	11KV	Habsiguda	15.06	16.22	01.16		11KV AB Cable failed near Saketh Apartment at St.No.08 Habsiguda	-
6		CRPF	Chennapur	11KV	Keesara	10.56	11.45	00.49		11KV AB Switch copper patti cut near Crusher Crane at Ardaspally & 11KV Breaker fault at Dumping Yard	-
7		P&T Colony	Budda Nagar	11KV	Keesara	01.05	04.10	03.05		11KV Pin Insulator failed at Budda Nagar Road No.01	-
8		P&T Colony	Chengicherla	11KV	Keesara	01.25	03.25	02.00		11KV Pin Insulator failed at Medipally Petrol bunk	-
1	HYD N	Macha Bollaram	Reddy Enclave	11KV	Bowenpally	16.18	17.59	01.41	EL,OL	AB Cable fault at Janaki Ram Colony	-
2		Osm. University	Mettuguda	11KV	Sec-Bad	18.55	20.10	01.15	OL-Yph	Big tree fallen on lines	-
3		Kalyan Nagar	Rahamath Nagar	11KV	Banjarahills	21.04	23.15	02.11	EL	Cable End Kit fault & HT Jumper cut at Gurdwara Galli	-
1	HYD C	Jawahar Nagar	Ashok Nagar	11KV	Saifabad	06.14	07.50	01.36	OL-Bph	Tree branches fallen on lines at Ashok Nagar Chaman	-----
2		Jawahar Nagar	Ashok Nagar	11KV	Saifabad	08.25	10.25	02.00	EL	I/C Cable fault	Arranged B/F on 11KV Kuchipudi fdr
3		Indira Park	Datta Nagar	11KV	Saifabad	10.38	11.40	01.02	EL,OL	Cable fault at Ashok Nala	-----
4		Bathkammakunta	Ayyappa Temple	11KV	Azamabad	21.28	22.36	01.08	EL	Disc Insulator flash over near Library	-
5		Narayanaguda	Narayanaguda	11KV	Azamabad	21.55	23.10	01.15	EL,OL-Yph	Pin Insulator flash over at Deepak Theater	-