

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	2	5	2	5	2	5			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		4		4		4			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		12		12		12			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>26</b>	<b>2</b>	<b>26</b>	<b>2</b>	<b>26</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 03.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Malkaram	33KV Shameerpet	33kv	Medchal	07.06	10.45	03.39		33KV Line problem at Bits Compound	33KV Shameerpet	-
2		132KV LGM Pet	33KV LGM Pet	33kv	Medchal	02.58	03.30	00.32		33KV Jumper Cut at Chemo Company(Backfeeding to 33KV Ratnalayam feeder from 132KV Malkaram)	33KV LGM Pet	-

TSSPDCL - LMRC / Corporate office

Date: 03.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Vemula	Dasarpally	11kv	Jadcherla	04.00	12.47	08.47		11Kv Disc Fail Near Dasarpally (V)	-
2		Ponnakal	Rachala	11kv	Jadcherla	13.20	15.30	02.10		11Kv Line Cut Near Rajeshwarreddy bavi Side	-
1	NLG	Arlagaddagudem	Suraram	11kv	Nalgonda	06.00	12.10	06.10	EL	Tree branches fallen on 11KV line at AGL lands, Suraram(V)	-
2		Agamothkur	Bommakal	11kv	Miryalguda	14.50	16.00	01.10	EL	Tree branches fallen on 11KV line near village	-
3		Thimmapuram	Shanthi Nagar	11kv	Miryalguda	10.04	11.30	01.26	EL	11KV insulator failed near Turupu Thanda village	
4		Munagala	Nelamarry	11kv	Huzurnagar	07.30	10.35	03.05	EL	Due to 11Kv insulator failed	
5		Keethavarigudem	Velidanda	11kv	Huzurnagar	06.45	09.30	02.45	OL	Due to 11Kv jumper cutted	
6		Repala	V R Puram	11kv	Huzurnagar	12.35	15.30	02.55	EL	Due to 11Kv insulator failed	
7		Mukundapuram	Somaram	11kv	Huzurnagar	12.55	15.45	02.50	EL	Due to Tree branch fall on 11Kv line	
8		Nandanam	Anajipuram	11kv	Bhongir	04.00	07.00	x	EL	11 kv Insulator Failed & 11 KV Line Snapped at Poultry farm Near Anajipuram Village	
9		Raigiri	Jammapur Agl	11kv	Bhongir	12.00	17.00	05.00	EL	11 kv 2 no.s Disc Failed Near Jammapur Village	-
10		Motakondur	Motakondur Agl	11kv	Bhongir	14.00	15.30	01.30	EL	11 Kv Disc Failed Near Motakondur Village	-
11		Athmakur	Thukkapuram	11kv	Bhongir	08.30	11.00	02.30	EL	11 kv Insulator Failed Near Sub-station Back side	-
12		IPDS Choutuppal	Dhamara	11kv	Choutuppal	05.46	08.56	03.10	EL	11 kv Insulator Failed Near Dhamara Village	-
1	RR N	Jeedimetla-I	Raghava	11kv	Jeedimetla	14.55	17.15	02.20		11kv line Endkit failure at opp:KLJ Plastic at Phase-I	-
2		HMT	Gandhi Nagar	11kv	Medchal	17.55	18.05	00.10		Backfeeding arranged from 11KV Bhagath Singh Feeder from Chinthal SS	-
3		Ravalkole	Ravalkole	11kv	Medchal	09.55	10.55	01.00		11KV Line Cut & Replaced at Mallanna Temple Opposite, Ravalkole	-
4		Subhash Nagar	Jairam Nagar	11kv	Medchal	04.01	05.50	01.49		Tree fallen on the 11KV Line at Countinya Club	-
5		Athiwelly	Dabeerpur	11kv	Medchal	18.50	20.00	01.10		11KV Pin Insulator failed near SS	-
1	RR E	RGK	Nissa	11kv	SKP	16.30	17.40	01.10		11Kv Disk failed at Singayapally Gate-I (LM Rajender)	-
2		Moula-Ali	Jawahar Nagar	11kv	SKP	15.00	15.50	00.50		11Kv AB Switch Open at Jawahar Nagar Water Tank (L.Insp Venkateshwarulu) due to 11Kv Insulator failed at Andhra Bank	-
3		Moula-Ali	HCL	11kv	SKP	18.00	18.40	00.40		Tree branches fallen on 11Kv line at Krishna Nagar Road No.7 AE/Moula-Ali)	-
1	HYD N	LV Prasad Marg	Cine Max	11kv	X	18.48	19.56	01.08	EL,OL-Rph	No Visible Fault	-----
2	HYD S	C.R.P.F.	Balapur	11kv	III	03.25	05.07	01.42	EL	Cable fault	Partial fdr charged at 04:00Hrs & remaining loads added on 11KV Omer Colony fdr
3	Hyd C	Asif Nagar	N.S.F. Colony	11kv	VII	01.45	02.55	01.10	EL,OL-Rph	AB Cable fault at Ice Factory (2No. DTR's kept Off)	-----
4		Amberpet	C.P.L.	11kv	II	08.55	10.50	01.55	EL,OL-Y&Bph	Big tree fallen on lines at CPL Ground	-----