

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	2		2		2				
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	2	6	2	6	2	6	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		9		9		9			
3	MDK	107	933	1		1		1				
4	SDPT				11		11		11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	21	1	21	1	21	0	0	
	Grand Total	1082	6468	3	27	3	27	3	27	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Watpally	Medikunda	33kv	Jogipet	13.27	19.00	05.33		BD due to 4no.s Poles Damaged	Medikunda	-
1	RR N	132KV Malkaram	33KV Shameerpet	33kv	Medchal	07.06	10.45	03.39		33KV Line problem at Bits Compound	33KV Shameerpet	-
2		132KV LGM Pet	33KV LGM Pet	33kv	Medchal	02.58	03.30	00.32		33KV Jumper Cut at Chemo Company(Backfeeding to 33KV Ratnalayam feeder from 132KV Malkaram)	33KV LGM Pet	-

TSSPDCL - LMRC / Corporate office

Date: 04.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Gangapur	11kv	Jadcherla	14.36	16.24	01.48		Due to 11 KV Bus bar cut near Aloor railway gate	-
1	NLG	Madgulapally	Dacharam	11kv	Nalgonda	08.15	11.30	03.15	E/L	SS-5 Brass Patti Failed	-
2		Thurkapally	M.Gouraram	11kv	Nalgonda	13.35	14.39	01.04	E/L	Tree Branches Fallen on the Line	-
3		Athmakur(S)	T.Penpahad	11kv	Suryapet	04.30	06.00	01.30	E/L	11Kv Conductor snapped	-
4		Janpahad	Sunypahad Lift	11kv	Huzurnagar	10.00	13.00	03.00	E/L	11kv Disk failed	-
5		Raghunadapalem	Gundlapally	11kv	Huzurnagar	06.30	09.30	03.00	O/L	11Kv insulator failed	-
6		Mattapally	Mattapally	11kv	Huzurnagar	11.00	14.00	03.00	E/L	11kv Disk failed	-
7		Mellacheruvu	Y madaram	11kv	Huzurnagar	10.12	13.15	03.03	E/L	11kv Disk failed	-
8		Nemaragommula	Nemaragommula	11kv	Bhongir	09.00	11.00	02.00	E/L	11kv Insulator Failed near Nemaragommula (V) 3 Phase B/d Single Phase OK	-
9		Motakondur	Motakondur Agl	11kv	Bhongir	10.30	13.00	02.30	E/L	11kv Insulator Failed near Motakondur (V)	-
1	SDPT	Mustabad Chowrasta	Kotilingal	11kv	Siddipet	11.30	11.35	00.05		EL	-
2		Mustabad Chowrasta	Kotilingal	11kv	Siddipet	12.40	12.50	00.10		LC for AB Switch works LC No.15158	-
3		Mustabad Chowrasta	Kotilingal	11kv	Siddipet	13.35	13.40	00.05		LC for AB Switch works LC No.15159	-
4		Mustabad Chowrasta	Kotilingal	11kv	Siddipet	16.00	16.15	00.15		LC for Jumper works LC No.15160	-
5		Indore	Old Bus Stand	11kv	Siddipet	05.40	06.50	01.10		B/D	-
6		Indore	Town PS	11kv	Siddipet	06.55	07.00	00.05		EL	-
7		Indore	Town PS	11kv	Siddipet	12.20	12.40	00.20		LC for Tree Cutting LC No.7284	-
8		Komaticheruvu	Sri Nagar Colony	11kv	Siddipet	16.25	16.30	00.05		EL	-
9		Peddakodur	Chinnakodur	11kv	Siddipet	11.10	12.10	01.00		LC for Fuse of call LC No.16604	-
10		Dubbak	Dubbak	11kv	Siddipet	09.30	09.44	00.14		LC for Fuse wire fail LC No.15964	-
11		Dubbak	Dubbak	11kv	Siddipet	12.14	12.30	00.16		LC for LT Conductor cut LC No.15965	-
1	RR E	Aushapur	Madharam	11kv	Keesara	12.10	16.50	04.40		11KV Polymer disc failed at Madharam Village Backside	-
2		Balaji Nagar	Mahankali	11kv	Keesara	20.40	22.10	01.30		11KV Pin Insulator Failed Near Indus School Balaji Nagar	-
1	HYD S	Ch' Baradari	Dood Bowli	11kv	Charminar	05.25	07.00	01.35	EL	Cable fault at Ganesh Temple	-
2		Hyderguda	Jana Priya OH	11kv	Charminar	22.05	23.30	01.25	EL	Cable fault at Narayana College	-
3	HYD N	Madhapur	Vaishnavi Residency	11kv	Jubilee Hills	16.13	17.29	01.16	All indication	Cable fault	-
4	HYD C	Bathkamma Kunta	D.D.Colony	11kv	Azamabad	21.55	23.15	01.20	EL	Pin Insulator flash over at D.D.Colony	-