

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		8		8		8			
	Total	606	3055	0	12	0	12	0	12	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933		1		1		1			
4	SDPT				6		6		6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	12	1	12	1	12	0	0	
	Grand Total	1082	6468	1	24	1	24	1	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.09.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shanthinagar	33KV	Gadwal	14.45	16.05	01.20	EL	Tree fallen on the 33KV line near Shanthinagar	Shanthinagar	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narketpally	Mandra	11KV	Nalgonda	12:30	15:00	2:30	E/L	Tree Branches Fallen on the Line	No
2		P.D.Pally	P.D.Pally	11KV	Nalgonda	10.50	14.10	03.20	E/L	Tree Branches Fallen on the Line	No
3		Velugupally	Keshavapuram	11KV	Suryapet	11.00	12.35	01.35	E/L	Bird fallen on the line	No
4		Palakeedu	Nagireddy gudem	11KV	Huzurnagar	15.45	17.00	01.15	EL	11 KV Line snapped	No
5		Ananthagiri	Ameenabad	11KV	Huzurnagar	14:05	16:30	1:55	EL	11 KV Jumper cut	No
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	2:10	6:50	4:40		Insulator failed	No
1	SDPT	Markook	Sneha	11KV	Gajwel	0:00	4:00	4:00		Disc failure	
2		Markook	Markook Agl	11KV	Gajwel	04.00	08.15	04.15		Insulator failure	
3		Gouravelly	Gudatipally	11KV	Husnabad	11.50	14.50	03.00		LT line cut	
4		Akunoor	Rampoor	11KV	Husnabad	15.15	18.15	03.00		Bird fallen on two lines, same rectified	
5		Mustyal	Chuchanakota	11KV	Husnabad	00.00	11.35	11.35		Insulator failure	
6		Chityal	Thadoor	11KV	Husnabad	4:15	6:00	1:45		Insulator failure	
1	RR N	Suraram	Venkatramnagar	11KV	Jeedimetla	12:28	14:35	2:07		11kv line AB Cable failure near Jiya Super Market at Venkateshwer Nagar	No
2		Jeedimetla-II	Phase-V	11KV	Jeedimetla	20.00	21.05	01.05		11kv line End kit failure at Sai krishana Conttner, Phase-V	No
3		Gowdawelly	IDA Gowdawelly	11KV	Medchal	18.50	19.50	01.00		Tree fallen on the 11KV Line at Basaragadi	No
1	RR E	Moula-Ali	Kailasgiri	11KV	Sainikpuri	19:40	20:20	0:40		HG fuse Insulator failed at Sagar Construction	No
1	HYD N	Bowenpally	B.B.R Hospital	11KV	VI	14.10	15.35	01.25	EL	Cable fault	Arranged B/F on 11KV Samrat fdr
2		Tirumalagiri	Officers Colony	11KV	C-VI	15:05	16:10	1:05	EL,OL-Rph	Pin Insulator flash over at Officers Colony	No
3		Tirumalagiri	Officers Colony	11KV	C-VI	18:20	20:08	1:48	EL,OL-R&Yph	Disc Insulator flash over at Little Fower School	No
4		Ravindra Society	Sri Chaitanya	11KV	X	19:10	20:25	1:15	OL	No Visible Fault	No
5		Gunrock	Surya Enclave	11KV	C-VI	19.20	20.20	01.00	EL,OL-Bph	DTR fault at S.P Colony	No
6		Chinna Thokatta	Dubai Gate	11KV	VI	19.41	21.08	01.27	EL	Jumper cut at HDFC Bank	No
7		Macha Bollarum	Ayyappa Nagar	11KV	C-VI	21:19	0:20	3:01	OL	Jumper cut at Errukala Basti	22:01 Hrs Partial arranged B/F on 11KV Mangapuram Colony fdr
1	HYD C	Bathkammakunta	Indira Nagar	11KV	II	06.05	07.27	01.22	EL	Jumper cut at Tilak Nagar Railway Track	No