

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>17</b>	<b>1</b>	<b>17</b>	<b>1</b>	<b>17</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 07.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Medchal	33KV Santha Bio Tech	33KV	Medchal	03.36	12.10	08.34	BD	33KV UG Cable failed at ITI College	33KV Santha Bio Tech	-

TSSPDCL - LMRC / Corporate office

Date: 07.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Mallepally	11KV	Jadcherla	09.10	10.40	01.30		11 KV jumper cut near Rangareddy guda.	-
2		Udityal	Macharam	11KV	Jadcherla	10.48	12.29	01.41		11 KV wire cut near Jalgadda thanda.	-
1	NLG	Agamothkur	Chirumarthy	11KV	Miryalaguda	12.35	16.45	04.10	E/L	Jumpet Cut	-
2		Nampally	M.R.Pally	11KV	Devarakonda	12.50	15.00	02.10	E/L	11KV Conductor Cut	-
3		Mattapally	Ramachandrapuram	11KV	Huzurnagar	05.00	07.25	02.25	EL	11 KV LINE SNAPPED	-
4		Gaddipally	Ponugodu	11KV	Huzurnagar	07.00	09.30	02.30	EL	11 KV LINE SNAPPED	-
5		Dondapahad	Vajinepally	11KV	Huzurnagar	06.20	07.30	01.10	EL	11 KV JUMPER CUT	-
6		Manaikunta	Gattusingaram	11KV	Bhongir	05.00	09.00	04.00	EL	11 kv Line Snapped at Gangadeamma temple Near Gattusingaram Village. 3 Phase B/d Single Phase OK	-
7		Chamapur	Chamapur	11KV	Bhongir	04.00	08.30	04.30	EL	11 kv Line Snapped Near Chamapur Village. 3 Phase B/d Single Phase OK	-
1	SDP	Mustyal	Cherial Town	11KV	Husnabad	15.30	11.30	20.00		Disk fail	-
2		Guruvannapet	Posanpally	11KV	Husnabad	10.30	10.50	00.20		Insulator Brust	-
1	RR S	Chanda Nagar	Rail Vihar	11KV	Gachibowli	08.00	09.10	01.10	BD	11kv Cable failed at Brundavan Hotel	-
1	RR N	Keshavaram	Potharam	11KV	Medchal	13.25	15.35	02.10	BD	11KV Jumper & Brass Patti Cut & Replaced at Jonna Banda, Forest	-
1	RR E	Moula-Ali	Moula-Ali	11KV	Sainikpuri	11.17	12.02	00.45		Tree branches fallen on 11Kv line at Unani Hospital (AE/OP)	-
1	HYD N	Road No.2	Arora Colony	11KV	X	02.35	04.13	01.38	EL	Tree branches fallen on lines at Arora Colony	-
2		Patigadda	Sanjeevaiah Park	11KV	V	09.15	10.25	01.10	EL	AB Cable fault at Sanjeevaiah Park Railway Station	-
1	HYD C	Amberpet	Play Ground	11KV	II	01.15	02.23	01.08	EL,OL-Yph	No Visible Fault	Arranged B/F on 11KV Bapu Nagar feeder