

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1						1		1 No. 33KV Still
2	NLG	144	988		8		8		8			
3	MDK	107	933		1		1		1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	10	0	10	0	10	1	0	
	Grand Total	1082	6468	1	16	0	16	0	16	1	0	

TSSPDCL - LMRC / Corporate office

Date: 13.09.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amarchintha	Chandragattu Lift	33KV	Wanaparthu	22.58	00.00	01.02		Tripped on EL & OL	Chandragattu Lift	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thungathurthy	Vempaty	11KV	Suryapeta	5:00	7:35	2:35	E/L	Insulator failed	No
2		Tekumatla	Yandlapally	11KV	Suryapeta	05.30	07.30	02.00	E/L	Disc failed	No
3		Repala	N S gudem	11KV	Huzurnagar	04.30	07.00	02.30	EL	11KV Line snapped	No
4		Raghunadapalem	Gundlapally	11KV	Huzurnagar	06.00	08.45	02.45	EL	11KV Disc failed	No
5		Ponugodu	Velidanda	11KV	Huzurnagar	03.36	06.30	02.54	EL	11KV Line snapped	No
6		Kethepally	Korlapahad	11KV	Nalgonda	05.00	08.00	03.00	EL	11KV Jumper cut	No
7		Eduloor	Munukuntla	11KV	Nalgonda	03.00	07.30	04.30	EL	11KV Jumper cut	No
8		Palem	Ogodu	11KV	Nalgonda	4:00	6:30	2:30	EL	11KV Jumper cut	No
1	MDK	Patancheru Town	MIA-II	11KV	Patancheru	12:25	16:25	4:00		Tree fallen on the 11KV line	No
1	SDPT	Dharmaram	Dharmaram R	11KV	Husnabad	8:30	9:40	1:10		Male female blade failed	No
1	RR N	Subhash Nagar	Jairam Nagar	11KV	Medchal	5:50	6:55	1:05		No visible fault	No
2		Gowdawelly	Ayodya	11KV	Medchal	11.30	13.20	01.50		11KV Line cut and replaced at Saketh Venture	No
1	RR E	P&T colony	Budda nagar	11KV	Keesara	23:50	1:00	1:10		11KV Pole broken at Surya hospital	No
1	HYD N	Allwyn	Mothi Nagar	11KV	IV	00.50	02.35	01.45	EL	No Visible Fault	No
1	HYD S	Yakuthpura	Dharmavath	11KV	VIII	00.40	02.16	01.36	EL,OL-Yph	Cable touching to Channel at 1st line AB Switch near SS	No
2		Aliyabad	Police Quarters	11KV	III	21:09	22:45	1:36	OL-Rph	Isolated faulty AB Cable End Kit & Connected OH Jumpers at Kabrasthan	No