

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	1	3	1	3	1	3			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		18		18		18			
	Total	606	3055	1	28	1	28	1	28	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		9		9		9			
3	MDK	107	933		1		1		1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	12	1	12	1	12	0	0	
	Grand Total	1082	6468	2	40	2	40	2	40	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Chinnamaroor	Jetprole	33kv	Wanaparthi	20.35	22.15	01.40	EL	Tree branch follen on the line and removed	Jetprole	-
1	RR N	132KV Malkaram	33KV Ratnalayam	33kv	Medchal	07.50	13.55	06.05		No visible Fault	33KV Ratnalayam	-

TSSPDCL - LMRC / Corporate office

Date: 17.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kollur	Kollur	11kv	Jadcherla	14.30	15.00	00.30		11KV Jumper cut near Kollur	-
1	NLG	B.Chandupatla	V.K Pahahd	11kv	Suryapeta	05.40	08.30	02.50	E/L	Disk failed	-
2		Alingapuram	Channaipalem	11kv	Huzurnagar	04.15	07.17	03.02	EL/OL	Due to 11Kv Disk Failure	-
3		Ananthagiri	Ameenabad	11kv	Huzurnagar	15.45	17.00	01.15	EL	Due to 11Kv line cutted	-
4		Thogarrai	Kuchipudi	11kv	Huzurnagar	15.28	16.55	01.27	OL	Due to 11kv jumper cutted	-
5		Pottichalma	Ramannagudem	11kv	Miryalaguda	16.00	17.30	01.30	EL	Due to heavy gale and wind	-
6		Pottichalma	Parvedula	11kv	Miryalaguda	16.40	18.00	01.20	EL	Due to heavy gale and wind	-
7		Mupparam	Guntakagudem	11kv	Miryalaguda	15.45	16.50	01.05	EL	Due to heavy gale and wind	-
8		Mothkur	Areygudem	11kv	Bhongiri	13.25	15.25	02.00	OL	Tree Branch Fallen at Line Near Areygudem Village	-
9		Gundala	Gundala Rural	11kv	Bhongiri	07.15	09.30	02.15	EL	100 kva DTR Failed at SS-5 Near Gundala Village.	-
1	MDK	Sadasivpet	TSM	11kv	Sangareddy	02.04	07.09	05.05		B/D DUE TO TREE FALL DOWN ON LINE AT IBZA COMPANY	-
1	SDPT	Husnabad	Town I	11kv	Husnabad	12.35	12.45	00.10		Line cut	-
1	RR S	Nallagandla	EPISPOM School	11kv	Gachibowli	01.10	02.45	01.35		11kv Line AB switch opened (11kv Pin insulator failed at EPISPOM school)	-
2		Gachibowli	Kalajyothi	11kv	Kondapur	00.50	02.10	01.20		11kv AB Switch jumper cut at Kalajyothi	-
1	RR N	KPHB	Jalavyu Vihar	11kv	Kukatpally	22.50	23.59	01.09	EL	Due To Heavy Rain	-
2		KPHB	Gowtaminagar	11kv	Kukatpally	22.48	23.58	01.10	EL	Due To Heavy Rain	-
3		KPHB	HyderNagar	11kv	Kukatpally	22.52	23.58	01.06	EL	Due To Heavy Rain	-
1	RR E	Yapral	Pradhampuri	11kv	Sainikpuri	22.50	00.25	01.35		Tree branches fallen on 11Kv line at Mythri Enclave near TulasiGarden (Artisian Raju)	-
2		Kushaiguda	Kushaiguda	11kv	Sainikpuri	22.54	00.20	01.26		11Kv line AB Switch opened at Sai Sudheer college Due to Tree branches touching on 11Kv line (AE)	-
3		Kushaiguda	Rukminipuri	11kv	Sainikpuri	23.41	00.50	01.09		100Kva T/F cable kit failure at Srinivas Nagar (AE)	-
4		IICT	Snehapuri	11kv	Habsiguda	23.20	01.20	02.00		AB swith insulator fail at Radhka enclave snehapuri colony	-
5		NGRI	HMT nagar	11kv	Habsiguda	23.30	02.00	02.30		Tree branches fallen on 11kv line at Sarawathi nagar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	R.P Nilayam	Rythu Bazar	11kv	C-VI	22.45	01.00	02.15	All Indication	No Visible Fault	Arranged B/F on 11KV Chinthal Bazar feeder
2		Clock Tower	Railway Reservation	11kv	V	23.00	01.10	02.10	EL,OL-R&Yph	CT PT fault at Rama Krishna Hotel	-----
3		Zamistanpur	MCH Park	11kv	V	23.00	01.50	02.50	EL,OL-Bph	Tree branches fallen on lines at Garunda Apts	-----
4		Toli Chowki	Road No.86	11kv	X	23.04	00.15	01.11	All Indication	No Visible Fault	-----
5		I.D.P.L	Wonder Plast	11kv	VI	23.20	01.15	01.55	EL	Pin Insulator flash over at Plot No.42/A	-----
6		Prashanth Nagar	Colgate	11kv	VI	23.20	01.38	02.18	EL	I/C Cable fault	Arranged B/F on 11KV Tipcon feeder
1	HYD S	Miralam	Ansari Road	11kv	III	06.50	08.20	01.30	EL,OL-Bph	HT Line snapped, Pin Insulator flash over at Idli Hotel & Twisted lines at Ansari Road	-----
2		Miralam	Mustafa Nagar	11kv	III	22.25	01.05	02.40	EL	I/C Cable fault	Arranged B/F on 11KV Ansari Road feeder
3		Hyderguda	W.S Colony	11kv	III	22.55	01.22	02.27	EL,OL	Pin Insulator flash over at New Gold Drop & DTR AB Cable fault at Rambagh	-----
4		Gosha Mahal	M.J Market	11kv	IX	22.55	01.40	02.45	EL,OL-Y&Bph	No Visible Fault	-----
5		Ch' Baradari	Fire Station	11kv	III	23.25	01.45	02.20	EL,OL-Bph	Tree branches fallen on lines at backside Fire Station	-----
6		Yakuthpura	Dharmavath	11kv	VIII	23.53	01.30	01.37	EL,OL-Rph	Channel touching to AB Switch at Bada Bazar Chilla	-----
1	HYD C	Hyderguda	Abids	11kv	I	22.58	00.20	01.22	EL	Cable End Kit fault at Lepakshi	
2		Golconda	Brindavan Colony	11kv	VII	23.00	01.40	02.40	EL	Faulty loads of 11KV Hakimsha feeder	
3		Toli Chowki	B.S.N.L	11kv	VII	23.15	00.45	01.30	All Indication	No Visible Fault	
4		Golconda	Mothi Mahal	11kv	VII	23.30	00.35	01.05	EL	No Visible Fault	
5		A.S.R Raju Nagar	GHMC Park	11kv	VII	23.30			EL		
6		I.T.I Mallepally	Zahira Masjid	11kv	VII	23.34	01.56	02.22	EL	Tree branches fallen on lines at Zahira Masjid	