

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		7		7		7			
	Total	606	3055	0	14	0	14	0	14	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	2	3	2	3	2			
2	NLG	144	988		8		8		8			
3	MDK	107	933	1		1		1				
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	13	4	13	4	13	0	0	
	Grand Total	1082	6468	4	27	4	27	4	27	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Arabindo	33KV	Jadcherla	09.37	12.00	02.23	E/L&O/L	Due to Problem in Company	Polepally	No
2		Wanaparthly	Buddaram	33KV	Wanaparthly	15.31	19.14	03.43	E/L	3No Disc Replacement at Buddaram SS Back Side	Wanaparthly	No
3		Amangal	Mudwin	33KV	Shadnagar	16.25	18.40	02.15	E/L	33KV Pole Crossed and Touched 11KV Line Near Kadthal Toll Plaza	Amangal	No
1	MDK	Gummadidala	GPSS-1	33KV	Patancheru	15.30	16.35	01.05		B/D due to Jumper cut		-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Town	11KV	Jadcherla	04.00	06.50	02.50		Bird Died on The 11Kv line Near Adhya Mines.	-
2		Nawabpet	Gurukunta	11KV	Jadcherla	06.10	10.40	04.30		DTR Failure At Gurukunta(Vi)	-
1	NLG	Akaram	Vadhipamula	11KV	Nalgonda	07.00	10.00	03.00	EL	11 KV Line Jumper Cut	-
2		Sh.Gowraram	Kondaram	11KV	Nalgonda	07.35	12.05	04.30	EL	11 KV Line Jumper Cut	-
3		Kamreddy Gudem	Konthalapally	11KV	Miryalaguda	09.15	10.35	01.20	EL	11KV Conductor snapped near village	-
4		P.A.Pally	Akkampally	11KV	Devarakonda	07.00	10.00	03.00	EL	11 kv Line Cut	-
5		P.A.Pally	Guddipally	11KV	Devarakonda	09.00	11.00	02.00	EL	11 Kv Insulator Failed	-
6		Kudakuda	Kudakuda AGL	11KV	Suryapet	07.30	10.10	02.40	E/L	Insulator falshover	-
7		Penpahd	Penpahd	11KV	Suryapet	06.00	08.10	02.10	E/L	Conductor snapped	-
8		Kodad Town	Srirangapuram	11KV	Huzurnagar	15.45	17.35	01.50	EL	Due to 11kv jumper cutted	-
1	SDPT	Potharam	Potharam rural	11KV	Husnabad	06.35	07.35	01.00		Line cut	-
2		pandilla	Potlapelly	11KV	Husnabad	08.30	10.40	02.10		Jumper cut	-
3		Rebarthy	Laddunoor	11KV	Husnabad	17.20	18.50	01.30		Jumper cut	-
1	RR S	IDPL	Power Nagar	11KV	Kondapur	13.05	15.30	02.25	BD	Outgoing Jumper cut in IDPL Sub-Station(Due to heavy rain)	-
1	RR N	Dulapally	Prasanth Nagar	11KV	Medchal	13.05	14.10	01.05		No Fault	-
2		Kandlakoya	Godrej	11KV	Medchal	15.17	16.40	01.23		Tree Branch fallen on the 11KV Line at Nujiveedu Seeds	-
3		Pudur	Munirabad	11KV	Medchal	16.46	17.30	00.44		11KV Pin Insulator Failed at Munirabad Village	-
1	RR E	IDA Uppal	Devender Nagar	11KV	Habsiguda	06.55	07.25	00.30		Line patrolling but no visible fault	-
2		St.No.08	ISI	11KV	Habsiguda	19.41	20.32	00.51		11KV Pin Insulator failed at JSN Colony	-
3		VP Nagar	Brudhavan Colony	11KV	Sainikpuri	15.50	16.20	00.30		11Kv Pin Insulator failed at Sapthagiri colony (L.Insp Chandra Shekar)	-
1	HYD N	Macha Bollaram	Madhura Enclave	11KV	C-VI	15.05	16.15	01.10	EL,OL-Bph	No Visible Fault	-
1	HYD C	Langer House	Pensionpura	11KV	VII	10.20	11.21	01.01	EL,OL-Rph	Cable fault at Pensionpura	Arranged B/F on 11KV Prashanth Nagar feeder
2		Golconda	O.U Colony	11KV	VII	12.05	13.13	01.08	EL,OL	Cable fault at O.U.Colony	At 13:06 Hrs Partial loads added on 11KV Darga OH fdr & remaning loads on 11KV Darga Cable feeder
3		Asif Nagar	Kakatiya Nagar	11KV	VII	13.40	16.45	03.05	EL,OL-Bph	2No. Disc Insulators flash over at Salarjung Colony Church	At 14:50Hrs Partial fdr charged & remaining loads added on 11KV Military Hospital feeder
4		S.D.Hospital	Crescent Hospital	11KV	VII	15.15	16.30	01.15	EL,OL-Y&Bph	Breaker mechanical problem at SS	----
5		Golconda	Mothi Mahal	11KV	VII	16.10	17.27	01.17	EL	AB Cable fault at Nadeem Colony	Arranged B/F on 11KV M.D.Lines fdr
6		Toli Chowki	B.S.N.L.	11KV	VII	17.50	19.20	01.30	EL	Disc Insulator flash over at Fathima Masjid	----