

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550	1	8	1	8	1	8			
7	RR(E)	168	403		14		14		14			
8	Hyd	194	1044	3	52	3	52	1	41	2	1	2 No.s 33KV & 1 No. 11Kv still
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>4</b>	<b>78</b>	<b>4</b>	<b>78</b>	<b>2</b>	<b>67</b>	<b>2</b>	<b>1</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		2		1		1 No. 33kv Still
2	NLG	144	988		14		14		14			
3	MDK	107	933		1		1		1			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>22</b>	<b>3</b>	<b>22</b>	<b>2</b>	<b>22</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>7</b>	<b>100</b>	<b>7</b>	<b>100</b>	<b>4</b>	<b>89</b>	<b>3</b>	<b>1</b>	

TSSPDCL - LMRC / Corporate office

Date: 24.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanpet	03.47	05.00	01.13	E/L&O/L	Mominapur cut point jumpers open supply Stude OK	Vepoor	-
2		Ghanpur	Lattupally	33KV	Wanaparthi	00.44	09.31	08.47	O/L	Jumpers Removed at Manganoor	Lattupally	-
3		Kothur	Natco Pharma	33KV	Shadnagar	22.00	00.00	02.00	E/L	Not Rectified	Natco Pharma	-
1	RR N	132KV DP Pally	33KV Gowdavelly	33kv	Medchal	00.56	10.50	09.54	BD	No visible Fault	33KV Gowdavelly	Backfeeding Arranged from 33KV Bandamadaram feeder from 132KV Medchal SS time:02:00
1	HYD N	132KV Madhapur	Venunburg (HT Service)	33kv	Jubilee Hills	15.50	00.00	08.10	EL,OL-R,Y&Bph	33KV Breaker blast and jumpre cut at 132KV Madhapur SS	Venunburg (HT Service)	----
2		132KV Madhapur	I-Labs (HT service)	33kv	Jubilee Hills	15.50	00.00	08.10	EL,OL-R,Y&Bph	33KV Breaker blast and jumpre cut at 132KV Madhapur SS	I-Labs (HT service)	----
3		132KV Erragadda	LV Prasad Marg	33kv	Erragadda	16.42	16.45	00.03	EL	Tree fallen on lines at MSME Institute, Rahemath Nagar	LV Prasad Marg	Loads transferred onto 132KV Erragadda - LV Prasad Marg UG

TSSPDCL - LMRC / Corporate office

Date: 24.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kethepally	Korlapahad	11KV	Nalgonda	00.10	12.20	12.10	E/L	11 KV Jumper Cut	-
2		Kethepally	Chekatigudem	11KV	Nalgonda	00.00	10.00	10.00	E/L	11Kv Insulator Failed Under SS-9	-
3		Kethepally	Chekatigudem	11KV	Nalgonda	07.00	10.00	03.00	E/L	Tree Fallen on 11 KV Line	
4		Aitipamula	Aitipamula	11KV	Nalgonda	00.30	07.30	07.00	E/L	11Kv Jumper Cut	
5		Shettipalem	Shettipalem-1	11KV	Miryalguda	09.30	11.00	01.30	E/L	AB switch problem	
6		Kama Reddy Gudem	K N Pally	11KV	Miryalguda	00.35	06.20	05.45	E/L	11Kv jumper cut	
7		N Annaram	Lingala	11KV	Suryapet	08.30	11.30	03.00	E/L	HT/LT Line Melt	
8		Kalmaicheruvu	Kalmaicheruvu	11KV	Huzurnagar	05.30	07.30	02.00	E/L	11Kv jumper cut	
9		Akupamula	Singaram	11KV	Huzurnagar	06.00	07.45	01.45	E/L	11Kv Line Snapped	
10		Bollepally	Jampally	11KV	Bhongir	11.15	14.00	02.45	E/L	11kv Line snapped near Chinnollabavi (V)	
11		Venkatapur	Velupally	11KV	Bhongir	03.00	07.00	04.00	E/L	2no's 11kv Pin Insulator Failed near Velupally (V)	-
12		Venkatapur	Dattaipally	11KV	Bhongir	06.00	10.00	04.00	EL/OL	11kv Insulator Failed near Datthaipally (V) 3Phase B/d Single phase ok	-
13		Pamukunta	Pamukunta	11KV	Bhongir	01.00	07.30	06.30	E/L	11kv Pin Insulator Failed near Mallagudem (V)	-
14		Chamapur	Singaram	11KV	Bhongir	01.50	11.20	09.30	E/L	10kv DTR Failed near Morpiralla (V)	-
1	MDK	Waddepally	NCL	11KV	Jogipet	01.10	08.05	06.55		BD due to Conductor snapped	-
1	SDPT	Begumpet	Laxmipur	11KV	Husnabad	20.00	00.00	04.00		BD	-
2		Begumpet	Begumpet Rural	11KV	Husnabad	20.05	21.40	01.35		Tree branch fallen on line, same rectified	-
3		Gurjakunta	Vechareni	11KV	Husnabad	01.05	07.40	06.35		Tree branch fallen on line, same rectified	-
4		Nagapuri	Pothireddypalli	11KV	Husnabad	00.00	06.30	06.30		Insulator failure same rectified	-
5		Bekkal	Bairanpally	11KV	Husnabad	10.20	15.50	05.30		Insulator failure same rectified	-
6		Gagillapur	Gagillapur Agl	11KV	Husnabad	21.47	00.00	02.13		Due to gale and wind	-
7		Gagillapur	Gagillapur 24 Hrs	11KV	Husnabad	21.59	00.00	02.01		BD	-
1	RR S	Puppallaguda	Lanco	11KV	Ibrahimbagh	18.50	22.00	03.10	BD	No Visible fault ( Due to Rain )	-
2		Puppallaguda	Alkapur	11KV	Ibrahimbagh	17.00	17.50	00.50	BD	No Visible fault ( Due to Rain )	-
3		Puppallaguda	Puppallaguda	11KV	Ibrahimbagh	18.45	19.18	00.33	BD	11KV jumper cut at Puppallaguda	-
4		Manikonda	Lalamma garden	11KV	Ibrahimbagh	20.30	22.20	01.50	BD	11KV pin insulator failed at Lalamma Garden	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Vemana Colony	Surksha Enclave	11KV	Kukatpally	20.49	21.53	01.04	EL/OL	11kv Pin Insulator Failure At Godavari project	-
2		GP Pally	GP Pally	11KV	Medchal	01.10	02.05	00.55	EL/OL	Tree fallon on the 11KV Line at Ayodhya X Road	-
3		Town Medchal	Country Club	11KV	Medchal	02.10	03.40	01.30	EL	11KV Pin Insulator failed & Tree fallen on the 11KV Line at Government Hospital Medchal	-
4		Athiwelly	Dabeerpur	11KV	Medchal	09.25	10.10	00.45	EL	11KV Conductor Snapped & Replaced at MAA TV Venture, Water Tank	-
5		ICICI	Unique-I	11KV	Medchal	10.50	12.32	01.42	EL	11KV Conductor Snapped & Replaced at near SS	-
6		Ravalkole	Ravalkole	11KV	Medchal	11.40	12.50	01.10	BD	Tree Branch fallen on the 11KV Line at Ravalkole Village	-
7		Laxmapur	MC Pally	11KV	Medchal	18.00	19.03	01.03	EL/OL	11KV Disc failed at Madhusudhan Reddy Bavi MC Pally	-
8		JDM-I	Phase-V	11KV	Jeedimetla	22.40	00.25	01.45	EL	Due to Rain and 11kv Jumper cut at Phase-V	-
1	RR E	Cherlapally-III	Gail	11KV	Sainikpuri	02.05	02.35	00.30		11Kv HG fuse failed at Koteswar Rao Comapnay (AE)	-
2		Kushaiguda	Kushaiguda	11KV	Sainikpuri	02.00	03.05	01.05		Tree branches fallen on 11Kv line at Sai Sudheer college (AE)	-
3		NN Colony	Jai Jawan	11KV	Sainikpuri	16.20	18.00	01.40		11Kv Disk failed & Heavy Rain at Adharsh Nagar (AE/OP)	
4		Moula ali	Malkajgiri	11KV	Sainikpuri	01.40	05.13	03.33		Internet wire fallen on 11Kv line at ZTC Main Road (L.Insp Venkateshwaulu)	
5		Moula ali	Malkajgiri	11KV	Sainikpuri	16.59	21.10	04.11		11Kv Pin Insulator failed at ZTS X Road (L.Insp Venkateshwarulu)	
6		Kushaiguda	Saibaba Temple	11KV	Sainikpuri	21.35	00.45	03.10		Tree Branches fallen on 11KV Line at Kushiguda Industry Phase-II	
7		St.No.08	Green Hills	11KV	Habsiguda	01.52	03.38	01.46		11KV Pin Insulator failed & Replaced at Hymavathi Apartment	
8		NGRI	Scientist Colony	11KV	Habsiguda	02.08	03.46	01.38		11KV Pin Insulator failed at Woodland & 11KV AB Switch opened at Kakathiya Nagar	
9		Techpark	AP Food	11KV	Habsiguda	01.25	04.03	02.38		Tree fallen on 11KV line & removed near SS Yard due to heavy rain	
10		Ramanthpur	gokul nagar	11KV	Habsiguda	21.45	23.15	01.30		Due to heavy rain & wall fallen on T/F at pragathi nagar	-
11		Chakripuram	Ayyappa nagar	11KV	Keesara	16.55	17.40	00.45		Due to rain no falt found	-
12		GKSR	Yammunapet	11KV	Keesara	02.20	03.30	01.10		11KV Line cut at Ismalkhan guda	-
13		Nagaram	Bandlaguda	11KV	Keesara	02.11	05.55	03.44		Insulator fail at praja sai garden	-
14		Peerzathiguda	Shankar nagar	11KV	Keesara	22.30	23.40	01.10		Coconut tree fallen on HT line at shankar nagar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Gymkhana	Tadbun Temple	11KV	C-VI	15.40	17.05	01.25	EL,OL-Bph	No Visible Fault (Due to rain)	----
2		Allwyn	I.E.	11KV	IV	15.50	17.35	01.45	EL,OL-Rph	No Visible Fault (Due to rain)	----
3		Prashasan Nagar	Wood Appartments	11KV	X	15.40	17.55	02.15	EL	Pin Insulator flash over at Road No.70, Judges Colony	----
4		R.P.Nilayam	Venkatapuram	11KV	C-VI	16.40	18.15	01.35	EL	No Visible Fault (Due to rain)	----
5		Gymkhana	Laxmi Nagar	11KV	C-VI	16.37	18.15	01.38	EL,OL-Bph	I/C Cable fault	Arranged B/F on 11KV Apollo fdr
6		R.P.Nilayam	Rythu Bazar	11KV	C-VI	16.45	18.40	01.55	EL,OL	No Visible Fault (Due to rain)	----
7		Gunrock	M.D.F.	11KV	VI	16.45	18.54	02.09	EL,OL	Faulty 3No. DTR's near SS	Arranged B/F on 11KV Medchal fdr
8		Madhapur	Ven-En-Burg	11KV	X	13.15	19.07	05.52	EL,OL	11KV Lines twisted & snapped at Traffic PS, Madhapur	----
9		Sanjeevaiah Park	Police Lines	11KV	C-VI	19.36	20.52	01.16	OL-Rph	Cable Jumper cut at Rasoolpura	----
10		Green Lands	Ameerpet	11KV	IV	21.50	23.05	01.15	OL-Rph	Post type insulator at Lalbanglow	----
11		Seethaphalmandi	Srinivas Nagar Colony	11KV	V	21.25	23.25	02.00	EL,OL	No Visible Fault (Due to rain)	----
12		Bhudevi Nagar	Ramraj Nagar	11KV	VI	21.59	23.30	01.31	EL,OL	No Visible Fault (Due to rain)	----
13		Tirumalagiri	Kanjiguda	11KV	VI	22.20	00.05	01.45	EL	fault loads of 11KV Manapuram fdr	----
14		Prashasan Nagar	Ashwini Heights	11KV	X	22.50	00.20	01.30	EL,OL	No Visible Fault (Due to rain)	----
15		Bhudevi Nagar	Yadamma Nagar	11KV	C-VI	21.55	00.25	02.30	EL	Pin Insulator flash over at Shiva Nagar	----
16		Monda Market	Daramkanta	11KV	V	21.35	00.35	03.00	EL,OL	Stand by Cable fault at Dharamkanta	----
17		Monda Market	Gurdwara	11KV	V	22.55	00.50	01.55	EL	No Visible Fault (Due to rain)	----
18		Hakimpet	Risala Bazar	11KV	C-VI	22.45	23.55	01.10	EL	Tree branches on lines at Gummadi Raj Residnecy	----
19		Hakimpet	Hakimpet Airforce	11KV	C-VI	22.45	00.50	02.05	EL	No Visible Fault (Due to rain)	----
20		R.P.Nilayam	Rythu Bazar	11KV	C-VI	22.50	01.15	02.25	EL	No Visible Fault (Due to rain)	----
21		Bowenpally	I.A.F	11KV	VI	21.50	01.25	03.35	EL	Faulty Yph AB Switch at SS	Partial feeder charged
22		Prashasan Nagar	B.N.R Hill	11KV	X	23.00	01.40	02.40	OL-R&Yph	Tree branches fallen on lines behind Durgam Cheruvu	----
23		Gymkhana	Balamrai	11KV	V	21.45	02.00	04.15	EL	Cable fault at GVK	----
24		Road No.12	Kanka Durga	11KV	X	20.05	22.45	02.40	EL	Cable fault	Arranged B/F on 11KV Kalinga fdr
25		Clock Tower	Anjali	11KV	V	21.35	00.03	02.28	EL,OL-Rph	Moisture in RMU's at Anjali	Partial loads added on 11KV Monda Market fdr (4No. DTR's kept off)
26		I.D.P.L	I.E.	11KV	V	21.45	02.10	04.25	EL	Cable fault	----
27		Pragatools	Pragathi Pack	11KV	VI	23.22	04.05	04.43	EL,OL-Bph	Faulty HT Service at F-7, IDA Kukatpally	----
28		Tirumalagiri	Mangapuram	11KV	C-VI	22.20	06.20	08.00	EL	Pin Insulator flash over at Water Reservoir, Mangapuram	
29		Tirumalagiri	Officer's Colony	11KV	C-VI	21.30	00.00	02.30	EL		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Hyd S	Petlaburz	Gansi Bazar	11KV	III	01.55	04.10	02.15	EL,OL	DTR fault at Post Office	----
2		Devi Bagh	Siddiq Gulshan	11KV	III	11.15	12.35	01.20	EL	Cable fault at Opp.SS	----
3		Miralam	Madina Masjid	11KV	III	21.20	23.00	01.40	EL	2no HT top jumper at Madina Masjid	----
4		C.R.P.F	Salala	11KV	III	21.20	23.20	02.00	EL	Cable fault at Salala	4No. DTR's kept off
1	Hyd C	I.T.I Mallepally	Jyothi Colony	11KV	VII	01.55	03.25	01.30	EL	Pin Insulator flash over & tree branches fallen on lines at Jyothi Colony	Arranged B/F on 11KV Vasavi Colony fdr
2		Asif Nagar	Toli Chowki	11KV	VII	03.05	04.15	01.10	EL,OL-Bph	DTR fault at Yousuf Tekdi	----
3		Toli Chowki	B.S.N.L.	11KV	VII	17.55	19.38	01.43	EL	DTR Lug B/O at P.P. Apts	----
4		Asif Nagar	Market Yard	11KV	VII	17.55	19.05	01.10	EL,OL	Tree branches fallen on lines at Market Yard	----
5		Indira Park	Vivek Nagar	11KV	I	18.45	20.00	01.15	OL-Rph	I/C AB Switch Insulator flash over at near Dr.Laxman MLA's House	----
6		Indira Park	Kuchipudi	11KV	I	17.35	19.30	01.55	OL-Rph	I/C AB Switch Insulator flash over at Andhra Patrika DTR	----
7		Vittalwadi	Gandhi Kuteer	11KV	II	19.40	20.45	01.05	EL,OL	No Visible Fault (Due to rain)	----
8		Narayanguda	Preventive Medicine	11KV	II	19.40	20.52	01.12	EL,OL	Faulty 2No. DTR's at Narayanguda	----
9		Narayanguda	Chikkadpally	11KV	II	21.30	22.45	01.15	EL,OL-R&Bph	Opened AB Switch at Chikkadpally	3No. DTR's kept off
10		A.C.Gaurds	N.M.D.C	11KV	VII	21.50	23.10	01.20	EL	Jumper cut & Tree branches on lines at Hockey Ground	----
11		Indira Park	Gagan Mahal	11KV	I	19.45	22.35	02.50	EL,OL-Bph	----	Added partial loads of 11KV Gagan Mahal fdr (3No. DTR's kept off)
12		Toli Chowki	B.S.N.L.	11KV	VII	22.55	00.20	01.25	EL	Disc flash over at Limra Hotel & AB Cable fault at Abitech Apt, IAS Colony	----
13		Bathakamma Kunta	Ayyappa Temple	11KV	II	21.20	00.50	03.30	EL	Big tree fallen on lines at Sai Datta Hospital	----
14		Jawahar Nagar	Anjaiah Bhavan	11KV	I	23.00	02.05	03.05	EL	Tree branches fallen on lines at Labour Office	----
15		Zamistanpur	Jama Osmania	11KV	II	22.04	01.40	03.36	EL,OL-Rph		(3No. DTR's kept off)
16		Indira Park	Vivek Nagar	11KV	I	21.40	04.10	06.30	EL	RMU End Kit fault at Ashok Nagar Chowrastha	----
17		Indira Park	Kuchipudi	11KV	I	23.15	03.50	04.35	EL	Tree branches fallen on lines at Ashok Nagar Chaman	----
18		Fever Hospital	Tourist Hotel	11KV	II	21.35	04.25	06.50	EL	RMU insulator flash over at Badhurka College	Partial feeder charged
19		Fever Hospital	Fever Hospital	11KV	II	22.20	05.00	06.40	EL	Pin Insulator flash over at Shardha Enclave Apts	----