

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		13		13		13			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		31		31		31			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>51</b>	<b>0</b>	<b>51</b>	<b>0</b>	<b>51</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988	1	13	1	13	1	13			
3	MDK	107	933		4		4		4			
4	SDPT			3	1	3	1	3	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>7</b>	<b>19</b>	<b>7</b>	<b>19</b>	<b>7</b>	<b>19</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>7</b>	<b>70</b>	<b>7</b>	<b>70</b>	<b>7</b>	<b>70</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 25.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kothur	33KV	Vikarabad	00.30	09.25	08.55	EL	Tree fallen on the line Near Regadimailaram	Kothur	-
2		Kothur	Thimmapur	33KV	Shadnagar	18.15	20.55	02.40	EL	R Phase disc insulator failed and replaced near Radha Garden	Thimmapur	-
3		Shadnagar	Rayalseema	33KV	Shadnagar	18.05	19.05	01.00	EL	No visible fault due to Rain	Rayalseema	-
1	NLG	Thungathurthy	Annaram	33KV	Suryapeta	12.40	14.10	01.30	EL	Insulator Failure	Annaram	-
1	SDPT	Siddipet	Naryanraopet	33KV	Siddipet	22.02	23.25	01.23		B/D	Naryanraopet	-
2		Siddipet	Narsapur	33KV	Siddipet	21.35	00.00	02.25		B/D Loads shifted to Mittapally	Narsapur	-
3		Chandlapur	Jakkapur	33KV	Siddipet	19.40	20.45	01.05		B/D	Jakkapur	-

TSSPDCL - LMRC / Corporate office

Date: 25.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Nawabpet	11KV	Jadcherla	05.00	11.00	06.00		11KV Jumper cut near Jangamaipally	-
1		Athmakur(S)	Athmakur(S) AGL	11KV	Suryapeta	09.00	12.00	03.00	E/L	Insulator failed	-
2		Gaddipaly	Medaram	11KV	Huzurnagar	14.20	17.20	03.00	EL	Due to 11kv jumper cutted	-
3		Munagala	Kokkireni-II	11KV	Huzurnagar	06.40	08.20	01.40	EL	Due to 11kv line snapped	-
4		Repala	V R Puram	11KV	Huzurnagar	13.10	15.20	02.10	EL	Due to tree branch fall on 11kv line	-
5		Nandanam	Anajipur	11KV	Bhongir	03.30	07.05	03.35	EL	11 KV Disc Failed Near Cheruvu Anajipur Village	-
6		NG.Bandal	Konapur	11KV	Bhongir	12.30	15.00	02.30	EL	11kv Disc Failed near Sub_station	-
7		Alair	Ch.kandukur	11KV	Bhongir	10.45	14.00	03.15	EL	11kv Insulator Failed near Ch.Kandukur Village 3 Phase B/d Single phase ok	-
8	NLG	Chamapur	Chamapur	11KV	Bhongir	08.00	12.15	04.15	EL	11kv Insulator Failed near Cahmapur Village 3 Phase B/d Single phase ok	-
9		Ishkilla	Munipampula	11KV	Choutuppal	06.00	10.35	04.35	EL	11 kv Insulator Failed Near Munipampula Village. 3 Phase B/d Single phase ok	-
10		Ishkilla	Uthathoor	11KV	Choutuppal	05.30	10.35	05.05	EL	11 kv Insulator Failed Near Uththoor Village. 3 Phase B/d Single phase ok	-
11		D.Nagaram	D.Nagaram Agl	11KV	Choutuppal	07.00	11.15	04.15	EL	11kv Insulator Failed near Parlamaissamma Road	-
12		Aroor	Lingarajupally	11KV	Choutuppal	05.00	08.00	03.00	EL	11 kv Insulator Failed Near Lingarajupally Village	-
13		MT.Pally	Mogilipaka	11KV	Choutuppal	05.00	08.50	03.50	EL	11 KV Insulator Failed Near Mogilipka Village	-
1		Pati	Shalimar	11KV	Patancheru	03.05	08.25	05.20		BD Due to Jumper replaced & Disk fail at Ringroad	-
2	MDK	Bollaram - I	NCL	11KV	Patancheru	08.45	10.46	02.01		BD due to Conductor snapped	-
3		Bollaram - II	Vasavidatta	11KV	Patancheru	01.55	04.10	02.15		BD due to Conductor snapped	-
4		Bollaram - II	Vasavidatta	11KV	Patancheru	04.20	04.40	00.20		BD due to Tree fallan on line	-
7	SDPT	Gagillapur	Vallampatta	11KV	Husnabad	10.00	00.00	14.00		Break down (Single ph-ok)	-
1	RR S	Manikonda	Lalamma Garden	11KV	Ibrahimbagh	18.45	20.20	01.35	BD	11KV Pin insulator failed at Lalamma garden	-
1		UMCC	Crusher	11KV	Medchal	01.45	02.25	00.40	BD	11KV Pin Insulator failedat Barbar Shop, Devendhar Nagar	-
2		GP Pally	Maisammaguda	11KV	Medchal	00.50	01.50	01.00	BD	Tree Fallen on 11KV Line at MREC Campus.Maisammaguda	-
3		GP Pally	Niberwood	11KV	Medchal	01.05	02.10	01.05	BD	11KV Post of Insulator Failed at Trident Property	-
4		Kandlakoya	Kandlakoya	11KV	Medchal	23.30	02.05	02.35	BD	Tree Fallen on 11KV Line at Kandlakoya Toll Gate	-
5		Town Medchal	Country Club	11KV	Medchal	01.00	02.30	01.30	BD	11KV Pin Insulator Failed at SVR Colony	-
6		Ravalkole	Ravalkole	11KV	Medchal	07.48	10.34	02.46	BD	11KV Pin Insulator Failed at Pochamma Temple,Ravalkole	-
7	RR N	Shameerpet	Thumkunta	11KV	Medchal	09.10	10.10	01.00	BD	11KV Jumper Opened in SS(Cable Kit Failed)	-
8		Laxmapur	MC Pally	11KV	Medchal	09.00	13.00	04.00	BD	3 Nos. 11KV Disc Failed at Racherla Kunta, Dasarolla Bhavi & Madhusudhan Reddy Bhavi	-
9		Kandlakoya	KV Reddy Nagar	11KV	Medchal	15.00	16.00	01.00	BD	Tree Branch fallen on the 11KV Line at Indian Petrol Bunk	-
10		J T P L	K S R Enclave	11KV	Kukatpally	12.35	13.40	01.05	OL	11kv Pin Insultor Failure At Road-3 K S R enclave	-
11		Mayurinagar	Ramnareshanagar	11KV	Kukatpally	18.20	19.45	01.25	OL	Tree branches Fallen on the 11kv line Near Ladies Hostel mayurinagar	-
12		Jeedimetla-I	Meashawari	11KV	Jeedimetla	18.00	19.40	01.40	EL/OL	Due To Heavy rain	-
13		Jeedimetla-I	Subashanagar	11KV	Jeedimetla	18.00	19.30	01.30	EL/OL	Due To Heavy rain	-
1		Janapriya	High Tension Road	11KV	Sainikpuri	01.10	02.10	01.00		11Kv Pole damage at Chandrapuri Colony Near (AE/SKP)	-
2	RR E	AS Rao Nagar	AS Rao Nagar	11KV	Sainikpuri	01.25	02.07	00.42		Tree fallen on 11Kv line at Miga Park (LM Srinivas/Artisan Upender)	-
3		VP Nagar	RK Puram	11KV	Sainikpuri	06.10	06.45	00.35		11Kv jumper cut at RK Puram (AE/OP)	-
4		Vinayak Nagar	RK Nagar	11KV	Sainikpuri	01.28	02.03	00.35		HT/LT line snaped at Near RK Nagar (L.Insp Venu Gopal)	-
5		Peerzathiguda	RTC	11KV	Keesara	05.20	07.36	02.16		Internet Cable touched to 11KV Line & Short Circuit at Mangalya Shopping Mall	-
6		Aushapur	Bokkenguda	11KV	Keesara	17.50	19.00	01.10		11KV Pin Insulator failed at Forest Area	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	I.I.C.T	Deccan	11kv	V	04.38	08.36	03.58	EL	Pin Insulator flash over at Mitra Apts & Tree branches fallen on lines at Pochamma Temple	-----
2		Macha Bollaram	Chinthal Bazar	11kv	C-VI	05.09	06.33	01.24	EL	HG fuse Insulator flash over at Vivekananda Colony	-----
3		Pragatools	Pragathi Pack	11kv	VI	06.00	11.25	05.25	EL,OL-Bph	Tree branches fallen on lines at I.T.I, Kukatpally	-----
4		Bowenpally	Akshaya Enclave	11kv	VI	06.15	11.24	05.09	EL	No Visible Fault	Arranged B/F on 11KV Gowtham Nagar feeder
5		Hakimpet	Hakimpet Airforce	11kv	C-VI	06.55	08.28	01.33	All Indication	No Visible Fault	Arranged B/F on 11KV Risala Bazar feeder
6		Tirumalagiri	Satya Sai Enclave	11kv	VI	11.58	14.06	02.08	EL,OL-Yph	Cable fault	Arranged B/F on 11KV Khanajiguda fdr
7		Jubilee Hills	BSNL	11kv	X	12.50	14.25	01.35	All Indication	Tree branches fallen on lines at Rd.No.44	-----
8		Bowenpally	Pipe Line Road	11kv	VI	18.05	19.10	01.05	EL	No Visible Fault	-----
9		Mothi Nagar	Rajive Nagar	11kv	IV	18.02	19.05	01.03	All Indication	Jumper B/O at Mid Land Bakery	-----
10		Prashanth Nagar	Colgate	11kv	VI	18.05	19.15	01.10	All Indication	No Visible Fault	-----
11		Prashanth Nagar	Prashanth Nagar	11kv	VI	18.05	19.15	01.10	All Indication	No Visible Fault	-----
12		Road No.12	C.R.P.F	11kv	X	17.50	19.20	01.30	EL,OL-Bph	Tree Branches fallen on lines at Minabai Tower	-----
13		Bowenpally	Gowtham Nagar	11kv	VI	17.45	20.00	02.15	EL,OL-Rph	No Visible Fault	-----
14		R.P.Nilayam	Nagadevatha Temple	11kv	C-VI	17.55	21.02	03.07	All Indication	Pin Insulator flash over at Officers Colony & replaced 6No HG fuse at Rly.Track	-----
15		I.D.P.L	I.E	11kv	VI	18.10	20.10	02.00	All Indication	No Visible Fault	-----
16		Chinthal	Caption Gas	11kv	VI	18.10	19.10	01.00	EL	No Visible Fault	-----
17		Mothi Nagar	N.R.R.Puram	11kv	IV	18.04	20.35	02.31	All Indication	Tree branches fallen on lines	-----
18		Seethaphal Mandi	Srinivasa Nagar Colony	11kv	V	18.15	19.45	01.30	All Indication	No Visible Fault	-----
1	HYD S	Laxmi Nagar	Laxmi Nagar	11kv	VIII	00.01	01.44	01.43	OL-Rph	HT Jumper cut at Milk Booth	-----
2		Vittalwadi	Narayanaguda Water Works	11kv	IX	04.18	05.27	01.09	EL	No Visible Fault	Arranged B/F on 11KV Taraka Rama feeder
3		Devibagh	Shivalayam	11kv	III	17.55	19.00	01.05	EL,OL	AB Cable fault at Shiva Nagar	-----
4		Vittalwadi	Narayanaguda Water Works	11kv	IX	18.15	20.15	02.00	EL,OL-Rph	Tree Branches fallen on lines at Water Works	-----
5		Osm.Hospital	Puthli Bowli	11kv	IX	18.40	20.30	01.50	All Indication	Cable fault at Triveni Lodge	-----
1	HYD C	Indira Park	Domalguda	11kv	I	01.00	03.12	02.12	EL	Tree branches fallen on lines at Bank of Baroda	-----
2		Indira Park	Gulshan Nagar	11kv	I	02.25	04.25	02.00	EL	Tree branches fallen on lines at Mother Dairy	-----
3		Indira Park	Kuchipudi	11kv	I	13.30	14.45	01.15	EL,OL	faulty loads of 11KV Ashok Nagar fdr	Arranged B/F on 11KV R.K.Mutt fdr
4		Public Garden	Parisram Bhavan	11kv	I	15.47	16.50	01.03	EL,OL-Bph	Cable fault	Arranged B/F on 11KV A.I.R fdr
5		Chilkalguda	Musheerabad	11kv	I	16.55	18.15	01.20	EL,OL-Rph	No Visible Fault	-----
6		Fever Hospital	Nallakunta	11kv	II	18.25	19.25	01.00	All Indication	Faulty loads of 11KV BKP Bus Depot fdr	-----
7		Amberpet	Amberpet	11kv	II	19.11	20.25	01.14	EL,OL-Rph	HT Jumper cut at Kummarwadi	-----
8		Fever Hospital	Tourist Hotel	11kv	II	18.00	20.35	02.35	All Indication	No Visible Fault	20:05Hrs partial fdr charged AB switch opened at Bhadraka Colleg