

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		12		11		11		1	1 No 11KV Still
	Total	606	3055	0	17	0	16	0	16	0	1	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		13		13		13			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	15	2	15	2	15	0	0	
	Grand Total	1082	6468	2	32	2	31	2	31	0	1	

TSSPDCL - LMRC / Corporate office

Date: 26.09.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narwa	33KV	Narayanapet	19.05	23.45	04.40	EL	AB Switch open at Manthangod	Narwa	Alternate Supply Arranged from 33/11KV SS Narwa at 23:45Hrs
1	MDK	Borapatla	Covalent	33KV	Jogipet	10:00	12:51	2:51		Jumper cut	Covalent	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koppole(K)	Kopolu	11KV	Nalgonda	4:15	6:00	1:45	E/L	Disc failure	No
2		Madgulapally	Kukadam	11KV	Nalgonda	10.00	12.00	02.00	E/L	11 KV Jumper cut	No
3		V.K. Palem	V.K. Palem	11KV	Miryalguda	05.36	07.48	02.12	E/L	Conductor snapped	No
4		Nellikal	Godumadaka	11KV	Miryalguda	06.10	08.20	02.10	E/L	11 KV Insulator Failure	No
5		Guntipally	Yerrabelly	11KV	Miryalguda	05.48	06.28	00.40	E/L	Tree fallen on the line	No
6		Pulimamidi	Chennaram	11KV	Miryalguda	04.56	06.28	01.32	E/L	11 KV Insulator Failure	No
7		Jammigadda	Jammigadda	11KV	Suryapet	03.50	05.41	01.51	E/L	Insulator failed	No
8		Jalalpuram	Jalalpuram	11KV	Suryapet	05.30	08.40	03.10	E/L	11KV Line cut	No
9		GT Giri	Bakthalapuram	11KV	Suryapet	10.00	12.10	02.10	E/L	Jumper cut	No
10		Raigir	Raigir Agl	11KV	Bhongir	04.00	08.40	04.40	E/L	11 KV Line Snapped	No
11		Bollepally	Jampally	11KV	Bhongir	07.00	10.00	03.00	E/L	11 KV Line Snapped	No
12		Datherpally	Jangampally	11KV	Bhongir	01.00	05.58	04.48	E/L	11 KV Insulator failed	No
13		Ishkilla	Munipampula	11KV	Choutuppal	4:00	8:00	4:00	E/L	11 KV Insulator failed	No
1	MDK	Patancheru Town	MIA-I	11KV	Patancheru	18:00	18:40	0:40		Tree branch fallen on the line	No
1	SDPT	Thotapally	Thotapally Expres	11KV	Husnabad	4:00	6:00	2:00		Tree fallen on the line	No
1	RR N	Dulapally	Prasanth Nagar	11KV	Medchal	14:22	15:45	1:23		11KV Pole bend & Rectified at Poultry farm opposite	No
2		Gowdawelly	Ayodhya	11KV	Medchal	09.40	10.40	01.00		11KV Disc failed at Saketh Venture, Ayodhya Chowrasta	No
3		vemana colony	friends colony	11KV	Kukatpally	22.23	22.09	01.46		11KV Line AB swtch open at Arjun Reddy Colony	No
4		Jeedimetla	R G K Surarteam	11KV	Jeedimetla	10.21	11.28	01.07		Tree Branches fallen on The 11kv Line at Suraram	No
1	RR E	Janapriya	Vampuguda	11KV	Sainikpuri	16:40	17:40	1:00		11KV Disc failed at Mayor Baba Colony	No
1	HYD N	R.P Nilayam	Vaisnavi Matha Temple	11KV	C-VI	14.55	17.05	02.10	EL	HT Jumper cut at Laxmi Kala Mandir & 2 No. Disc Insulators flash over at Alwal HDFC Bank	No
2		I.D.P.L	Shivalayam	11KV	VI	23:20	1:35	2:15	EL	No Visible Fault (Due to Rain)	No
3		Road No.22	Obul Reddy	11KV	X	23:35	0:40	1:05	EL,OL-R&Bph	No Visible Fault (Due to Rain)	No
4		Gymkhana	Tadbund Temple	11KV	C-VI	23:35	1:05	1:30	EL,OL-Bph	No Visible Fault (Due to Rain)	No
5		Osm. University	RTC Hospital	11KV	V	23.50	01.20	01.30	EL,OL-R&Yph	No Visible Fault (Due to Rain)	No
1	HYD C	Golconda	Narayanamma College	11KV	VII	13.05	14.15	01.10	EL,OL	No Visible Fault	No
2		Nampally	Pearl Regency	11KV	VII	20.05	22.00	01.55	EL,OL	LV-2 O/G AB Switch Bph Jumper cut at SS	Arranged B/F on 11KV Niloufer Hospital fdr
3		Bathkammakunta	Saibaba Temple	11KV	II	21.34	23.39	02.05	EL	Cable fault at Andhra Bank	Arranged B/F on 11KV Ahobilmutt & 11KV C.E Colony feeders
4		Z.P Office	Golconda Hotel	11KV	I	23:14	0:20	1:06	EL,OL	Cat fallen on HT Lines near Prem Nagar	No
5		Indira Park	Datta Nagar	11KV	I	23:30	1:55	2:25	EL	No Visible Fault (Due to Rain)	No
6		Narayanaguda	Chikkadapally	11KV	II	23:50	1:30	1:40	EL,OL	No Visible Fault (Due to Rain)	No
7		Exhibition	Gandhi Bhavan	11KV	I	23.58			EL		No