

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044	2	3	2	3	2	3			
	Total	606	3055	2	6	2	6	2	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	3	11	3	11	3	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.09.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	AFA	33KV	Patancheru	16.29	17.55	01.26		BD due to Lighting arrester failed	AFA	-
1	HYD N	132KV Gunrock	Hakimpet Cable-2	33KV	Nehru Ngr	01.31	01.35	00.04	EL	Cable fault at Tirumalagiri PS	Hakimpet Cable-2	Loads transferred onto 132KV Gunrock - R.P Nilayam
2		132KV Jubilee Hills	Road No.13A	33KV	Kalyan Nagar	11.47	11.51	00.04	EL,OL-Yph	Cable fault at Centuary Hosptial (by GHMC Wing)	Road No.13A	

TSSPDCL - LMRC / Corporate office

Date: 28.09.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kurumarthi	Eduloor	11KV	Nalgonda	16.30	18.00	01.30	E/L	11KV Jumper cut	-
2		Penpahad	Potlapahad	11KV	Suryapet	09.05	10.40	01.35	E/L	11Kv Insulator failed	-
3		Mattapally	R C Puram	11KV	Huzurnagar	04.30	06.00	01.30	E/L	11Kv Line Snapped	-
4		N B Gudem	Redlakunta	11KV	Huzurnagar	03.00	05.40	02.40	E/L	11KV Jumper cut	-
5		Mukundapuram	Dacharam	11KV	Huzurnagar	07.00	09.20	02.20	E/L	11Kv Line Snapped	-
1	RR N	Town Medchal	Balaji Nagar	11KV	Medchal	19.20	20.12	00.52	BD	Bird fallen on the 11KV Line at Mukund Theatre	-
1	RR E	Ananadbagh	NMDC	11KV	Sainikpuri	13.20	14.05	00.45		Bird fallen on 11Kv Pin Insuletor fail at Megana Brundhavan Apt Kalyan Nagar (L Insp Ramulu)	-
2		Aushapur	Bokkenguda	11KV	Keesara	17.30	18.15	00.45		post of insulator fail at Bokkenguda village	-
1	HYD N	Lalaguda	Lalapet	11KV	V	15.55	17.30	01.35	EL,OL-R&Bph	HT jumper cut at Ram Takies	-
1	HYD S	Khilwath	Charminar	11KV	III	00.28	02.01	01.33	EL,OL	Cable fault at Opp: Khilwath Office	Partial feeder charged & Remaining loads added on 11KV Pancha Mohalla feeder
2		Vittalwadi	Ramkoti	11KV	IX	06.25	07.37	01.12	EL,OL-Rph	Cable fault at Ramkoti	Arranged B/F on 11KV Taraka Rama feeder