

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Medchal	33KV Steelmill	33KV	Medchal	00.22	09.28	09.06	BD	33KV Jumper cut and replaced at Medchal checkpost and Opp Steelmill		-

TSSPDCL - LMRC / Corporate office

Date: 01.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Polepally	Polepally AGL	11KV	Jadcherla	11.16	12.36	01.20		11KV Wire Cut near Polepally	
2		Kandoor	Choudaipally	11KV	Jadcherla	11.40	14.15	02.35		11KV Wire Cut near Sukkarampally	
1	NLG	Tekumatla	Pinnaipalem	11KV	Suryapet	08.30	11.15	02.45	EL	Conductor snapped	-
2		Palakeedu	Nagireddygudem	11KV	Huzurnagar	13.30	15.00	01.30	EL	11 KV LINE SNAPPED	-
1	RR N	Subhash Nagar	Bank Colony	11KV	Medchal	12.10	13.36	01.26	BD	11KV Jumper cut and replaced at Suchitra Wines	-
2		Athiwelly	Ravalkole Thanda	11KV	Medchal	06.55	08.00	01.05	BD	Bird fallen on the 11KV Line at Ravalkole Thanda	-
1	HYD N	LV Prasad Marg	Sagar Society	11KV	Banjarahills	23.25	01.20	01.55	EL,OL	RMU Cable fault at Sagar Society	00:45 hrs Partial loads added on 11KV Lumbini Mall feeder & remaining loads added on 11KV Kamalapuri Colony feeder