

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	2	1	2	1	2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	2	1	2	1	2	0	0	
	Grand Total	1082	6468	2	3	2	3	2	3	0	0	

## TSSPDCL - LMRC / Corporate office

Date: 03.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Ramapuram	Mellacheruvu	33kv	Huzurnagar	01.50	06.30	04.40	EL/OL	33Kv Line Snapped	Mellacheruvu	-
1	HYD N	132KV Madhapur	Sundew(HT Service)	33kv	Jubilee Hills	12.30	12.40	00.10		Cable damaged by TS TRANSCO at 132KV Rayadurgam SS	Sundew(HT Service)	arranged from 132KV Jubilee Hills - 33KV Intime Properties

## TSSPDCL - LMRC / Corporate office

Date: 03.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bibigudem	Munyanaik Thanda	11kv	Suryapet	16.00	17.10	01.10	E/L	11Kv Line Melt	-
2		Keethavarigudem	Velidanda	11kv	Huzurnagar	16.15	17.30	01.15	E/L	11Kv Line Snapped	-
1	HYD C	A.C Guards	N.M.D.C	11kv	Saifabad	17.35	19.35	02.00	EL	Suspected R.M.U Cable fault	Arranged B/F on 11KV P.S Nagar & 11KV Crescent Hospital feeders