

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988	2	1	2	1	2	1			
3	MDK	107	933									
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	3	3	3	3	3	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Miryalaguda	Avanthipuram	33KV	Miryalaguda	5:12	7:14	2:02	E/L	Tree fallen on 33KV Line	Avanthipuram	No
2		Dirsicncherla	Kalmalcheruvu	33KV	Huzurnagar	13.30	17.30	04.00	EL	33Kv Insulator failure	Kalmalcheruvu	No
1	SDPT	Husnabad	Katkur	33KV	Husnabad	7:30	8:30	1:00		Bird fallen on the line in Hanmakonda road	Katkur	No

TSSPDCL - LMRC / Corporate office

Date: 04.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Chennavelly	11KV	Jadcherla	09.50	12.00	02.10		11KV Wire cut near Kucharkal	No
2		Balanagar	Kethireddypally	11KV	Jadcherla	12.18	13.58	01.40		11KV Wire cut near Ekvaipally	No
1	NLG	Kandagatla	Thimmapuram	11KV	Suryapet	8:30	10:50	2:20	EL	Insulator failed	No
1	HYD S	Sultan Bazar	Taraka Rama	11KV	IX	05.15	06.35	01.20	EL	No visible fault	Partial feeder charged & Remaining fdr B/F on 11KV Sultan Bazar feeder