

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	3	13	3	13	3	13			
7	RR(E)	168	403		10		10		10			
8	Hyd	194	1044		43		43		43			
	Total	606	3055	3	67	3	67	3	67	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	1	4	1	2	1	2		2 No.s 33kv still
2	NLG	144	988	1	8	1	8	1	8			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	9	6	9	4	9	2	0	
	Grand Total	1082	6468	9	76	9	76	7	76	2	0	

TSSPDCL - LMRC / Corporate office

Date: 09.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Paspula	33KV	Narayanapet	18.05	00.00	05.55	O/L & EL	DP Problem & Pole damaged , Tree follen on the line (Mustipally,Paspula SS Dark) (Concerned Sub-Eng/Makthal Venkatesh -9912971079)	Paspula	-
2		Amarchintha	Amarchintha	33KV	Wanaparthu	17.58	18.36	00.38	EL	Pin Binding failed ,Tree follen on the line (Mastipur SS Dark)(Concerned AE/OP/Amarchintha 8185941601)	Amarchintha	-
3		Amarchintha	Peddakadmoor	33KV	Wanaparthu	18.05	00.00	05.55	EL	Tree follen on the line (AE/OP/Narva)	Peddakadmoor	-
4		leeza	Maddelabanda	33KV	Gadwal	19.50	20.41	00.51	EL	Tree branches removed near Nagadoddi SS	Maddelabanda	-
1	NLG	Madgulapally	Agamothkur	33KV	Miryalaguda	00.40	10.15	09.35	E/L,O/L	Tree branch fallen on the line Insulator failure	Agamothkur	-
1	MDK	Narayankhed	Kalher	33KV	Sangareddy	18.30	21.37	03.07	B/D Due to Jumper Cut		Kalher	-
1	RR N	132KV Medchal	33KV Athiwelly	33KV	Medchal	03.36	12.55	09.19	EL	2 Nos Pin Insulators failed at Venkateshwara Theater,Medchal	33KV Athiwelly	-
2		132KV Medchal	33KV Shantha Biotech	33KV	Medchal	16.25	18.55	02.30	EL	No Fault	33KV Shantha Biotech	-
3		132KV Medchal	33KV Aliabad	33KV	Medchal	17.55	18.55	01.00	EL	Tripped on EL Indication (Due to heavy Rain & wind)(33KV Isolator Opened)	33KV Aliabad	-

TSSPDCL - LMRC / Corporate office

Date: 09.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Chakalpally	11kv	Jadcherla	07.58	10.20	02.22		BD due to 11 KV wire cut near Chakalalally.	-
1	NLG	Aipoor	Kotapahad	11kv	Suryapet	03.30	06.00	02.30	E/L	Tree branch fallen on the line	-
2		Raghunadapalem	Nakkagudem	11kv	Huzurnagar	00.10	06.00	05.50	EL	11 KV JUMPER CUT	-
3		Turkapally	Hyrjalapuram	11kv	Nalgonda	11.30	12.31	01.01	EL	11 KV JUMPER CUT	-
4		chandampeta	mudidandla	11kv	Devarakonda	14.00	18.00	04.00	EL	11 KV JUMPER CUT	-
5		NG.Bandal	Konapur	11kv	Bhongir	05.50	10.30	04.40	EL	11 kv Insulator failed SS -24 at Bola narsireddy rwell Near Ibrahimpur village.	-
6		Kolanpaka	Somaram	11kv	Bhongir	06.30	10.40	04.10	OL	11kv Line Snapped & 11kv Insulator Failed near Kolanpaka Sub Station	-
7		Athmakur	Koratikal	11kv	Bhongir	05.40	08.40	03.00	EL	11 kv Insulator failed at Pole no 121 Near Athmakur village	-
8		Peddaravlapaly	Peddaravlapaly	11kv	Choutuppal	11.20	12.05	00.45	OL	11kv Line snapped near Peddaravlapally villge	-
1	RR S	Gachibowli	Kalajothy	11KV	Kondapur	17.20	19.00	01.40	BD	Due to heavy rain and Wind, 11kv line problem at Jail Khana, Backfeeding given on 11kv kothaguda Feeder.	-
1	RR N	KPHB	Jalavayuvihar	11KV	Kukatpally	17.18	18.34	01.16	EL	Tree branch touched the 11kv line near JNTU Police station	-
2		Jagathgirutta	Jagathgirutta	11KV	Medchal	16.15	17.25	01.10	EL	11KV Cable Endkit Lug cut at Anjaya nagar	-
3		Jagathgirutta	Shiridi Hills	11KV	Medchal	16.10	17.50	01.40	EL	HG Fuse Insulator failed RGK 47 Block	-
4		Kompally	Kompally	11KV	Medchal	15.57	16.17	00.20	EL	11KV Line AB Switch opened at Dulapally Main Road(11KV AB Cable failed)	-
5		Petbasheerabad	Satyam Enclave	11KV	Medchal	15.58	17.02	01.04	EL	Tree fallen the 11KV Line at Dandamudi Enclave	-
6		Keshavaram	potharam	11KV	Medchal	16.52	17.55	01.03	EL/OL	Tree fallen the 11KV Line at Potharam village	-
7		Medchal	Navadurga	11KV	Medchal	16.38	17.50	01.12	EL	11KV Pin Insulators failed at Sleepwell company	-
8		Shameerpet	Anthaipally	11KV	Medchal	17.30	19.30	02.00	EL	No Fault	-
9		Shameerpet	Shameerpet	11KV	Medchal	17.30	19.15	01.45	EL	11KV Jumper opened at Babaguda(100 KVA DTRs 3 Nos off)	-
10		Athiwelly	Dabeerapur	11KV	Medchal	17.50	20.00	02.10	EL	Tree fallen the 11KV Line at Lingapur village	-
11		Athiwelly	SPIC	11KV	Medchal	17.50	20.30	02.40	EL	11KV Pin Insulators failed at Rekulabavi	-
12		Devarayamjal	DMC	11KV	Medchal	17.50	18.40	00.50	EL/OL	Tree fallen the 11KV Line at Devarayamjal village	-
13		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	17.10	18.15	01.05	EL	Tree fallen the 11KV Line at EMRI 108	-
1	RR E	Sainikpuri	Saipuri	11KV	Sainikpuri	16.16	17.28	01.12		Tree branches fallen on 11kv line at SBO Colony (AE/OP)	-
2		Uppal	Bank colony	11KV	Habsiguda	16.30	17.30	01.00		Tree branches fallen on 11kv line at LFJC Due to heavy wind & Gail	-
3		Mallapur 2	AP colony	11KV	Habsiguda	16.10	17.55	01.45		11KV Cable end kit fail at Janshi school Due to heavy wind & Gail	-
4		IDAuppal	Devendar nagar	11KV	Habsiguda	16.34	17.28	00.54		Tree fallen on 11kv line at Devendar nagar Due to heavy wind & Gail	-
5		CRPF	Chennapur	11KV	Keesara	16.40	18.40	02.00		Tree fallen on 11kv line at Fara nagar	-
6		Singapur	Singapur 1	11KV	Keesara	15.45	17.10	01.25		11KV jumper cut at Block 33	-
7		P&T colony	Chengicherla	11KV	Keesara	17.10	18.15	01.05		Tree fallen on 11kv line at MKBR garden	-
8		Saket	Dammaiguda	11KV	Keesara	17.33	18.22	00.49		Tree fallen on 11kv line at Prashanti enclave	-
9		Nagaram	SN colony	11KV	Keesara	16.05	17.50	01.45		Insulaotr fail at Rampally X road	-
10		Keesara	Cheryala	11KV	Keesara	16.18	18.40	02.22		11KV line cut at Kundanpally	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Chilkalguda	Dandu Pentaiah	11KV	V	15.56	17.20	01.24	EL	1st Line AB Switch Jumper cut at Thungabadra	-----
2		Seethaphalmandi	Seethaphalmandi	11KV	V	16.30	18.40	02.10	EL,OL-Rph	No Visible Fault (Due to Rain)	-----
3		Seethaphalmandi	Warasiguda	11KV	V	16.33	17.55	01.22	EL,OL	No Visible Fault (Due to Rain)	-----
4		Gunrock	Anjaiah Nagar	11KV	VI	16.15	17.55	01.40	EL,OL-Rph	Cable fault at Market Yard, due to 33KV Line snapped	-----
5		I.D.P.L	Samatha Nagar	11KV	VI	16.20	17.40	01.20	EL	CT PT fault at ELICO Company	-----
6		Bowenpally	Goutham Nagar	11KV	VI	16.25	17.45	01.20	EL	Tree branches fallen on line at 1st Line AB Switch, Goutham Nagar	-----
7		Gunrock	Bowenpally	11KV	C-VI	16.15	17.55	01.40	All Indication	No Visible Fault (Due to Rain)	-----
8		Gymkhana	Balaji Enclave	11KV	C-VI	16.20	18.33	02.13	EL	HT Jumper cut at Road No.4	-----
9		Gymkhana	Tadbun Temple	11KV	C-VI	16.23	17.39	01.16	EL	No Visible Fault (Due to Rain)	-----
10		Gymkhana	Sikh Village	11KV	C-VI	16.25	19.33	03.08	All Indication	Big tree fallen on lines at FOC backside	-----
11		Tirumalagiri	Jupiter Colony	11KV	C-VI	16.33	18.34	02.01	EL	Tree branches fallen on line at Teachers Colony	-----
12		Nehru Nagar	L.I.C	11KV	C-VI	16.40	18.45	02.05	EL	Tree branches fallen on line at Court Office	-----
13		Road No.12	N.B.T Nagar	11KV	X	16.34	18.30	01.56	EL	Jumper cut at Pochamma Temple, Road No.12	-----
14		Film Nagar	B.V.Bhavan	11KV	X	16.50	18.02	01.12	EL	Jumper cut at Road No.71	-----
1	HYD S	Asmangadh	G.A.Bank Colony	11KV	VIII	15.53	17.40	01.47	OL-Yph	Stick fallen on lines at Post Office	
1	HYD C	Narayanguda	City Central Library	11KV	I	16.31	18.10	01.39	EL	Tree fallen on lines at Ganesh Temple	-----
2		Jawahar Nagar	Jawahar Nagar	11KV	I	16.38	18.05	01.27	EL,OL-Rph	Tree branches fallen on line at Jawahar Nagar	-----
3		Jawahar Nagar	Balaji Indiraprastha	11KV	I	16.40	18.10	01.30	EL	Tree branches fallen on lines at Janapriya Apartment	17:04 hrs partial feeder charged OK
4		Indira Park	Ambedkar Nagar	11KV	I	16.40	17.50	01.10	EL	Tree branches fallen on lines at Ashok Nagar	-----
5		Z.P Office	Anand Nagar	11KV	I	16.40	18.24	01.44	EL,OL	Tree branches fallen on line at Post Office, Anand Nagar	-----
6		Erramanzil	Jaffer Ali Bagh	11KV	I	16.48	18.12	01.24	OL-Rph	Tree branches fallen on lines at Care Hospital	-----
7		Jawahar Nagar	J.N Homes	11KV	I	16.57	19.15	02.18	EL	Pin Insulator flash over at Garunda Apartment	-----
8		Industrial Area	Shankarmutt	11KV	II	16.30	18.00	01.30	EL,OL-Rph	Rope fallen on HT lines at Shankarmutt	-----
9		Golnaka	Kamala Nagar	11KV	II	16.35	17.52	01.17	EL,OL	HG fuse fault at Lanka PT	-----
10		Vittalwadi	Y.M.C.A	11KV	II	16.35	18.12	01.37	EL,OL-Rph	Tree branches fallen on line at Reddy College	-----
11		Golnaka	Nehru Nagar	11KV	II	16.44	18.09	01.25	EL,OL-Rph	HG fuse fault at Nehru Nagar Park	-----
12		Industrial Area	Barkathpura	11KV	II	16.48	18.30	01.42	All Indication	Tree branches fallen on lines at Nalakunta Market	-----
13		Amberpet	Tilak Nagar	11KV	II	17.03	18.40	01.37	EL	Tree branches fallen on lines at Cha Cha Nagar	-----
14		Industrial Area	R.O.M	11KV	II	17.08	19.10	02.02		Tree fallen on lines at Industrial Area	Arranged B/F on 11KV Preventive Medicine feeder
15		Vittalwadi	A.P.C.O	11KV	II	17.55	19.55	02.00	EL	Tree branches fallen on lines at Canara Bank	19:25 Hrs partial charged OK
16		Vittalwadi	Gandhi Kuteer	11KV	II	20.55	22.15	01.20	EL,OL-Bph	No Visible Fault (Due to Rain)	-----
17		S.D Hospital	Humayun Nagar	11KV	VII	15.40	16.52	01.12	OL-Rph	No Visible Fault (Due to Rain)	-----
18		ITI Mallepally	Zaheera Masjid	11KV	VII	16.34	18.32	01.58	EL,OL	No Visible Fault (Due to Rain)	-----
19		Asif Nagar	Military	11KV	VII	16.36	18.53	02.17	EL,OL-Rph	No Visible Fault (Due to Rain)	-----
20		ITI Mallepally	Anjuman	11KV	VII	16.40	18.15	01.35	EL,OL	Faulty loads of 11KV Zeba Bagh fdr	-----
21		Asif Nagar	Hakimpet	11KV	VII	16.40	18.44	02.04	EL,OL-Yph	No Visible Fault (Due to Rain)	-----
22		Asif Nagar	Kakatiya Nagar	11KV	VII	16.40	18.20	01.40	EL	No Visible Fault (Due to Rain)	-----
23	S.D Hospital	Cha Cha Nehru Park	11KV	VII	16.45	18.15	01.30	EL	Breaker problem at SS	Arranged B/F on 11KV Khadi Bandar feeder	
24	Asif Nagar	N.S.F Colony	11KV	VII	16.52	18.10	01.18	EL	Pin Insulator flash over at Akberpura	-----	
25	Asif Nagar	Padmanabha Nagar	11KV	VII	16.59	18.16	01.17	EL,OL-R&Yph	No Visible Fault (Due to Rain)	-----	
26	Mothi Mahal	Company Bagh	11KV	VII	17.01	19.06	02.05	EL,OL-Yph	Kite Sticks on lines at Company Bagh	-----	
27	Gudimalkapur	Sriram Nagar	11KV	VII	17.29	19.01	01.32	EL,OL	Tree branches fallen on lines at Patel Dairy Farm	-----	
28	S.D Hospital	Ahmed Nagar OH	11KV	VII	18.50	20.20	01.30	OL-R&Bph	Tree branches fallen on lines at S.D.Quarters	-----	