

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | 7 | | 7 | | 7 | | | |
| 6 | RR(N) | 54 | 550 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | 1 | 12 | 1 | 12 | 1 | 12 | | | |
| | Total | 606 | 3055 | 2 | 20 | 2 | 20 | 2 | 20 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| 2 | NLG | 144 | 988 | 2 | 3 | 2 | 3 | 2 | 3 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 3 | 4 | 3 | 4 | 3 | 4 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 5 | 24 | 5 | 24 | 5 | 24 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 17.04.2020

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|--|
| 1 | MBNR | Kodangal | Kodangal | 33kv | Vikarabad | 19.45 | 22.06 | 02.21 | E/L | Insulator damaged near Ravulapally (vi) | Kodangal | - |
| 1 | NLG | Yerrabelly | Kannekal | 33kv | Miryalaguda | 03.20 | 08.35 | 05.15 | EL | 33KV Insulator failure near GUNTIPALLY(V) | Kannekal | - |
| 2 | | Aitipamula | Aitipamula | 33kv | Nalgonda | 09.02 | 09.50 | 00.48 | EL | Aitipamula AB Switch open test charge supply ok Kattangur no supply | Aitipamula | - |
| 1 | RR N | 132KV Malkaram | 33KV Shameerpet | 33kv | Medchal | 12.55 | 14.55 | 02.00 | | No Fault | 33KV Shameerpet | - |
| 1 | HYD N | 132KV J' Hills - Mothi Mahal | Film Nagar | 33kv | Jubilee Hills | 06.24 | 06.28 | 00.04 | OL-Bph | Cable fault at Road No.86, Jubile Hills | Film Nagar | Loads normalised to 132KV J' Hills SS |

TSSPDCL - LMRC / Corporate office

Date: 17.04.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|--|
| 1 | MBNR | Kandoor | Komreddypally | 11kv | Jadcherla | 08.25 | 09.10 | 00.45 | | B.D.1Kv Insulator Failure Near Komreddypally(Vi). | - |
| 1 | NLG | Arlagaddagudem | N.R.Gudam | 11kv | Nalgonda | 06.00 | 07.45 | 01.45 | EL | Jumper cut | - |
| 2 | | Penpahad | Dubbathanda | 11kv | Suryapet | 07.40 | 10.55 | 03.15 | EL | Tree fallen on the line | - |
| 3 | | Golankonda | Golankonda | 11kv | Bhongir | 13.00 | 14.10 | 01.10 | EL | 11kv Line sanpped | - |
| 1 | RR S | Gachibowli | Aparna | 11kv | Gachibowli | 14.10 | 15.15 | 01.05 | | Tree branches fallen on the 11kv line at Alend company | - |
| 2 | | ESCI | Nanakramguda | 11kv | Gachibowli | 20.10 | 21.45 | 01.35 | | Due to heavy wind and rain | - |
| 3 | | Nanakramguda | IIRM | 11kv | Gachibowli | 21.20 | 22.50 | 01.30 | | Due to heavy wind and rain,Tree fallen on the 11kv line and 9.1 pole damaged at ICICI bank backside | - |
| 4 | | Hafeezpet | Vyshali Nagar | 11kv | Gachibowli | 20.05 | 21.30 | 01.25 | | Due to heavy wind and rain | - |
| 5 | | ESCI | Lumbini Park | 11kv | Kondapur | 19.48 | 21.10 | 01.22 | | Due to heavy wind and rain | - |
| 6 | | ESCI | Cyber Hills | 11kv | Kondapur | 20.02 | 21.28 | 01.26 | | Due to heavy wind and rain | - |
| 7 | | ESCI | Gachibowli | 11kv | Kondapur | 20.15 | 21.44 | 01.29 | | Due to heavy wind and rain | - |
| 1 | RR N | RGK Suraram | RGK | 11kv | Jeedimetla | 11.37 | 12.37 | 01.00 | EL | 11KV Insulator failure near 22 block at RGK | - |
| 1 | HYD N | Seethaphal Mandi | Namala Gundu | 11kv | V | 07.15 | 09.35 | 02.20 | EL,OL | No Visible Fault | 07:45Hrs partial fdr charged & remaining loads added on 11KV Gandhi Statue fdr |
| 2 | | Pragatools | L&T | 11kv | VI | 19.51 | 21.20 | 01.29 | EL | Tree branches fallen on lines at Gandhi Nagar | ----- |
| 3 | | H.M.T | Chinthal | 11kv | VI | 19.58 | 21.08 | 01.10 | EL | Tree branches fallen on lines at Agro Company, Chinthal | ----- |
| 4 | | I.D.P.L | Samatha Nagar | 11kv | VI | 20.05 | 21.55 | 01.50 | EL | No Visible Fault (Due to Rain) | ----- |
| 5 | | Jubilee Hills | A.O.U. | 11kv | X | 20.05 | 21.15 | 01.10 | EL | Tree branches fallen on lines at Road No.47 | ----- |
| 6 | | Kalyan Nagar | Yousufguda | 11kv | X | 20.11 | 21.24 | 01.13 | EL | No Visible Fault (Due to Rain) | ----- |
| 7 | | Bowenpally | Plassy Line | 11kv | VI | 20.16 | 21.30 | 01.14 | EL,OL-Yph | Disc Insulator flash over at More Super Market | ----- |
| 8 | | Kalyan Nagar | Madhura Nagar | 11kv | X | 20.16 | 21.35 | 01.19 | EL,OL | No Visible Fault (Due to Rain) | ----- |
| 9 | | Prashasan Nagar | Seri Culture | 11kv | X | 20.18 | 21.45 | 01.27 | EL,OL | Cable End Kit failed at Seri Culture | Arranged B/F on 11KV Andhra Bank fdr |
| 10 | | Kalyan Nagar | Rahamath Nagar | 11kv | X | 20.21 | 22.13 | 01.52 | EL,OL | 2No. Pin Insulators flash over at Rahamath Nagar X Road & Gurudwara Lane | ----- |
| 11 | | S.P.R.Hills | Bora Banda | 11kv | IV | 20.25 | 21.30 | 01.05 | EL | Tree branches fallen on lines at Kaktiya Wines | ----- |
| 12 | | Gymkhana | Mud Fort | 11kv | C-VI | 20.55 | 22.05 | 01.10 | EL,OL-Bph | Breaker problem at SS, Pin Insulator flash over & Jumper cut at Sagar Enclave | Arranged B/F on 11KV Bowenpally fdr & 11KV Balaji Enclave fdr |