

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		2		2		2			
3	MDK	107	933		4		4		4			
4	SDPT			1	15	1	15	1	15			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	23	2	23	2	23	0	0	
	Grand Total	1082	6468	2	27	2	27	2	27	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Manthati	33KV	Nagarkurnool	17.10	19.08	01.58	EL	DP Pole Damaged	Manthati	Alternate Supply Taken to 33KV Peddakothapally Feeder at 19:08Hrs
1	SDP	Mustyala	Cherial	33KV	Husnabad	06.55	08.20	01.25		Tree fallen on 33KV line Near gurjakunta SS	Cherial	-

TSSPDCL - LMRC / Corporate office

Date: 19.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Udithyal	Macharam	11KV	Jadcherla	12.50	14.45	01.55		11KV Line Phase to Phase near Suraram vagu	-
2		Midjil	Boinpally	11KV	Jadcherla	06.00	09.30	03.30		11KV Disc Fail near 132KV SS Midjil	-
1	NLG	Ravulapally	Kukkadam	11KV	Suryapet	09.30	12.00	02.30	E/L	11Kv Insulator failed	-
2		Munagala	Town	11KV	Huzurnagar	08.50	10.20	01.30	E/L	11Kv Line Snapped	-
1	MDK	SOL	IDA-II	11KV	Patancheru	11.55	12.52	00.57		BD due to Pole damaged	-
2		Patancheru Town	BSNL	11KV	Patancheru	10.35	12.25	01.50		BD due to Cable kit failed	-
3		Kistareddypet	Patelguda	11KV	Patancheru	09.24	12.10	02.46		BD due to Tree branches fallen on line	-
4		Dundigal	Annaram	11KV	Patancheru	07.30	10.18	02.48		BD due to Tree branches fallen on line	-
1	SDP	HUSNABAD	HUSNABAD TOWN-1	11KV	Husnabad	05.10	05.45	00.35		Line snapped	-
2		KATKUR	KATKUR RURAL	11KV	Husnabad	06.15	08.45	02.30		Insulator failure	-
3		THOTAPALLY	ANTHAKKAPET	11KV	Husnabad	05.18	08.02	02.44		Insulator failure	-
4		GANDIPALLY	GANDIPALLY	11KV	Husnabad	05.30	08.50	03.20		Line snapped	-
5		GANDIPALLY	RAMAVARAM EXP	11KV	Husnabad	05.40	07.50	02.10		Due to rainfall	-
6		DHARMARAM	Dharmaram(R.)	11KV	Husnabad	05.50	08.30	02.40		Due to rainfall	-
7		BEJANKI	MUTHANNAPET	11KV	Husnabad	04.40	16.40	12.00		Due to rainfall(3 ph BD 1-ph ok)	-
8		RAMCHANDRAPUR	VINJAPALLY	11KV	Husnabad	04.10	08.40	04.30		Insulator Failure	-
9		RAMCHANDRAPUR	VARIKOLU	11KV	Husnabad	04.20	08.00	03.40		Insulator failure	-
10		KOHEDA	SRIRAMULAPALLY	11KV	Husnabad	05.10	07.50	02.40		Insulator failure	-
11		SAMUDRALA	SAMUDRALA (R)	11KV	Husnabad	06.00	10.00	04.00		Due to rainfall & insulator failure	-
12		Cherial Town	Rollabanda Agl	11KV	Husnabad	07.30	10.00	02.30		Due to treefall	-
13		Akunoor	Rudrapally	11KV	Husnabad	08.10	12.40	04.30		Insulator Failure	-
14		Dhoolmitta	Lingapur	11KV	Husnabad	05.20	08.45	03.25		Due to rainfall	-
15		Gagillapur	Gagillapur Agl	11KV	Husnabad	11.30	13.30	02.00		Insulator failure	-
1	RR S	IIIT	APHB Colony	11KV	Gachibowli	02.40	03.55	01.15	BD	11kv AB Cable failed at DLF Gate-03	-
1	RR E	Chakriapuram	Shilpa Nagar	11KV	Keesara	09.31	13.50	04.19		Tree branches fallen on 11kv line at Shilpa Nagar	-
2		Peerzathiguda	Peerzathiguda	11KV	Keesara	10.40	11.45	01.05		Tree branches fallen on 11kv line at Peerzathiguda Main Road	-
1	HYD N	Gymkhana	Balamrai	11KV	C-VI	10.40	12.22	01.42	EL,OL-Bph	HT Line snapped at Geethanjali School	-