

Details of Power Transformers Failures

S.No.	Circle	No of PTRs Existing as on 31.03.2020	No of PTRs failed during the F/Y 2019-20	% Failures for the FY 2019-20	No of PTRs failed during the F/Y 2020-21	No of PTRs failed during the month April - 2020	No.of PTRs failed during the day	PTRs failed under				Failed PTRs replaced during the month	Reasons for not replaced
								WGP	RGP	BGP	TOTAL		
1	MBN	577	0	0.00	0	0	0				0		
2	NLG	680	0	0.00	0	0	0				0		
3	MDK	758	0	0.00	0	0	0				0		
4	RR(S)	438	0	0.00	0	0	0				0		
5	RR(N)	118	0	0.00	0	0	0				0		
6	RR(E)	242	0	0.00	0	0	0				0		
7	Hyd	314	0	0.00	0	0	0				0		
	Company	3127	0	0.00	0	0	0	0	0	0	0		

Details of PTR failures during the current month :

PTRs replaced in place of failed PTRs .

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	0	1	0	1	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	1	2	1	2	1	0	0	
	Grand Total	1082	6468	3	1	3	1	3	1	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alampur	Shantinagar-1	33KV	Gadwal	17.29	18.51	01.22	E/L	Tree Fallen on the line Near Maisamma Gattu		-
1	MDK	Zaheerabad	Mannapur	33KV	Zaheerabad	06.25	08.45	02.20		B/D due to Jumper cut		-
1	HYD S	132KV Fever Hospital-	Bathakamma Kunta	33KV	Chilkaiguda	03.06	03.49	00.43	OL-Bph	Straight through Joints failed on 33KV Bathamma Kunta - Fever hospital line at Tirumala Agency		-

TSSPDCL - LMRC / Corporate office

Date: 22.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gondriyala	Gondriyala 01	11KV	Huzurnagar	12.00	13.20	01.20	EL	Due to 11Kv Jumper open	-