

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	9	2	9	2	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijnapally	33kv	Nagarkurnool	19.18	19.48	00.30	E/L	Chameleon Fallen on the line near Vaddeman	Bijnapally	-
2		Wanaparthi	Gopalpet	33kv	Wanaparthi	22.46	23.50	01.04	E/L&O/L	Due to Heavy Spark Observed	Gopalpet	-

TSSPDCL - LMRC / Corporate office

Date: 23.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Alwanpally	11kv	Jadcherla	10.52	12.44	01.52		11KV Phase To Phase Near Alwanpally(V)	-
2		Bhoothpur	Amistapur	11kv	Jadcherla	09.30	10.05	00.35		Tree Fallen On The 11KV Line Near Hasnapur(V)	-
1	NLG	B.Chandupatla	V.K Pahad	11kv	Suryapet	15.15	17.45	02.30	E/L	11Kv Insulator flashover	-
2		Gondiryala	Gondiryala-1	11kv	Huzurnagar	10.50	12.30	01.40	E/L	11Kv Line snapped	-
3		Bollepally	Jampally	11kv	Bhongir	08.30	09.45	01.15	EL/OL	11kv Insulator failed & 11 KV Line snapped at Bhupal reddy well Near Sub station back side.	-
4		Choutuppal IPDS	Dhamera Agl	11kv	Choutuppal	18.32	06.39	12.07	EL/OL	11kv Insulator failed Near Dhamera (V)	-
1	HYD N	Lalaguda	Nagarjuna Nagar	11kv	V	04.36	05.45	01.09	EL	Pole damaged at Hanuman Temple	Partial loads arranged B/F on 11KV Dall Mill feeder
2		Hakimpet	Allenby Lines	11kv	C-VI	06.40	10.59	04.19	A/R Opened	Cargi HT Service fault	-----
3		Chilkaiguda	N.T.P.C	11kv	V	10.40	12.02	01.22	EL,OL-Rph	Cable fault	Arranged B/F on 11KV NTPC from 33KV Bansilalpet SS