

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044	2	7	2	7	2	7			
	Total	606	3055	2	8	2	8	2	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	10	1	10	1	10			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	10	2	10	2	10	0	0	
	Grand Total	1082	6468	4	18	4	18	4	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Shadnagar	Rayalseema	33kv	Shadnagar	16.17	18.10	01.53	E/L	Jumper Cut & Binding Work at 220KV SS Shadnagar	Rayalseema	-
1	NLG	Guntipally	Singarajpally	33kv	Devarakonda	16.00	20.18	04.18	E/L	CT Failure	Singarajpally	-
1	HYD N	132KV Jubilee Hills	Golden Jubilee (HT service)	33kv	Jubilee Hills	15.23	22.02	06.39	EL,OL-Yph	Cable damaged by Transco Opp. To Dell Office, Madhapur (2Nos straight through joints provided by Transco wing)	Golden Jubilee (HT service)	---
1	HYD C	132KV N.I.M.S. - A.C.Guards	S.D.Hospital	33kv	Saifabad	19.01	19.15	00.14	EL,OL	33KV S.D.Hospital extension supply End Kit failed at 33KV A.C.Guards SS	S.D.Hospital	Loads transferred onto 132KV Asif Nagar SS via 33KV S.D.Hospital fdr

TSSPDCL - LMRC / Corporate office

Date: 24.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	G.T Giri	Gunjalooru	11kv	Suryapeta	05.55	07.00	01.05	E/L	Tree Branch fallen on the line	-
2		Dirsincherla	Dirsincherla	11kv	Huzurnagar	03.30	06.30	03.00	EL	Due to 11Kv line Snapped	-
3		Thadakamalla	Settipalem	11kv	Miryalaguda	16.00	18.15	02.15	EL	Conductor Snaped	
4		Datherpally	Mallapuram	11kv	Bhongir	07.24	08.56	01.32	EL	11 kv Line snapped near Mallapuram village	
5		Golanpally	Golanpally	11kv	Choutuppal	02.10	08.30	06.20	EL	2 no's 11 KV Pole dammaged near Nemalikaluva village	
6		Junuthala	Thandarapally	11kv	Devarakonda	17.30	18.10	00.40	EL	Movement Fault	-
7		Junuthala	Makkapally	11kv	Devarakonda	17.30	18.00	00.30	EL	Movement Fault	-
8		Palvai	Kalavapally	11kv	Devarakonda	17.30	18.00	00.30	EL	Jumper Cutt	-
9		Shivannagudem	Shivannagudem	11kv	Devarakonda	17.30	18.30	01.00	EL	Cable Burnt	-
10		K.B.Pally	Venkapally	11kv	Devarakonda	17.30	18.20	00.50	EL	AB Switch Flames	-
1	RR N	Dulapally	IDA-I	11kv	Medchal	18.17	20.29	02.12	BD	33KV Pole damaged and fallen on the 11KV Line at Chowdary Company	-
1	HYD N	Ayyappa Society	Hitech Theater	11kv	X	18.45	20.10	01.25	EL,OL-R&Yph	Tree branches fallen on lines at Jai Enclave	-----
2		Jubilee Hills	Art Gallery	11kv	X	18.49	20.25	01.36	All Indication	Foreign material fallen on lines at D.S.R Apts	-----
3		Madhapur	Gowrah	11kv	X	18.55	20.50	01.55	EL	Tree branches fallen on lines at Gafoor Nagar	-----
4		Prashasan Nagar	B.N.R.Hills	11kv	X	19.50	21.08	01.18	OL-Rph	Tree branches fallen on lines at Road No.51	-----
1	HYD S	Asmangadh	Shiva Ganga	11kv	VIII	19.12	20.53	01.41	EL	Bushing Rod fault at Bharadwaj Apts	At 20:45 Hrs partial fdr loads added on 11KV P&T Colony fdr
1	HYD C	Durga Nagar	Chenna Reddy Nagar	11kv	II	19.13	20.23	01.10	EL	Cable fault	Arranged B/F on 11KV C.P.L feeder
2		Nampally	Red Hills	11kv	VII	19.00	20.40	01.40	EL	No Visible Fault	-----