

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	2	13	2	13	2	13			
3	MDK	107	933									
4	SDPT				16		16		16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	29	4	29	4	29	0	0	
	Grand Total	1082	6468	5	36	5	36	5	36	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Rajapur	33KV	Wanaparthy	10.50	12.35	01.45		CT Blast	Rajapur	Alternate supply given from 132KV SS Singotam at 12:35 hrs
2		Alampur	Shanthinagar -1	33KV	Gadwal	09.50	12.08	02.18	E/L	for AB Switch Open at Paipad Metel	Shanthinagar -1	No
1	NLG	Guntipally	Thatikolu	33KV	Devarakonda	13:15	16:08	2:53	E/L	Insulator Failed	Thatikolu	No
2		Suryapet	Nuthankal	33KV	Suryapet	13.25	17.55	04.30	E/L	Jumpet Cut	Nuthankal	No
1	RR N	132KV Medchal	Athively	33KV	Medchal	13:41	17:25	3:44		33KV Pad clamp failed at Bharat Petrol pump Medchal	Athively	At 13:50 hrs. Alternate supply arranged from 33KV Nuthankal feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamangundla	Yerrasanigudem	11KV	Nalgonda	12:30	13:45	1:15	E/L	Jumper cut	No
2		Yerkaram	Yerkaram	11KV	Suryapet	05.30	07.40	02.10	E/L	Jumper cut	No
3		Repala	Kalakova	11KV	Huzurnagar	05.00	07.00	02.00	EL	11KV Line snapped	No
4		Mukundapuram	Somaram	11KV	Huzurnagar	05.30	06.45	01.15	E/L	11KV Line snapped	No
5		Anantharam	Hanmapuram	11KV	Bhongir	00.20	09.15	08.55	EL	11KV Line snapped	No
6		Bollepally	Surepally	11KV	Bhongir	06.00	11.00	05.00	E/L	2 Nos 11kv Poles Damaged	No
7		Nandanam	Telephone Exchange	11KV	Bhongir	22.20	08.45	10.25	EL	11KV Insulator failed	No
8		NG.Bandal	Veerareddypally	11KV	Bhongir	06.20	14.20	08.00	E/L	11KV Disc failed	No
9		Golankonda	Matoor	11KV	Bhongir	05.30	07.05	01.35	EL	11KV Line snapped	No
10		Golankonda	Vanchyagudem	11KV	Bhongir	05.30	11.00	05.30	E/L	11KV Insulator failed	No
11		Sharajipet	Sharajipet	11KV	Bhongir	08.00	14.00	06.00	EL	11KV Insulator failed	No
12		Juloor	Pilaipally	11KV	Choutuppal	06.45	08.45	02.00	E/L	11KV Line snapped	No
13		MT.Pally	Thimmapur	11KV	Choutuppal	23:50	8:16	8:26	EL	11KV Line snapped	No
1	SDPT	Pandilla	Pandilla Express	11KV	Husnabad	16:40	17:40	1:00		Tree fallen	No
2		Dharmaram	Nandaram	11KV	Husnabad	06.40	09.40	03.00		2 Poles Broken	No
3		Akunoor	Rudrapally	11KV	Husnabad	02.25	10.10	07.45		Tree fallen	No
4		Chityal	Dommeta	11KV	Husnabad	01.00	09.15	08.15		Tree fallen	No
5		Jagadevapur	Industrial feeder	11KV	Gajwel	14.39	18.00	03.21		11KV Cable kit burnt	No
6		Jagadevapur	Town feeder	11KV	Gajwel	10.25	12.10	01.45		11KV Line insulator failed	No
7		Munigadapa	Wattipally	11KV	Gajwel	13.55	15.40	01.45		11KV Line cut	No
8		Kodakandla	Kuknoorpally	11KV	Gajwel	10.30	14.35	04.05		11KV Jumper cut	No
9		Ganeshpally	Angadikistapur	11KV	Gajwel	15.45	16.30	00.45		LT Jumper cut	No
10		Wardharajpur	Wardharajpur	11KV	Gajwel	04.02	09.29	05.27		11KV Line breakdown	No
11		Wardharajpur	Kothapet	11KV	Gajwel	10.20	12.24	02.04		HT/LT Line burnt	No
12		Damarakunta	Damarakunta	11KV	Gajwel	11.30	12.25	00.55		LT Line cut	No
13		Wargal	Town feeder	11KV	Gajwel	07.20	08.00	00.40		11KV Line jumper cut	No
14		Sitarampally	Vellore	11KV	Gajwel	18.00	19.30	01.30		11KV Insulator failed	No
15		Doulathabad	Town feeder	11KV	Gajwel	19.29	20.32	01.03		LT Cable burnt	No
16		Rampur	Rampur	11KV	Gajwel	07.50	09.15	01.25		11KV Jumper cut	No
1	RR E	AS Rao Nagar	Maruthi Nagar	11KV	Sainikpuri	14:20	15:12	0:52		No visible fault	No
2		Chakripuram	Shilpa Nagar	11KV	Keesara	10.08	11.30	01.22		Tree fallen on 11KV line at Shilpa Nagar	No
3		Keesara	Bogaram	11KV	Keesara	06.30	07.10	00.40		Lizard fallen on 11KV line at Bogaram Road	No
4		Yadgarpally	Thimmaipally	11KV	Keesara	11.30	12.00	00.30		11KV HG fuse failed at Thimmaipally Bondalgadda T/F	No
5		Narapally	AP Meat	11KV	Keesara	9:30	10:30	1:00		Tree branches fallen on 11KV Line at Ganesh Nagar	No
1	HYD C	Fever Hospital	Nallakunta	11KV	II	18.30	19.33	01.03	EL,OL-Rph	Cable fault at Fever Hospital X Road	Arranged B/F on 11KV Indira Nagar feeder
2		Batkammakunta	Shivam	11KV	II	21.46	22.50	01.04	OL	Over load	Removed loads of 11KV DDH fdr