

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044	1	39	1	39	1	39			
	Total	606	3055	1	40	1	40	1	40	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	8	1	8	1	8			
3	MDK	107	933									
4	SDPT				11		11		11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	19	2	19	2	19	0	0	
	Grand Total	1082	6468	3	59	3	59	3	59	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.04.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Peddakothapally	33KV	Nagarkurnool	15.58	17.35	01.37	EL	33KV insulator failed Itikyala village	Peddakothapally	-
1	NLG	Gudapur	Narsingbatla	33KV	Nalgonda	19.55	22.20	02.25	EL	Pin Insulator Failed	Narsingbatla	-
1	HYD N	132KV Madhapur	Deva Bhoomi (HT Service)	33KV	Kalyan Ngr	10.54	13.56	03.02	EL,OL-Bph	Straight through Joint failed by digging Unknown person at Nandu Electricals	Deva Bhoomi (HT Service)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Marriguda	Thamadapally	11KV	Devarakonda	18.00	19.20	01.20	EL	11KV Line Cut	-
2		Nampally	Mandapuram	11KV	Devarakonda	18.00	19.30	01.30	EL	11KVLine Cut Tree Fallen the Line	-
3		Mellavai	Devathpally	11KV	Devarakonda	18.00	19.45	01.45	EL	11KV Line Cut	-
4		Junuthala	Makapally	11KV	Devarakonda	17.40	19.20	01.40	EL	11KV Jumper Cut	-
5		B.Chandupatla	Pachya thanda	11KV	Suryapet	06.00	09.00	03.00	E/L	Disc Flashover	-
6		Athmakur(S)	Athmakur	11KV	Suryapet	04.30	08.00	03.30	E/L	Conductor snapped	-
7		N.B.Gudem	Redlakunta	11KV	Huzurnagar	02.30	05.30	03.00	EL	Due to 11kv line snapped	-
8		Sirikonda	Ravipahad	11KV	Huzurnagar	10.00	13.00	03.00	EL	Due to 11kv tree branch fall on 11kv line	-
1	SDP	Nangnoor	Nangnoor	11KV	Siddipet	05.25	09.00	03.35		LC-B/D-Tree branches fallen on the line, LC book completed	-
2		Irkode	Irkode	11KV	Siddipet	13.15	17.45	04.30		LC -B/D - DTR fault, LC No. 15151	-
3		Komaticheruvu	Housing board	11KV	Siddipet	06.02	06.07	00.05		EL	-
4		Komaticheruvu	Kushal Nagar	11KV	Siddipet	15.05	15.10	00.05		EL	-
5		Indore	Erracheruvu	11KV	Siddipet	09.00	11.00	02.00		LC - PMI - LC No. 35816	-
6		Mustabad X-road	Raghavendhranagar	11KV	Siddipet	08.50	12.40	03.50		LC - Tree cutting, LC No. 35691	-
7		Dubbak	Dubbak MHQ	11KV	Siddipet	09.15	10.20	01.05		LC-Jumpuer out, LC No 17325	-
8		33/11KV SS Komuravelly	Kadavergu	11KV	Husanabad	02.15	08.26	06.11		11KV Line cut	-
9		WARGAL	WARGAL TOWN LC No. 13943	11KV	Gajwel	06.00	06.30	00.30		11 KV line touched by LT line	-
10		RAIPOLE	KOTHAPALLY LC No. 10931	11KV	Gajwel	19.07	20.20	01.13		SHAparpati Faile	-
11		LINGAPUR	LINGAPUR LC No. 266	11KV	Gajwel	07.00	08.40	00.40		Conductor snapping	-
1	RR N	Aliabad	HBL	11KV	Medchal	05.45	06.55	01.10		Bird fallen on the 11KV Line at Monsanto Company	-
1		Ch' Baradari	SRT Colony	11KV	III	17.38	19.50	02.12	EL	Faulty 4Nos DTR's at SRT Colony	-----
2		Salarjung	Darulshifa	11KV	III	17.45	19.15	01.30	EL,OL	Tree branches fallen on lines at Criminal Court	-----
3		Panjesha	Sultan Shai	11KV	III	17.45	19.40	01.55	EL	Tree branches fallen on lines at Sultan Shai	-----
4		Panjesha	Panch Mohallah	11KV	III	17.47	19.00	01.13	EL,OL	No Visible Fault (Due to heay rain & Gale)	-----
5		Ch' Baradari	Dood Bowli	11KV	III	17.47	19.30	01.43	OL-Bph	Tree fallen on lines at Kamatipura PS	-----
6		Falaknuma	Falaknuma OH	11KV	III	17.45	19.30	01.45	EL,OL	Tree Branches fallen on lines at Hemah Supply company	-----
7		Kandikal Gate	Saibaba Colony	11KV	III	17.42	19.30	01.48	EL,OL	O/G AB Switch Rph Jumper cut at SS	-----
8		Kandikal Gate	Rakshapuram	11KV	III	17.48	18.55	01.07	EL,OL	Tree Branches fallen on lines at Rakshapuram	-----
9		Kandikal Gate	G.M.Chowni	11KV	III	17.49	19.00	01.11	EL,OL	No Visible Fault (Due to heay rain & Gale)	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
10	HYD S	Kandikal Gate	Phool Bagh	11KV	III	17.52	19.00	01.08	EL,OL	No Visible Fault (Due to heay rain & Gale)	-----
11		Asmangadh	Shiva Ganga	11KV	VIII	17.38	18.47	01.09	EL,OL-R&Bph	No Visible Fault (Due to heay rain & Gale)	-----
12		Malakpet B-Block	Ekalavya Nagar	11KV	VIII	17.52	19.05	01.13	OL-R&Bph	Banner fallen on lines at Sai Nursing Home	-----
13		Malakpet B-Block	LIC Colony	11KV	VIII	17.53	19.05	01.12	OL-R&Bph	No Visible Fault (Due to heay rain & Gale)	-----
14		Santosh Nagar	Jyothi Bagh	11KV	VIII	17.48	18.54	01.06	OL-Yph	No Visible Fault (Due to heay rain & Gale)	-----
15		Santosh Nagar	Edi Bazar	11KV	VIII	17.48	18.53	01.05	EL,OL-Rph	No Visible Fault (Due to heay rain & Gale)	-----
16		Santosh Nagar	SRT Colony	11KV	VIII	17.48	18.54	01.06	OL-Rph	No Visible Fault (Due to heay rain & Gale)	-----
17		Santosh Nagar	Rein Bazar	11KV	VIII	17.48	18.55	01.07	EL,OL-Rph	No Visible Fault (Due to heay rain & Gale)	-----
18		Chanchalguda	Chanchalguda	11KV	VIII	17.40	19.05	01.25	OL	No Visible Fault (Due to heay rain & Gale)	-----
19		Chanchalguda	Anand Nagar	11KV	VIII	17.40	19.05	01.25	OL-Rph	No Visible Fault (Due to heay rain & Gale)	-----
20		Kanchanbagh	Jamal Colony	11KV	VIII	17.15	19.28	02.13	All Indication	No Visible Fault (Due to heay rain & Gale)	-----
21		Salarjung	Sadath Nagar	11KV	VIII	17.48	20.00	02.12	EL	Tree branches fallen on lines at Imlibun Masjid	-----
22		Laxmi Nagar	S.B.H.	11KV	VIII	17.49	20.08	02.19	EL	Tree branches fallen on lines at Kabrasthan	-----
23		Yakuthpura	Somnath Temple	11KV	VIII	17.45	20.12	02.27	EL	No Visible Fault (I/C supply failed to SS from 17:51Hrs to 19:40Hrs)	-----
24		Yakuthpura	Moulaka Chilla	11KV	VIII	17.49	20.20	02.31	EL,OL-Y&Bph	No Visible Fault (I/C supply failed to SS from 17:51Hrs to 19:40Hrs)	-----
25		Yakuthpura	Saleema Khatoon	11KV	VIII	17.50	20.10	02.20	OL-Y&Bph	No Visible Fault (I/C supply failed to SS from 17:51Hrs to 19:40Hrs)	-----
26		Yakuthpura	Bada Bazar	11KV	VIII	17.50	19.54	02.04	OL-Y&Bph	No Visible Fault (I/C supply failed to SS from 17:51Hrs to 19:40Hrs)	-----
27		Yakuthpura	Murthuza Nagar	11KV	VIII	17.50	20.02	02.12	OL-B&Yph	No Visible Fault (I/C supply failed to SS from 17:51Hrs to 19:40Hrs)	-----
28		Yakuthpura	Khan Nagar	11KV	VIII	17.50	20.11	02.21	OL-B&Yph	No Visible Fault (I/C supply failed to SS from 17:51Hrs to 19:40Hrs)	-----
29		Arundathi Colony	Kummarwadi	11KV	VIII	18.25	20.30	02.05	EL,OL	No Visible Fault (Due to heay rain & Gale)	Arranged B/F on 11KV Raza Nagar fdr
30		Santosh Nagar	Dry Land	11KV	VIII	18.53	20.17	01.24	EL	No Visible Fault (Due to heay rain & Gale)	-----
31		Santosh Nagar	Bhavani Nagar	11KV	VIII	17.48	20.16	02.28	OL-Yph	No Visible Fault (Due to heay rain & Gale)	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
32		Yakuthpura	Sravani Hospital	11KV	VIII	17.50	20.47	02.57	OL-Y&Bph	Tree branches fallen on lines at Sravani Hospital	-----
33		Santosh Nagar	Santosh Nagar	11KV	VIII	17.50	20.56	03.06	EL,OL	Tree branches fallen on lines at Kanaka Durga Temple	-----
34		Santosh Nagar	Chandra Huts	11KV	VIII	18.54	23.08	04.14	EL	Tree branches fallen on lines at various Locations (3No DTR's Kept off)	21:55Hrs charged without load
35		Santosh Nagar	Bhavani Nagar	11KV	VIII	20.50	23.48	02.58	EL,OL-Bph	Tree Branches fallen on lines at Talab Katta	-----
36		Malakpet B-Block	Ekalavya Nagar	11KV	VIII	19.38	21.02	01.24	OL-Rph	Tree Branches fallen on lines at Jakir Hussain Colony	-----
37		Kanchanbagh	Darga	11KV	VIII	19.10	20.30	01.20	EL,OL	No Visible Fault (Due to heay rain & Gale)	Arranged B/F on 11KV Habeeb Nagar fdr
38		Kanchanbagh	Kanchan Bagh	11KV	VIII	17.46	19.25	01.39	EL	No Visible Fault (Due to heay rain & Gale)	-----
39		Kulsumpura	R.K.Pet	11KV	IX	17.34	18.58	01.24	EL	LT damaged at Gandhi Hanuman Temple	-----