

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		8		8		8			
7	RR(E)	168	403		19		19		19			
8	Hyd	194	1044	1	10	1	10	1	10			
	Total	606	3055	1	37	1	37	1	37	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	8	6	8	6	8	6			
2	NLG	144	988		2		2		2			
3	MDK	107	933	4	2	4	2	4	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	12	10	12	10	12	10	0	0	
	Grand Total	1082	6468	13	47	13	47	13	47	0	0	

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijinapally	33KV	Nagarkurnool	21.35	22.49	01.14	EL	No Visible Fault Due to Rain	Nagarkurnool	No
2		Achampet	Uppunuthala	33KV	Nagarkurnool	21.35	23.30	01.55	EL	Insulator failed	Achampet	Alternate Supply Arranged from 33KV Veltloor feeder
3		Balanagar	Rajapur	33KV	Jadcherla	17.35	18.15	00.40	EL	No Visible Fault Due to Rain	Balanagar	No
4		Maddur	Maddur	33KV	Narayanapet	18.02	19.45	01.43	EL	Pin Insulater replaced at 33 KV Maddur	Maddur	No
5		Maddur	Kothapally	33KV	Narayanapet	18.02	19.45	01.43	EL	Pin Insulater replaced at 33 KV Maddur	Maddur	No
6		Shadnagar	Kisannagar	33KV	Shadnagar	17.47	19.15	01.28	EL & OL	Due to Rain	Shadnagar	Alternate Supply Arranged from 132KV Balanagar SS
7		Sri Rangapur	Mogilgidda	33KV	Shadnagar	17.46	19.28	01.42	EL	Due to Rain No visibule fault	Sri Rangapur	No
8		Alampur	Shanthinagar	33KV	Gadwal	16.12	22.00	05.48	OL	Tree follen on the line	Alampur	Alternate Supply Arranged from 33KV Shanthinagar 2 feeder
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	16.20	19.10	02.50		BD due to Tree branches fallen on line	Sadasivpet	-
2		Pashamailaram	SOL	33KV	Sangareddy	11.35	13.35	02.00		BD due to Tree fallen on line	Pashamailaram	-
3		Zaheerabad	Mirzapur B	33KV	Zaheerabad	16.10	18.30	02.20		BD due to Tree branches fallen on line	Zaheerabad	-
4		Gummadidala	GPSS-2	33KV	Patancheru	15.45	18.25	02.40		BD due to Conductor snapped	Gummadidala	-
1	HYD C	132KV Asif Nagar	Mothi Magar	CEN	Asif Ngr	08.25	08.35	00.10	OL-Bph	Cable Old Joint failed at Opp: Madina Mobile & Stationary Shop	132KV Asif Nagar	Loads transferred onto 132KV J' Hills SS

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 28.04.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Badepally	11KV	Jadcherla	18.26	19.10	00.44		11KV Jumper cut near Old Bajar	-
2		Rajapur	Mallepally	11KV	Jadcherla	17.30	21.30	04.00		Phase to Phase near Marribai thanda	-
3		Boothpur	Boothpur Town	11KV	Jadcherla	18.15	20.08	01.53		Phase to Phase near Boothpur	-
4		Kotha Molgara	Kotha Molgara	11KV	Jadcherla	17.30	20.00	02.30		11KV Jumper cut near Kappeta	-
5		Kotha Molgara	Madigatla	11KV	Jadcherla	17.20	18.10	00.50		Tree follon the line near Madogatla	-
6		Kotha Molgara	Karvena	11KV	Jadcherla	17.30	20.00	02.30		11KV Jumper cut near Kotha Molgara	-
1	NLG	Jalalpuram	Velishala	11KV	Suryapet	09.00	12.35	03.35	EL	Conductor snapped	-
2		Phanigiri	Phanigiri	11KV	Suryapet	08.45	10.10	01.25	EL	Insulator failed	-
1	MDK	Bollaram - II	Shalini	11KV	Patancheru	17.50	18.58	01.08		BD due to Insulator failed	-
2		Gummadidala	Agrobell	11KV	Patancheru	15.40	18.40	03.00		BD due to Insulator failed	-
1	RR N	Miyapur X road	Lotus colony	11KV	Kukatpally	02.35	03.50	01.15	BD	Tree branches fall on the 11kv line at MYP Bus body due to heavy wind	-
2		Town Medchal	Country Club	11KV	Medchal	16.06	17.16	01.10	BD	11KV Pole damaged by Lorry at Gove hospital Medchal	-
3		Medicity	Pudur	11KV	Medchal	15.50	19.00	03.10	BD	11KV Conductor Snapped at Bairangutta	-
4		Ravalkole	IDA Ganapathi	11KV	Medchal	15.30	18.30	03.00	BD	Tree fallen on the 11KV Line at Ravalkole Village	-
5		Thumkunta	Thumkunta	11KV	Medchal	16.00	17.20	01.20	BD	Tree fallen on the 11KV Line at Thumkunta Village	-
6		Kistapur	Welset	11KV	Medchal	15.45	17.00	01.15	BD	Tree fallen on the 11KV Line Ravalkole X road	-
7		Athiwelly	Athiwelly	11KV	Medchal	16.10	17.50	01.40	BD	Tree fallen on the 11KV Line & Jumper cut Athiwelly Village	-
8		Athiwelly	SPIC	11KV	Medchal	16.10	19.45	03.35	BD	11KV Poles Damaged at near by SPIC	-
1		Street no 8	Green hills colony	11KV	Habsiguda	16.40	17.52	01.12		Insulator fail at Gayatri tiffen beside street no 8	-
2		IDAuppall	Metro	11KV	Habsiguda	16.44	18.37	01.53		Tree Fallen & Insulator fail at VR Company	
3		Janapriya	Hihgh Tension	11KV	Sainikpuri	16.30	17.20	00.50		Tree Branches fallen on 11Kv line at Shivapuri Colony (AE/OP)	
4		Sainikpuri	Saipuri	11KV	Sainikpuri	17.10	17.55	00.45		Tree fall on 11Kv line at Hasthinapuri Colony 3rd Cross (AE/OP)	
5		Vayupuri	Vayupuri	11KV	Sainikpuri	17.00	18.10	01.10		2 Trees fall on 11Kvline at Vayupuri (LM Chandu)	
6		Moula-Ali	Jawahar Nagar	11KV	Sainikpuri	16.23	17.30	01.07		Mango Tree fall on 11Kv line at near SS (Artisan/Bala Narsimma)	
7		Moula-Ali	Mirzalaguda	11KV	Sainikpuri	16.23	18.26	02.03		Tree branches fall on 11Kv line at near HMT Compony (Artisan/Bala Narsimma)	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
8	RR E	Moula-Ali	HCL	11KV	Sainikpuri	16.23	18.20	01.57		11Kv line cut at Krishna Nagar Road No-2 (L Insp Srikanth)	
9		VP Nagar	Madhura Nagar	11KV	Sainikpuri	16.35	17.15	00.40		Tree branches fall on 11Kv line at Cable Office Madhura Nagar (AE/OP)	
10		VP Nagar	VV Puram	11KV	Sainikpuri	16.40	17.35	00.55		Tree fall on 11Kv line at VV Puram Road No 8 (AE/OP)	
11		Anandbagh	NMDC	11KV	Sainikpuri	16.26	17.38	01.12		Tree fall on 11Kv line at Sri Krishna Apt East Anandbagh (LM Babu)	
12		Anandbagh	Chandragiri Colony	11KV	Sainikpuri	17.24	18.19	00.55		Flexble Copper Patti cut at Jain Mandhir East Anandbagh (L Insp Venu)	-
13		Yapral	Pedso	11KV	Sainikpuri	17.20	18.00	00.40		Tree fall on 11Kv line at Pedso Phase-II (AE/OP)	-
14		Yapral	Tulasi Garden	11KV	Sainikpuri	17.20	19.00	01.40		Tree fall on 11Kv line at Shaily Garden (AE/OP)	-
15		Yapral	Pradamapuri	11KV	Sainikpuri	17.20	18.25	01.05		Tree fall on 11Kv line at SS Enclave (AE/OP)	-
16		Yapral	Yapral	11KV	Sainikpuri	17.20	19.00	01.40		Tree fall on 11Kv line at Andhra Bank Sai Krupa Colony (L Insp Murali)	-
17		Yapral	Govt School	11KV	Sainikpuri	17.20	19.10	01.50		Tree fall on 11Kv line at Employs Colony (AE/OP)	-
18		Peerzathiguda	Chenna reddy thota	11KV	Keesara	16.50	17.27	00.37		Coconut tree fallen on 11kv line at Ambedkar nagar	-
19		Nagaram	Bandlaguda	11KV	Keesara	01.54	03.45	01.51		Tree branches twiseded to 11kv line at Virat colony	-
1		HYD N	Macha Bollaram	Ayyappa Nagar	11KV	Bowenpally	16.07	17.13	01.06	EL,OL	No Visible fault (Heavy wind & Gale)
2	Macha Bollaram		Radha Sath Sang	11KV	Bowenpally	16.08	17.55	01.47	A/R Opened	Tree branches fallen on lines at Rukmini Enclave	-
3	Hakimpet		Risala Bazar	11KV	Bowenpally	16.10	17.30	01.20	EL,OL	Tree branches fallen on lines at Risala Bazar	-
4	Hakimpet		Bollaram P.S	11KV	Bowenpally	16.12	17.40	01.28	EL,OL	Tree branches fallen on lines at Lakkadwala	-
5	Macha Bollaram		Chinthal Bazar	11KV	Bowenpally	16.12	18.18	02.06	EL,OL	Tree branches fallen on lines at Viveka Nanda Nagar	-
6	Macha Bollaram		Sai Reddy Nagar	11KV	Bowenpally	16.13	18.55	02.42	EL,OL	Street Light Pole fallen on lines at Sai Brundavan Colony	-
7	R.P.Nilayam		Naga Devatha Temple	11KV	Bowenpally	16.18	18.06	01.48	EL,OL	FEL HT Service fault (Kept opened)	-
8	Gunrock		Anjaiah Nagar	11KV	Bowenpally	16.25	17.48	01.23	EL,OL	Brass Patti bunt out at Bowenpally Market	-
1	HYD S	Santosh Nagar	Chandra Huts	11KV	Asmangadh	07.40	09.35	01.55	OL-Rph	Cable fault at Crystal Bar (1No. DTR kept off)	-
1	HYD C	Bathkammakunta	C.E.Colony	11KV	Azamabad	02.45	04.06	01.21	EL,OL-Bph	Pin Insulator flash over at Ayyappa Temple	At 03:47Hrs Partial fdr charged