

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		15		15		15			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>24</b>	<b>0</b>	<b>24</b>	<b>0</b>	<b>24</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				16		16		16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>24</b>	<b>1</b>	<b>24</b>	<b>1</b>	<b>24</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>48</b>	<b>1</b>	<b>48</b>	<b>1</b>	<b>48</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 01.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	Gummadidala	33KV	Patancheru	11.08	13.35	02.27		BD due to Conductor pin binding failed		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 01.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narkatpally	M.Yedavally	11KV	Nalgonda	02.30	09.40	07.10	EL	11KV jumper cut	-
2		Chivvemla	Durajpally	11KV	Suryapet	08.30	12.10	03.40	EL	Disk failed	-
3		N B gudem	Redlakunta	11KV	Huzurnagar	13.10	15.10	02.00	EL	11 KV LINE SNAPPED	-
4		Nemaragommula	Jameelapet	11KV	Bhongir	05.07	08.05	02.58	EL/OL	11 KV Insulator failed at SS-50 near Gopal cheruvu Jameelapet village	-
5		Manaikunta	Gattusingaram	11KV	Bhongir	12.45	15.30	02.45	EL/OL	11 kv Disc failed at SS-2 near Gattusingaram village	-
1	MDK	Cheryal	Turbovent	11KV	Sangareddy	17.50	20.50	03.00		BD due to Disk failed	-
2		Patancheru Town	High power	11KV	Patancheru	14.15	17.15	03.00		BD due to Conductor snapped	-
3		Bollaram - I	Arobindo	11KV	Patancheru	15.04	17.50	02.46		BD due to Jumper cut	-
1	SDPT	Narmetta	Narmetta	11KV	Siddipet	07.35	11.10	03.35		B/D Insulater failed	-
2		Narmetta	Venkatapur	11KV	Siddipet	11.40	12.15	00.35		B/D disk fail	-
3		Ramancha	Gangapur	11KV	Siddipet	10.20	11.50	01.30		B/D 11Kv Line cut	-
4		Medipally	Ibrahimnagar	11KV	Siddipet	13.00	15.45	02.45		B/D 11Kv Line cut	-
5		Machapur	Gangapur	11KV	Siddipet	09.10	13.20	04.10		B/D 11Kv insulator Blot	-
6		Akberpet	Bhoompally	11KV	Siddipet	11.32	13.24	01.52		BiD 11Kv line cut	-
7		Mirdoddy	Andhy	11KV	Siddipet	09.36	14.45	05.09		Kv Disk Fail	-
8		THIGULLA	THIGULLA	11KV	Gajwel	05.10	07.32	02.22		CONDUCTER CUT	-
9		PREGNAPUR	KUKNOORPALLY	11KV	Gajwel	10.30	12.30	02.00		INSULATOR FAILED	-
10		MULUGU	MULUGU PT	11KV	Gajwel	01.35	03.15	01.40		PT FAILED	-
11		BEGUMPET	YELKAL	11KV	Gajwel	17:05	18:10	01.05		25 KV DTR FAILED	-
12		Akkannapet	Akkannapet rural	11KV	Husnabad	11.30	11.50	00.20		Line cut	-
13		Akkannapet	Fakkirnayak thanda	11KV	Husnabad	16.40	18.36	01.56		Line cut	-
14		Rebarthi	Rebarthi	11KV	Husnabad	08.15	09.20	01.05		Heavy gale and wind	-
15		Mustyala	Chunchanakota	11KV	Husnabad	09.30	11.40	02.10		Disk fail	-
16		Akunoor	Akunoor	11KV	Husnabad	09.05	11.05	02.00		Insulator fail	-
1	RR S	Chandanagar	Chandanagar	11KV	Gachibowli	14.30	17.00	02.30		Due to heavy rain, 11kv Line Jumper cut at Poornima Apartment	-
2		Balajinagar	Moosapet	11KV	Kondapur	15.45	17.30	01.45		11kv pin insulator failed to Replacement near LIG - 554 (Due to heavy Rain)	-
3		Balajinagar	KPHB Road No - 1	11KV	Kondapur	14.12	15.45	01.33		Due to Heavy Rain.	-
1	RR N	Kompally	Jaibheri	11KV	Medchal	14.30	16.35	02.05	EL	11KV Cable endkit failed at ARC Homes	-
2		Vijayanagar	Jalakanya	11KV	Kukatpally	14.55	17.15	02.20	EL	11kv AB Cable End kit failed at B type Allwyn Colony	-
3		Prashanthi Hills	Mithula Nagar	11KV	Kukatpally	15.40	17.30	01.50	EL/OL	Due to Heavy Rain	-
4		Vikas	Vikas	11KV	Kukatpally	17.15	19.10	01.55	EL/OL	Tree branches fallen on the 11kv line at Turbo company	-
5		KPHB	Bhagyanagar Colony	11KV	Kukatpally	15.04	16.22	01.18	EL/OL	Due to Heavy Rain, B/F Srinivasa Colony from HMT SS	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Uppal	Adarsh nagar	11KV	Habsiguda	17.10	18.40	01.30		11KV U/G Cable failed at Bharath nagar & B/F from 11KV Chilaka Nagar feeder	-
1	HYD N	Road No.13	Sai Enclave	11KV	Banjarahills	14.26	16.00	01.34	EL,OL-Rph	Tree branches fallen on lines at Burial Ground	-
2		N.I.M.S	Banjara Hills	11KV	Banjarahills	14.27	15.30	01.03	EL	No Visible Fault (due to Rain)	-
3		Seethaphal Mandi	Warasiguda	11KV	Sec-Bad	14.55	16.50	01.55	EL,OL-Rph	Post type insulator flash over at Sai Latha Apartment	15:50 Hrs Partial feeder charged
4		Tirumalagiri	Jupiter Colony	11KV	Sec-Bad	15.12	16.38	01.26	EL	Tree branches fallen on lines at Jupiter Colony	-----
5		Road No.12	C.R.P.F	11KV	Banjarahills	14.20	16.28	02.08	EL	Pin Insulator flash over at Meenashi Tower	-----
6		Clock Tower	Railway Reservation	11KV	Sec-Bad	16.15	17.25	01.10	EL,OL	Tree branches fallen on lines & Brass Patti cut at Pass Port Office	During the Period no supply to 11KV Station Road feeder (under B/F)
7		Prashanth Nagar	Ganesh Kanta	11KV	Bowenpally	16.15	17.20	01.05	EL	No Visible Fault (due to Rain)	-----
1	HYD S	Seetharambagh	Zinci Chowraha	11KV	Asmangadh	17.20	18.30	01.10	EL	Cable Jumper cut at Darulsalam	During the Period no supply to 11KV Gyanbagh Colony feeder (under B/F)
1	HYD C	Nampally	Red Hills	11KV	Mehdipatanam	14.28	15.39	01.11	All Indication	No Visible Fault (due to Rain)	-
2		S.D Hospital	Ahmed Nagar OH	11KV	Mehdipatanam	14.23	15.27	01.04	EL	No Visible Fault (due to Rain)	-
3		Public Garden	L.B Stadium	11KV	Saifabad	14.36	16.05	01.29	EL,OL-Rph	Tree branches fallen on lines at Bule Diamond PT, Basheerbagh	-
4		A.C.Gaurds	Niloufer	11KV	Mehdipatanam	14.20	16.02	01.42	EL,OL	Tree branches fallen on lines at Master Anurag Apartment	-
5		I.T.I Mallepally	Zaheera Masjid	11KV	Mehdipatanam	14.26	16.10	01.44	EL	Tree branches fallen on lines at Zaheera Masjid	-
6		A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11KV	Mehdipatanam	14.40	16.28	01.48	EL	Tree branches fallen on lines at Jeevan Kalyan Nagar	-
7		S.D Hospital	Ahmed Nagar Cable	11KV	Mehdipatanam	20.17	22.36	02.19	EL	Disc Insulator flash over at Priyadarshini School	-