

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	3	1	3	1	3			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		7		7		7			
	Total	606	3055	1	14	1	14	1	14	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	4	3	4	3	4			
2	NLG	144	988		6		6		6			
3	MDK	107	933		2		2		2			
4	SDPT				17		17		17			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	29	3	29	3	29	0	0	
	Grand Total	1082	6468	4	43	4	43	4	43	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.08.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Chinnamaroor	Jetprole	33KV	Wanaparthi	11.05	14.45	03.40	E/L	Tree Fallen on the Line Near Peddadagada Bus Stop	Jetprole	No
2		Polepally	Jadcherla	33KV	Jadcherla	11.01	16.12	05.11	E/L&O/L	Pole Adjustment & Phase to Phase Near Polepally	Jadcherla	No
3		Gadwal	Nandinne	33KV	Gadwal	12.45	18.30	05.45	E/L	Insulator Damages & Tree Fallen on the line near Nandinne	Nandinne	No
1	RR N	132KV LGM Pet	Aliabad	33KV	Medchal	14.42	15.46	01.04	EL	33KV Pin Insulator failed at Potharam X Road	Aliabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Jeedimetla SS II	Apuroopa colony	11KV	Jeedimetla	9:30	10:30	1:00	EL	11kv AB Cable failure opp Mazeed	No
2		Dulapally	IDA-II	11KV	Medchal	11:50	13:09	1:19	EL/OL	Tree fallen on the 11KV Line at Shiva sai company	No
3		Gowdavelly	IDA Gowdawelly	11KV	Medchal	10:10	11:20	1:10	EL	Tree fallen on 11KV Line at Basaragadi Village	No
1	RR E	Cherlapally-III	Danmed	11KV	Sainikpuri	11:59	13:40	1:41		11 Kv line cut at Ramtech Company	No
2		Chengicherla	My Villas	11KV	Keesara	09.30	10.30	01.00		11KV Brass patti cut at My Villas Dongala T/F	No
3		Aushapur	Madharam	11KV	Keesara	11.50	13.30	01.40		Line Patrolling but no visible fault	No
4		Aushapur	Ankushapur	11KV	Keesara	20.10	21.00	00.50		Line Patrolling but no visible fault & 11KV AB Switch opened at Jagath Swapna Venture	No
1	HYD N	Hakimpet	Risala Bazar	11KV	C-VI	10.45	11.50	01.05	EL	2No. DTR's fault at Risala Bazar	No
2		Marredpally	Lalitha Nagar	11KV	C-VI	13:15	14:20	1:05	EL	HG fuse blown at Samrat Colony	No
3		Hakimpet	Risala Bazar	11KV	C-VI	13:20	14:50	1:30	All Indication	Conductor snapped at Thurkapally	No
4		Hakimpet	Risala Bazar	11KV	C-VI	15:35	17:30	1:55	EL,OL	Jumper cut & Tree branches fallen on lines at Ratna Colony	No
1	HYD S	C.R.P.F.	Baba Nagar	11KV	III	09.30	12.30	03.00	EL	Tree branches fallen on lines at Aliya Garden & Jumper cut at Ismail PT	At 10:15hrs partial fdr charged
1	HYD C	Asif Nagar	N.S.F Colony	11KV	VII	14.20	15.41	01.21	EL	No visible fault	Arranged B/F on 11KV Military Hospital fdr
2		Langer House	Military Hospital	11KV	VII	21.40	23.55	02.15	EL,OL-Bph	Cable fault at Military Hospital (1No. DTR & Military Hospital Service Kept Off)	Arranged B/F on 11KV Jyothi Nagar feeder