

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		10		10		10			
	Total	606	3055	0	20	0	20	0	20	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	7	1	7	1	7			
2	NLG	144	988		3		3		3			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	10	2	10	2	10	0	0	
	Grand Total	1082	6468	2	30	2	30	2	30	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurthy	33KV	Narayanpet	16.55	19.35	02.40	O/L	Tree Fallen on the Line Near Kankurthy	Kankurthy	-
1	MDK	Kandi	Aradhana	33KV	Sangareddy	15.05	18.15	03.10		BD due to Lighting Arrester failed		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 05.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Thirumalapur	Dondlapally	11KV	Jadcherla	08.47	10.58	02.11		11KV Jumper cut near Chukkampet	-
2		Marrikal	Malkapur	11KV	Jadcherla	02.00	11.00	09.00		11KV Wire cut near Malkapur	-
3		Mirzapur	Bijaram	11KV	Narayanapet	03.36	06.30	02.54		Jumper Cut at DTR	-
4		Kosgi	Sampally	11KV	Narayanapet	12.12	13.00	00.48		Jumper Cut at DTR	-
5		Maddur	Renivatla	11KV	Narayanapet	18.40	19.54	01.14		11KV Insulator Failed	-
6		Nancherla	Nancherla	11KV	Narayanapet	09.07	11.03	01.56		11KV Insulator damage	-
7		Nancherla	Juvulapally	11KV	Narayanapet	09.15	11.48	02.33		11V Jumper Cut & 11KV Insulator Damaged	-
1	NLG	Penpahad	Ananaam	11KV	Suryapet	02.40	06.30	03.50	E/L	11Kv Conductor snapped	-
2		Palakeedu	Sajjapuram	11KV	Huzurnagar	04.00	07.15	03.15	E/L	11Kv Conductor snapped	-
3		Gundala	Gangapur	11KV	Bhongir	02.15	09.25	07.10	E/L	11Kv Insulator failed near Marrispadaga (V) 3Phase supply ok	-
1	RR S	Gachibowli	Nallagandla	11KV	Gachibowli	12.40	15.10	02.30		11kv Cable failed at opposite DE Line office(Backfeeding from 11kv sudharshan Naga feeder)	-
1	RR N	UMCC	Mahadevpuram	11KV	Medchal	03.35	05.10	01.35		11KV AB Cable Failed at Gajularamaram(Backfeeding arranged from 11KV Gajularamaram and 11KV Crusher feeder)	-
2		Chintal	Chintal	11KV	Medchal	09.20	10.30	01.10		Tree fallen on the 11KV Line at Saibaba Temple	-
3		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	02.35	03.30	00.55		11KV Line AB Switch Opened at Sun Flower School(HT Services CTPT Failed)	-
4		Devarayamjal	Pothaipally	11KV	Medchal	06.50	09.25	02.35		11KV Cable failed at NTR Statue, Devarayamjal Village	-
5		Kistapur	IDA Hanuman	11KV	Medchal	15.30	18.00	02.30		11KV Pin Insulator failed at Singani Foods	-
1	RR E	Moula-Ali	Malkajgiri	11KV	Sainikpuri	15.14	16.24	01.10		Pin Insulator failed at RTC Colony 2nd Bus Stop (L.Insp Venkateshwarulu)	-
2		Uppal Kalsa	Sri Sri Nagar	11KV	Habsiguda	04.16	05.15	00.59		100KVA T/F Failed at Swaroop Nagar & 11KV Line AB Switch opened	-
3		Uppal	Chilkanagar	11KV	Habsiguda	15.45	16.45	01.00		Tree branches on 11kv line at Adarsh nagar	-
4		P&T colony	Buddanagar	11KV	Keesara	15.10	16.10	01.00		Insulator fail at 4S residency Budda nagar	-
1	HYD N	Marredpally	Lalitha Nagar	11KV	C-VI	09.40	11.07	01.27	EL,OL-Bph	No Visible Fault	Partial fdr added on 11KV Laxmi Nagar fdr & remaining loads on 11KV Apollo fdr
2		Chilkaalguda	P.R.Nagar	11KV	V	15.15	16.20	01.05	EL	Tree branches fallen on lines at Water Works	----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Moosarambagh	Sripuram Colony	11KV	VIII	02.55	04.18	01.23	A/R tripped	Tree branches fallen on lines at Sai Enclave Apts	Arranged B/F on 11KV Moosaram Bagh fdr
2		Seetharam Bagh	Dhoolpet OH	11KV	IX	15.10	16.20	01.10	EL,OL	Cable Jumper B/O at R.K.Pet	-----
1	HYD C	Amberpet	Che Number	11KV	II	14.54	16.10	01.16	EL,OL-Bph	Tree branches fallen on lines at Che Number X Road	-
2		Golconda	Aditya Nagar OH	11KV	VII	14.50	16.20	01.30	All Indication	Tree branches fallen on lines at Surya Nagar Colony	-
3		Golconda	Shaikpet W.W	11KV	VII	15.05	16.20	01.15	EL,OL-Rph	HT Jumper cut at Jaihind Nagar	-
4		Bathakamma Kunta	C.E.Colony	11KV	II	15.04	16.36	01.32	EL,OL-Rph	Pin Insulator flash over at Ayyappa Temple	-
5		Zamistanpur	Dayar Market	11KV	II	15.42	17.35	01.53	EL,OL	Tree branches fallen on lines at Westly Church	-
6		Chilkaiguda	Golconda X Roads	11KV	II	15.12	17.40	02.28	OL-Rph	Brass Patti cut at Nandu Chicken	-