

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		0		0		0			
8	Hyd	194	1044		10		10		10			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>15</b>	<b>0</b>	<b>15</b>	<b>0</b>	<b>15</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933		4		4		4			
4	SDPT				16		16		16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>25</b>	<b>1</b>	<b>25</b>	<b>1</b>	<b>25</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>40</b>	<b>1</b>	<b>40</b>	<b>1</b>	<b>40</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 09.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Rajapur	33KV	Jadcherla	18.30	19.10	00.40	E/L&O/L	Pin Insulator Failed Near Surya Jyothi Industry		NO

## Circle-wise 11KV Breakdowns

Date: 09.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bibigudem	Bibigudem	11KV	Suryapet	07.20	08.30	01.10	E/L	Bird fallen on the line	-
2		Pedaveedu	Krishnathanda	11KV	Huzurnagar	11.30	12.30	01.00	EL	11 KV JUMPER CUT	-
3		Palem	Ogodu	11KV	Nalgonda	11.00	14.00	03.00	EL	11 KV JUMPER CUT	-
4		Nidamanur	Shakapuram	11KV	Miryalaguda	07.20	08.35	01.15	EL	11 KV JUMPER CUT	-
5		Bibinagar	Town	11KV	Bhongir	16.01	16.45	00.44	EL/OL	11kv Insulator Failed near Railway Station Bibinagar	-
1	MDK	Sangareddy Rural	P.R. Pally	11KV	Sangareddy	18.40	20.58	02.18		B/D due to Insulator failure	-
2		Patancheru Town	Industrial	11KV	Patancheru	16.35	17.40	01.05		B/D due to Tree branches fallen on the line	-
3		Patancheru Town	Town	11KV	Patancheru	19.07	20.15	01.08		B/D due to Disk failure	-
4		Patancheru Town	MIA-II	11KV	Patancheru	18.55	21.15	02.20		B/D due to Insulator failure	-
1	SDPT	Chinthamadaka	Machapur	11KV	Siddipet	02.40	06.30	03.50		B/D (HAVE WIND )	-
2		Vittalapur	Vittalapur	11KV	Siddipet	17.45	19.10	01.25		B/D (HAVE WIND )	-
3		Boppapur	Akaram	11KV	Siddipet	18.05	Still continue			B/D (HAVE WIND & HAVE RAIN)	-
4		MARKOOK	MORKOOK Town	11KV	Gajwel	11:10	11:57	0:47		11KVA CABLE WIRE BORN & CUT	-
5		VARDHARAJPUR	VARDHARAJPUR	11KV	Gajwel	02:00	07:57	5:57		11KVA LINE TREE TOUCHING	-
6		NACHARAM	ANYHAGIRIPLLY	11KV	Gajwel	17:05	18:35	1:30		25KVA 1Ph DTR PROBLEM	-
7		NACHARAM	NACHARAM AGL	11KV	Gajwel	17:23	till			BREAKDOWN	-
8		GOWRARAM	GOWRARAM Town 1	11KV	Gajwel	21:00	till			11KVA LINE CUT (BREAKDOWN)	-
9		KOKKONDA	SINGANNAGUDA	11KV	Gajwel	13:30	15:00	1:30		11KVA LINE CUT	-
10		THUUKKAPUR	THUUKKAPUR AGL	11KV	Gajwel	20.30	21.10	00.40		11KVA LINE CUT & JUMPER OUT	-
11		KONDAPAKA	KONDAPAKA AGL	11KV	Gajwel	09:35	10:25	0:50		11KVA JUMPER CUT	-
12		GODUGUPALLY	GODUGUPALLY	11KV	Gajwel	18.22	till			3-Ph Breakdown (1-Ph Running)	-
13		MD SHAPUR	MD SHAPUR	11KV	Gajwel	18:00	till			3-Ph Breakdown (1-Ph Running)	-
14		MD SHAPUR	THANDA FEEDER	11KV	Gajwel	19:20	05.30 (10.08.20)	10.10		3-Ph Breakdown (1-Ph Running)	-
15		Cherial Town	Cherial-Town	11KV	Husnabad	12.00	08.38	11.02		B.D DUE TO LINE CUT	-
16		Thotapally	Devakkapally	11KV	Husnabad	07.12	04.48	12.00		B.D DUE TO LINE CUT BY HEAVY WIND	-
1	RR S	Madinaguda	Allwyn Colony	11KV	Gachibowli	16.19	18.05	01.46		Pin Insulator failed at Sapthagiri colony	-
1	RR N	Chandanagar	Sri Ram nagar	11KV	Kukatpally	16.15	17.15	01.00		Due To heavy Rain	-
2		Medchal	CMR	11KV	Medchal	16.40	17.20	00.40		Tree Fallen on 11KV Line at Suthariguda	-
3		Kandlakoya	KV Reddy Nagar	11KV	Medchal	18.40	19.55	01.15		Tree Fallen on 11KV Line at KV Reddy Nagar	-
4		Aliabad	Majeedpur	11KV	Medchal	18.10	19.40	01.30		Tree Fallen on 11KV Line at Ramalayam Temple	-
1	HYD N	Vasanthapuri	Siripuri	NT	V	02.19	04.10	01.51	EL,OL	No Visible Fault	Arranged B/F on 11KV Lalapet fdr
2		Addagutta	Shanthi Nikethan	NT	C-VI	06.26	07.40	01.14	EL	No Visible Fault	07:20 Hrs Partial loads added on 11KV Ravi Colony fdr & Remaining loads added on 11KV Tukaram Gate feeder
3		Macha Bollaram	Father Balaiah Nagar	NT	C-VI	18.25	20.02	01.37	EL	Kite Sticks on 1st Line AB Switch at Father Balaiah Nagar	-----
4		Film Nagar	Padmalaya Studio	NT	X	17.05	18.45	01.40	EL	Tree branches fallen on lines at P.Gopala Krishna's House	At 17:40Hrs partial fdr charged
5		Marredpally	Jyothi Colony	NT	C-VI	18.00	19.55	01.55	EL,OL-Yph	Cable Insulator flash over at Jyothi Colony	Arranged B/F on 11KV R.K.Puram fdr
6		R.P.Nilayam	Naga Devatha	NT	C-VI	18.35	19.58	01.23	EL	RMU Cable fault at Nagadevath Temple	Arranged B/F on 11KV R.K.Puram fdr
7		New Bowenpally	Raju Colony	NT	VI	22.10	00.05	01.55	EL,OL	Disc flash over at Vinayaka Nagar	-----
1	HYD S	Kanchanbagh	I.S.Sadan	ST	VIII	17.55	19.02	01.07	EL	Pin Insulator flash over Opp. SBI	-
1	HYD C	S.D.Hospital	Ahmed Nagar OH	CEN	VII	17.27	18.44	01.17	EL,OL-Bph	Jumper cut at Pochamma Temple	-
2		Langer House	Pensionpura	CEN	VII	22.35	23.37	01.02	EL	Cable fault at New Construction Apts, Pensionpura	-