

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		6		6		6			
	Total	606	3055	1	11	1	11	1	11	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	6	1	6	1	6			
2	NLG	144	988		18		18		18			
3	MDK	107	933	2	4	2	4	2	4			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	28	3	28	3	28	0	0	
	Grand Total	1082	6468	4	39	4	39	4	39	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Revally	33KV	Wanaparthi	20.30	21.15	00.45	OL	Not Rectified	Revally	Alternate Supply Arranged from 33KV Peddakothapally at 21:15Hrs
1	MDK	Pashamailaram	SOL	33KV	Patancheru	14.40	18.50	04.10		BD due to Cable kit failed	SOL	-
2		Narayankhed	Kalher	33KV	Jogipet	16.50	20.08	03.18		BD due to Cable kit failed	Kalher	-
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	03.52	08.14	04.22	EL	33KV Line Isolator Opened at Mansanto Company (Back feeding arranged from 33KV Ratnalayam Feeder)	33KV LGM Pet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 10.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Parpally	Achryapur	11KV	Mahabubnagar	13.30	15.15	01.45		11KV HT/LT at Gandhinagar	-
2		Karkonda	Fathepur	11KV	Jadcherla	10.52	12.35	01.43		11 KV Disc Failed Near Fathepur (V)	-
3		Nawabpet	Rudraram	11KV	Jadcherla	06.00	09.58	03.58		11 KV Disc Failed Near Rudraram(V)	-
4		Gundumal	Appaipally	11KV	Narayanapet	09.32	09.50	00.18		Tree Branch Fallen on 11KV Line	-
5		Gundumal	Appaipally	11KV	Narayanapet	13.00	15.00	02.00		Tree Branch Fallen on 11KV Line	-
6		Narayanpet Town	Civil Feeder	11KV	Narayanapet	21.30	22.30	01.00		11KV Disc Failed	-
1	NLG	Pole Center	Nalgonda T	11KV	Nalgonda	07.15	08.45	01.30	EL	11KV Disc Failur	-
2		Pole Center	Nalgonda T	11KV	Nalgonda	10.55	14.55	04.00	EL	6 Nos 11KV Disc Failur	-
3		Thimmannagudem	N,S.puram	11KV	Nalgonda	12.46	14.35	01.49	EL	Movement Fult	-
4		Thurkapally	M.Gouraram	11KV	Nalgonda	08.10	10.30	02.20	EL	11KV Line Cut	-
5		panagal	Panagal T	11KV	Nalgonda	04.35	05.55	01.20	EL	AB Switch open	-
6		Palem	Ogodu	11KV	Nalgonda	05.30	09.40	04.10	EL	Tree Branches On The Line	-
7		Kattangur	Bollepally	11KV	Nalgonda	05.30	06.30	01.00	EL	Movement Fult	-
8		Kattangur	Dudunelvely	11KV	Nalgonda	11.50	14.10	02.20	EL	HT/LT Melting	-
9		Yacharam	Marepally	11KV	Miryalaguda	08.05	12.23	04.18	EL	Line Snapped	-
10		Thummadam	Thummadam	11KV	Miryalaguda	08.00	10.30	02.30	EL	Jumper Cut	-
11		Peddavoor	Ramannagudem	11KV	Miryalaguda	20.30	07.50	11.20	EL	Insulator Failed	-
12		Jalalpuram	Jalalpuram	11KV	Suryapet	03.00	05.30	02.30	E/L	Tree Branch Fallen	-
13		Dirsenapally	Errapahad	11KV	Suryapet	03.50	07.00	03.10	E/L	Conductor Snapped	-
14		Dirsincherla	Dirsincherla	11KV	Huzurnagar	03.00	06.45	03.45	EL	11 KV LINE SNAPPED Line Snapped	-
15		Keethavarigudem	K K Thanda	11KV	Huzurnagar	05.00	07.15	02.15	EL	11 KV JUMPER CUT	-
16		MT.Pally	MT.Pally Agl	11KV	Bhongiri	04.00	10.00	06.00	EL/OL	11kv Insulator Failed near SS-10	-
17		Solipet	Ramulthanda	11KV	Bhongiri	03.45	10.15	06.30	EL/OL	11kv Insulator Failed near Ramulthanda	-
18		Malkapur	Malkapur Agl	11KV	Choutuppal	03.30	09.30	06.00	EL/OL	11kv Line Snapped near Malkapur Village	-
1	MDK	Pati	Shalimar	11KV	Patancheru	02.40	09.05	06.25		BD due to Disk failed	-
2		Bonthapally	Jaishenkar	11KV	Patancheru	06.20	11.00	04.40		BD due to Conductor snapped	-
3		Bonthapally	Newland	11KV	Patancheru	16.00	18.12	02.12		BD due to Insulator failed	-
4		Gundla Machnoor	Industrial	11KV	Jogipet	00.00	11.35	11.35		BD due to Tree fallen on the line	-
1	RR N	Vikas	Vikas	11KV	Kukatpally	13.00	14.00	01.00	EL	Through line 11kv AB Cable Dismetal at Raju house	-
2		Jeedimetla SS II	Phase III	11KV	Jeedimetla	00.45	01.45	01.00	EL	11KV Jumper cut & touch the channal at Phase III	-

1	RR E	Anand Bagh	Chandragiri Colony	11KV	Sainikpuri	03.38	06.45	03.07		11Kv Pin Insulator failed at Jain Mandir Chandragiri Colony (L.Insp Venu Gopal)	-
2		RGK	Bharatha Rathna	11KV	Keesara	08.21	11.43	03.22		11KV Disc failed at Indiramma Colony	-
3		Narapally	Prathap Singaram	11KV	Keesara	05.35	06.35	01.00		11KV Disc failed near SS Yard	-
1	HYD N	Bhudevi Nagar	Gollaguda	11KV	C-VI	07.37	08.40	01.03	EL,OL	Disc Insulator flash over at Brindavan Colony	At 08:05 Hrs Partial feeder charged
2		MLA Colony	Shopping Complex	11KV	X	15.08	16.23	01.15	AR tripped	Tree branches fallen on lines after Auto Recloser	-----
3		Gymkhana	Apollo	11KV	C-VI	20.25	22.20	01.55	All Indication	Cover Conductor snapped near Apollo	(No supply to partial 11KV Lalitha Nagar feeder)
1	HYD S	Chanchalguda	Chowni	11KV	VIII	04.45	06.25	01.40	OL-Rph	Cable fault	Arranged B/F on 11KV Kurmaguda fdr & 11KV Waheed Nagar feeder
1	HYD C	Mothi Mahal	Heera Khana	11KV	VII	06.00	07.13	01.13	EL,OL-Yph	Pin Insulator flash over at Heera Khana	-
2		Hussain Sagar	Fathe Maidan	11KV	I	12.30	13.56	01.26	EL	3Way RMU Wiper B/o at L.B Stadium	-