

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	3	1	3	1	3	1			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	3	5	3	5	3	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				13		13		13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	16	0	16	0	16	0	0	
	Grand Total	1082	6468	3	21	3	21	3	21	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	13.52	15.05	01.13	BD	Bird fallen on the 33KV Line at LGM Pet Village		-
2		132KV LGM Pet	33KV Aliabad	33KV	Medchal	14.36	15.58	01.22	BD	Tree fallen on the 22KV Line at Darga, LGM Pet Village		-
3		132KV LGM Pet	33KV LGM Pet	33KV	Medchal	04.02	06.06	02.04	BD	33KV Line AB Switch Opened at Shameerpet Bus Stop(IP College No Supply)		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 11.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mallaboinpally	Mallaboinpally	11KV	Jadcherla	00.00	11.10	11.10		11KV Disc Failed Near Mallaboinpally	-
1	NLG	Dirsenapally	Miryala	11KV	Suryapet	07.20	09.30	02.10	E/L	Insulator flashover	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	01.00	07.50	06.50	E/L	Tree Branch Fallen on the Line	-
1	SDPT	Komuravelli	Inapur AGL	11KV	Husnabad	15.40	18.45	03.05		Insulator failed	-
2		Husnabad	Town 1	11KV	Husnabad	16.30	17.10	00.40		EL Insulator failed	-
3		Chowdaram	Yellamajaju	11KV	Siddipet	09.30	12.23	02.53		B/D - Baras Faitti fail	-
4		Thimmapur	Padnadmpally	11KV	Siddipet	08.56	09.05	00.09		B/D - Disk Fail	-
5		Jangapally	Jangapally,Verared dypally	11KV	Siddipet	01.00	07.00	06.00		B/D Insulator Fail	
6		DOULTHABAD	MD SHAPUR	11KV	Gajwel	15:20	18:00	02.40		11 KVA JUMPER CUT	
7		THOGUTA	METTU	11KV	Gajwel	03.00	06.00	03.00		11 KVA INSULATOR FAILED	
8		MARKOOK	MATKOOK	11KV	Gajwel	17.15	20.10	02.55		INSULATOR FAILED 3Ph Breakdown, 1Ph Running	
9		MARKOOK	KARKAPATLA	11KV	Gajwel	07.50	15.30	07.40		GLOBIN COMPONY CT FAILED	
10		DUDEEDA	THIMMAREDDYPALLY	11KV	Gajwel	08.35	10.55	02.20		11 KVA DISK FAILED	-
11		DUDEEDA	BANDARAM	11KV	Gajwel	14.00	15.30	01.30		11 KVA DISK FAILED	-
12		DUDEEDA	MARPADGA	11KV	Gajwel	10.00	11.00	01.00		11 KVA DISK FAILED	-
13		DUDEEDA	MARPADGA	11KV	Gajwel	16.00	16.30	00.30		11 KVA DISK FAILED	-
1	RR N	Medchal	IDA-I	11KV	Medchal	09.45	10.55	01.10	BD	11KV Jumper Cut & replaced at near REVL Comapnay Backside	-
1	HYD N	Gymkhana	Vikrampuri	11KV	Bowenpally	09.08	10.22	01.14	A/R Tripped	No Visible Fault	-
2		Gymkhana	Pared Ground	11KV	Bowenpally	12.10	13.25	01.15	EL,OL-Bph	Jumper cut at Pump House	-
3		Chilkaiguda	Pragatools	11KV	Sec-Bad	18.15	19.50	01.35	EL,OL	I/C Cable fault near SS	Arranged B/F on 11KV Rajya Laxmi feeder
1	HYD C	Amberpet	6 Number	11KV	Saifabad	01.13	02.26	01.13	EL,OL-Yph	Cable fault & Addition loads of 11KV Tulasi Nagar feeder	Arranged B/F on 11KV Golnaka fdr