

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	3	2	3	2	3			
2	NLG	144	988		12		12		12			
3	MDK	107	933		1		1		1			
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	25	2	25	2	25	0	0	
	Grand Total	1082	6468	2	29	2	29	2	29	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Jadcherla	Balanagar	33KV	Thomidirekula	00.10	10.25	10.15	E/L & O/L	for Pole Replacement at Burdanpet Village	Balanagar	-
2		Nagarkurnool	Kalwakurthy	33KV	Rachoor	01.02	12.08	11.06	E/L & O/L	Tripped on E/L&O/L Due to Rain & AB Switch Open at Petrol Pump at Kalwakurthy & Pin Insulator Replacement at Kalwakurthy Town	Kalwakurthy	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 12.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Kondapur	11KV	Jadcherla	05.45	10.05	04.20		11Kv Jumper Cut Near Nawabpet(Vi) Back Side.	-
2		Nancherla	Komreddypally	11KV	Narayanapet	14.10	16.50	02.40		Due to Tree fallen down & DTR failed	-
3		Bijwar	Magdampur	11KV	Narayanapet	12.20	14.16	01.56		Due to 11KV Disc Failure	-
1	NLG	T.V.Gudem	Damarcharla	11KV	Miryalaguda	05.10	06.30	01.20	EL	11KV Jumper Cut	-
2		Wadapally	Damarcharla	11KV	Miryalaguda	02.15	05.00	02.45	EL	11KV Disc Failed	-
3		Damarcharla	Damarcharla	11KV	Miryalaguda	04.40	06.20	01.40	EL	11KV Conductor Snapped	-
4		K.N.Konda	Damarcharla	11KV	Miryalaguda	05.50	07.15	01.25	EL	11KV Jumper Cut	-
5		Kondrapole	Damarcharla	11KV	Miryalaguda	06.30	07.55	01.25	EL	Tree Fallen on 11KV Line	-
6		Teeded	Varakala	11KV	Devarakonda	14.25	15.10	00.45	EL	11kv Jumper Cut	-
7		Azmapuram	Azmapuram	11KV	Devarakonda	10.15	10.55	00.40	EL	11kv Insulator Faild	-
8		S.V.College	Loyala Agl	11KV	Suryapet	07.00	09.40	02.40	E/L	Bird Fault	-
9		D.Nagaram	Machireddypally	11KV	Suryapet	12.00	15.00	03.00	E/L	Insulator Failed	-
10		Janpahad	Janpahad	11KV	Huzurnagar	07.00	09.20	02.20	EL	11 KV Line Snapped	-
11		Akupamula	Singaram	11KV	Huzurnagar	09.30	11.15	01.45	EL	11 KV Jumper Cut	-
12		Paladugu	Panakabanda	11KV	Bhongiri	04.00	09.30	05.30	EL/OL	11kv Line Snapped & 11kv Insulator Failed Mushipatla Village.	-
1	MDK	Patancheru Town	MIA-II	11KV	Patancheru	07.50	10.05	02.15		B/D Due to Jumper Cut	-
1	SDP	Mirdoddi	Andhey	11KV	Siddipet	17.50	05.30	11.40		Heavy Rain	-
2		Mirdoddi	Kasulabad	11KV	Siddipet	18.05	06.15	12.10		Heavy Rain	-
3		Nangnoor	Akkenapally	11KV	Siddipet	11.25	14.00	02.35		B/D 11 KV Line cut LC No.3095	-
4		DAMAREDDYPALLY	GIRIPALLY	11KV	Gajwel	08.34	13.50	05.16		11KVA LINE CUT	-
5		AHMEEDPUR	GILALPUR	11KV	Gajwel	11.20	11.40	00.20		JUMPER CUT	-
6		RAIPOLE	THIMMAKKAPALLY	11KV	Gajwel	13:00	15:00	2:00		DTR COOPER PATTI CUT	-
7		RAMSAGAR	ANKHIREDDYPALLY	11KV	Gajwel	05.00	09.30	04.30		BREAKDOWN INSULATOR FAILED	-
8		Ramchandrapur	Vinjabally	11KV	Husnabad	16.00	18.30	02.30		Heavy gale and wind	-
9		Bekkal	Bairanpally	11KV	Husnabad	07.30	09.00	01.30		Disk failure	-
1	HYD N	Hakimpet	Bollarum PS	11KV	C-VI	21.40	22.58	01.18	EL	Tree branches fallen on lines at Adarsh Nagar	-
1	HYD C	Nampally	Pearl Regency	11KV	VII	22.29	23.35	01.06	EL,OL	AB Switch fault at Nilofur Hospital	-
2		Golconda	Darga Cable	11KV	VII	21.45	23.29	01.44	EL	AB Cable fault at Enalabasti	-
3		Asif Nagar	N.S F Colony	11KV	VII	22.40	00.27	01.47	EL	AB Cable fault at Virasath Nagar & Lighting Arrestor failed at Balreddy PT	-