

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		11		11		11			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		17		17		17			
	Total	606	3055	0	34	0	34	0	34	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		9		9		9			
3	MDK	107	933	2	5	2	5	2	5			
4	SDPT				28		28		28			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	44	2	44	2	44	0	0	
	Grand Total	1082	6468	2	78	2	78	2	78	0	0	

0 +

Date: 13.08.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Sadasivpet	Munipally	33KV	Sangareddy	16:35	18:55	2:20		Tree branches fallen on the line	Munipally	No
2		Narayankhed	Kalher	33KV	Jogipet	02.40	06.05	03.25		Insulator failed	Kalher	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Hanumanpally	11KV	Narayanapet	05.10	08.50	03.40		Tree fallen on the line	No
2		Bijwar	Magdumpur	11KV	Narayanapet	08.45	09.51	01.06		11KV Disc failure	No
1	NLG	Eduloor	Parada	11KV	Nalgonda	16:00	17:30	1:30	E/L	11Kv Line Jumper Cut	No
2		Thurkapally	M.Gowraram	11KV	Nalgonda	14.54	17.30	02.36	E/L	11Kv Line Jumper Cut	No
3		Annaram	Sangem	11KV	Suryapet	09.00	12.00	03.00	E/L	11Kv Insulator failed	No
4		Kudakuda	Komatikunta	11KV	Suryapet	05.00	07.35	02.35	E/L	11Kv Jumper cut	No
5		Mukundapuram	Smoaram	11KV	Huzurnagar	03.30	06.45	03.15	E/L	11Kv Line Snapped	No
6		Munagala	Barakathgudem	11KV	Huzurnagar	05.00	07.45	02.45	E/L	11Kv Line Jumper Cut	No
7		MT.Pally	Mulkalapally	11KV	Bhongir	02.00	06.00	04.00	EL/OL	11kv Insultor Failed near Sangathanda (V)	No
8		Addagudur	Ch.Ramaram	11KV	Bhongir	08.30	11.40	03.10	EL/OL	2no's 11kv Insulator Failed near Ch Ramaram (V)	No
9		Choutuppal	Thanhdapally	11KV	Choutuppal	13.10	13.45	00.35	EL/OL	11KV Line Phase to Phase Choutuppal Town	No
1	MDK	Sadasivpet	TSM	11KV	Sangareddy	18:00	20:40	2:40		Insulator failed	No
2		Cheryal	MYK Laticrete	11KV	Sangareddy	17.33	19.50	02.17		Jumper cut	No
3		Patancheru Town	MIA-II	11KV	Patancheru	17.20	19.05	01.45		Conductor snapped	No
4		Bollaram - II	Vipla	11KV	Patancheru	08.20	11.02	02.42		11KV Conductor snapped	No
5		Patancheru Town	Shanthinagar	11KV	Patancheru	19:50	20:50	1:00		Tree fallen on the line	No
1	SDPT	Mustabad X Road	Ragavendra Nagar	11KV	Siddipet	13:30	15:10	1:40		B/D Tree Branches Fall in Line	No
2		Gurralagundi	Malyala	11KV	Siddipet	6:00	12:50	6:50		B/D Insulater Problem Lcno.16624	No
3		Narayanaraopet	Beerapagudi	11KV	Siddipet	8:25	9:16	0:51		B/D Disk Fail Lcno.11526	No
4		Gonepally	Ramunipatla	11KV	Siddipet	6:15	14:18	8:03		B/D 11 KV Line cut LC No.20679	No
5		Ramancha	Gangapur	11KV	Siddipet	18:30	19:20	0:50		B/D Insulater Problem Lcno.30214	No
6		Chellapur	Rajakkapet	11KV	Siddipet	14:08	17:07	2:59		B/D Due to Bird Lcno.3078	No
7		Peddagundavelly	Peddagundavelly 1	11KV	Siddipet	0:00	7:00	7:00		B/D 11 KV Line cut LC No.0156	No
8		Peddagundavelly	Peddagundavelly 1	11KV	Siddipet	18:00	20:00	2:00		B/D Disk Fail Lcno.0157	No
9		Pedda Chikode	Chikode	11KV	Siddipet	16:57	17:45	0:48		B/D Tree branch fall in 11kv line Lcno.0639	No
10		JAGADEVPUR	INDUSTRIAL	11KV	Gajwel	17:20	19:00	1:40		BIRD TOUCHING IN JUMPER to KASARAM	No
11		JAGADEVPUR	ANTHAIGUDA	11KV	Gajwel	14:45	19:00	4:45		11KVA DISK FAILED	No
12		METTU	MASANPALLY	11KV	Gajwel	14:05	15:40	1:35		MONKEY PADINDI	No
13		THUHKAPUR	KANGAL	11KV	Gajwel	00:00	13:30	13:30		11KVA 3Nos DISK FAILED	No
14		RAMPUR	RAMPUR	11KV	Gajwel	07:15	8:40	1:25		11KVA JUMPER CUT	No
15		YELLAREDDYPET	YELLAREDDYPET & INDUSTRIAL	11KV	Gajwel	12:00	18:45	06:45		DISK FAILED IN THUHKAPUR S S	No
16		MARPADGA	MARPADGA AGL	11KV	Gajwel	1:00	6:00	05:00		BREAKDOWN (Rain falt)	No
17		THIPPARAM	ERRAVALLY AGL	11KV	Gajwel	19:40	5:30	9.50		Singel phase arranged	No
18		KONDAPAKA	KONDAPAKA AGL	11KV	Gajwel	15:10	18:50	2:05		INSULATOR FAILED	No
19		THIMMAREDDYPALLY	INDUTRIAL	11KV	Gajwel	23:00	13:45	14:45		DISK FAILED	No

20		GALWEL	MUTRAJPALLY	11KV	Gajwel	14:35	15:40	1:05		INSULATOR FAILED	No
21		GALWEL	BANGLA VENKATAPUR	11KV	Gajwel	17:20	18:10	0:50		11KVA DISK FAILED & 11KVA LINE CUT	No
22		AHMEEDPUR	AHMEEDPUR SS	11KV	Gajwel	13:58	14:13	0:15		33KVA INCOMMING OFF	No
23		PRAGNAPUR	INDUSTRIAL	11KV	Gajwel	19:03	19:51	0:48		E/L & O/L TRIPPING	No
24		Husnabad	Husnabad Town-2	11KV	Husnabad	14:00	14:30	0:30		Insulator failure, same rectified.	No
25		Pandilla	Potlapally	11KV	Husnabad	10:00	11:30	1:30		Jumper Cut	No
26		Thotapally	Devakkapally	11KV	Husnabad	12:05	12:35	0:30		Jumper Cut	No
27		Koheda	Theegalakuntapally	11KV	Husnabad	16:05	16:35	0:30		insulator failure, same rectified.	No
28		Akunoor	Akunoor Agl	11KV	Husnabad	21:00	7:30	10:30		insulator failure, same rectified.	No
1	RR N	Gagillapur	F-II	11KV	Jeedimetla	17:15	20:15	3:00	EL	11kv Pole Damedzed at Gagillapur	No
2		Dppally-II	Cable MLR	11KV	Jeedimetla	16.20	18.50	02.30	EL	Tree Fallen the 11kv line at Medchal Comman	No
3		UMCC	HAL Colony	11KV	Medchal	07.40	09.30	01.50	EL	11KV Pin Insulator failed at Indra Nagar	No
4		Dulapally	IDA-II	11KV	Medchal	01.59	03.17	01.18	EL/OL	11KV Pin Insulator failed at Srinidi Industry	No
5		Subhash Nagar	Gayatri Nagar	11KV	Medchal	16.43	17.35	00.52	EL/OL	25KVA T/F Post of Insulator failed at Manideep Apartment	No
6		Chintal	Surya Nagar	11KV	Medchal	17.00	18.05	01.05	EL/OL	11KV Post of Insulator failed at Balreddy Nagar	No
7		Subhash Nagar	Padma Nagar	11KV	Medchal	08.36	10.15	01.39	EL/OL	11KV Pin Insulator failed at near Andhra Bank	No
8		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	10.40	11.55	01.15	EL/OL	Tree fallen on the 11KV Line at Saigeetha Ashramam	No
9		Athiwelly	IDA	11KV	Medchal	16.05	16.55	00.50	EL	Tree fallen on the 11KV Line at Sreerama Spinning Mill backside	No
10		Thurkapally	Thurkapally	11KV	Medchal	15.25	18.55	03.30	EL	11KV Disc failed and 11KV Line cut and replaced at Thurkapally Village	No
11		Kistapur	IDA Hanuman	11KV	Medchal	16:30	19:00	2:30	EL/OL	11KV Line cut and replaced at Rudrapratap Godown	No
1	RR E	IDAUppal	Metro	11KV	Habsiguda	13:05	14:00	0:55		Tree fallen on 11kv line at Renuka company	No
2		NGRI	Street no 8	11KV	Habsiguda	18.23	19.20	00.57		Insulaotr fail at Kalavathi Appt	No
3		Ramanthapur	Durdarshan	11KV	Habsiguda	21.20	22.23	01.03		Tree fallen on 11kv line at Homeopathy Hospatel	No
4		Cherlapally-I	EC Computer	11KV	Sainikpuri	08.10	10.00	01.50		Polymer Disk failed at Open Jail	No
5		Cherlapally-IV	BN Reddy Nagar	11KV	Sainikpuri	19.10	20.20	01.10		11Kv Insulator failed at BN Reddy Nagar	No
6		Narapally	Narapally Industrial	11KV	Keesara	14:54	15:44	0:50		Tree branches fallen on 11kv line at Vijaypuri colony	No
1	HYD N	Pragatools	Eshwar Vimal	11KV	VI	07.42	09.28	01.46	OL-Bph	Tree branches fallen on lines & Jumper cut at Plot No.112, Gandhi Nagar	No
2		Osm. University	Ladies Hostel	11KV	V	8:15	9:25	1:10	OL-Rph	AB Switch sparking at O.U.Campus	No
3		New Bowenpally	Reliance Villa	11KV	VI	14:40	16:10	1:30	EL,OL	Tree branches fallen on lines at Sancharapuri Colony	No
4		Nehru Nagar	Hari Hara Kala Bhavan	11KV	V	19:37	22:18	2:41	EL,OL-Bph	RMU fault at NTPC	Arranged B/F on 11KV Rly. Reservation fdr & 11KV Picket fdr
5		Srinagar Colony	Udyog Nagar	11KV	X	21:25	22:50	1:25	EL,OL-Bph	Tree branches fallen on lines at My Home Madhuban Apts	At 21:30Hrs partial fdr charged
6		Macha Bollaram	Father Balaiah Nagar	11KV	C-VI	21:51	22:52	1:01	EL	Pin Insulator flash over at Satya Complex (1No. DTR kept off)	Partial fdr charged & remaining loads added on 11KV Sai Reddy Nagar fdr
7		Marredpally	R.K.Puram	11KV	C-VI	21:35	23:20	1:45	EL	Tree branches fallen on 1st Line AB Swtich	Arranged B/F on 11KV A.O.C fdr
8		Gunrock	Tirumalagiri	11KV	C-VI	20:45	0:35	3:50		HT Line snapped at Chandragiri Colony & Faulty DTR at Tirumalagiri	Arranged B/F on 11KV Sri Nagar Colony fdr & 11KV Surya Enclave fdr

9		Nehru Nagar	Teachers Colony	11KV	C-VI	23:01	0:35	1:34	All Indication	No Visible Fault	Arranged B/F on 11KV Ramser Café feeder
1	HYD S	Falaknuma	Guntal Shah Darga	11KV	III	07.15	08.43	01.28	EL,OL	I/C Cable fault	Arranged B/Fon 11KV Vattepally fdr
2		Salarjung	Sadath Nagar	11KV	VIII	17:55	19:21	1:26	EL	Cable fault at Nala (2No. DTR's Kept Off)	Arranged B/Fon 11KV Murtuza Nagar feeder
3		C.R.P.F.	Keshavgiri	11KV	III	22:25	0:25	2:00	EL	Tree branches fallen on lines at 3Nos. Locations, Keshavgiri	No
1	HYD C	Asif Nagar	Padmanaba Nagar	11KV	VII	14.34	17.05	02.31	EL	Cable fault	Arranged B/F on 11KV Maruthi Nagar feeder
2		Lake View	Katriya Hotel	11KV	I	15.05	16.10	01.05	EL,OL	DTR fault at Katriya Hotel	No
3		Langerhouse	Maruthi Nagar	11KV	VII	20.20	21.48	01.28	EL	Tree branches fallen on lines at Maruthi Nagar	No
4		Karwan	Langerhouse Cable	11KV	VII	20:00	23:57	3:57	EL,OL-R&Yph	Cable fault	Partial fdr charged & remaining loads added on 11KV Defence Colony fdr
5		Lake View	Kapadiya Lane	11KV	I	23.06	01.28	02.22	EL	Interlink Cable fault at Chella Chamber (1No. DTR kept off)	No