

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		18		18		18			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>26</b>	<b>0</b>	<b>26</b>	<b>0</b>	<b>26</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	10	3	10	3	10			
2	NLG	144	988		9		9		9			
3	MDK	107	933		5		5		5			
4	SDPT			1	18	1	16	1	16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>4</b>	<b>42</b>	<b>4</b>	<b>40</b>	<b>4</b>	<b>40</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>4</b>	<b>68</b>	<b>4</b>	<b>66</b>	<b>4</b>	<b>66</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 14.08.2020

## Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanapet	14.45	20.15	05.30	E/L	for Line Petroling & Line Phase to Phase near 132KV Maddur SS Poles no 5&9 pole		No
2		Achampet	Amrabad	33KV	Nagarkurnool	20.55	07.00 (15.08.20)	10.05	E/L	33KV pole broken due to tree fallen on line at Mannanoor forest		No
3		Ghanapur	Lattupally	33KV	Wanaparthy	23.34	8.00 (15.08.20)	08.24	E/L	No visible fault		No
1	SDPT	Angadikistapur	Jagadevpur	33KV	Gajwel	02.08	09.10	06.02		Due to insulator failed		-

## Circle-wise 11KV Breakdowns

Date: 14.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Sampally	11KV	Narayanapet	13.17	15.28	02.11		Break Down Due to 11 KV Disk Problem	-
2		Vennached	Janampally	11KV	Narayanapet	16.05	17.08	01.03		Break Down Due to 11 KV Insulator Failed	-
3		Marikal	P.C Kunta	11KV	Narayanapet	09.00	11.00	02.00		11KV Disc , Insulators failed	-
4		Marikal	Gunmukla	11KV	Narayanapet	11.00	13.30	02.30		11KV Disc , Insulators failed	-
5		Marikal	Madwar	11KV	Narayanapet	08.00	11.00	03.00		11KV Disc , Insulators failed	-
6		Utkoor	Pagidimary	11KV	Narayanapet	11.30	14.00	02.30		Tree branch fallen on 11Kv line	-
7		Manthangoud	Manthangoud	11KV	Narayanapet	19.37	20.42	01.05		11KV Disc , Insulators failed	-
8		Manthangoud	Manthangoud	11KV	Narayanapet	22.25	22.52	00.27		due to Heavy gale and wind	-
9		Jaklair	Gudigandla	11KV	Narayanapet	14.40	16.20	01.40		11KV Disc , Insulators failed	-
10		Jaklair	Satya Sai	11KV	Narayanapet	17.53	18.40	00.47		11KV line cut	-
1	NLG	Thipparthi	Indloor	11KV	Nalgonda	15.15	16.45	01.30	E/L	Insulator Failed	-
2		Eduloor	Munukuntla	11KV	Nalgonda	14.00	15.15	01.15	E/L	11 KV Line Jumper Cut	-
3		Penpahad	Penpahad	11KV	Suryapet	05.30	09.00	03.30	E/L	Insulator failed	-
4		Thatipamul	Nandhapuram	11KV	Suryapet	12.15	14.10	01.55	E/L	Jumper cut	-
5		Gaddipally	Kutubshapuram	11KV	Huzurnagar	04.00	06.45	02.45	E/L	11 KV LINE SNAPPED	-
6		Siripuram	Vallapuram	11KV	Huzurnagar	08.05	09.40	01.35	E/L	11 KV LINE SNAPPED	-
7		MT.Pally	Vasalamarry	11KV	Bhongir	04.00	08.00	04.00	E/L	Post off - Insulator failed at SS-9 near Vasalamarry village	-
8		Peddakandukur	Masaipet	11KV	Bhongir	03.00	09.15	06.15	E/L	11 kv insulator failed near Masaipeta village.	-
9		Choutuppal	Thangedipally	11KV	Choutuppal	05.00	11.30	06.30	E/L	2no's 11kv Disc Failed near Thangdapally Village	-
1	MDK	Sangareddy Town-II	Balaji	11KV	Sangareddy	00.23	01.26	01.03		BD due to Conductor snapped	-
2		Gaddapotharam-I	Matrix	11KV	Patancheru	03.00	07.30	04.30		BD due to Tree branches fallen on line	-
3		Gaddapotharam-I	United	11KV	Patancheru	03.50	08.05	04.15		BD due to Conductor snapped	-
4		Gaddapotharam-I	Kajipally	11KV	Patancheru	04.00	09.05	05.05		BD due to Jumper cut	-
5		Patancheru Town	Town Indl.	11KV	Patancheru	11.20	12.00	00.40		BD due to Conductor snapped	-
1	SDPT	Mittapally	Yellupally	11KV	Siddipet	17.45	18.50	01.05		B/D 11Kv Disk Fail	-
2		Jakkapur	Shanigakuntla	11KV	Siddipet	10.24	14.46	04.22		11Kv Disk Fail	-
3		Gurralongondi	Gurralongondi	11KV	Siddipet	05.35	09.45	04.10		11Kv Jumpet Cut	-
4		Dharmajipet	Lachapet	11KV	Siddipet	01.00	12.00	11.00		B/D Tree fall	-
5		Mirdoddy	Kasulabad	11KV	Siddipet	15.20		Still		due to Heavy Rain water flood	-
6		Mirdoddy	Andhy	11KV	Siddipet	16.35		Still		due to Heavy Rain water flood	-
7		Husnabad-ii	Malapally	11KV	Husnabad	07.35	11.00	03.25		B/D(11KV LINE CUT)	-
8		Thoyapally	Thotapally Agl	11KV	Husnabad	07.05	09.55	02.50		B/D(TREE BRANCHES FALLEN ON THE LINR)	-
9		Thotapally	Mallampally	11KV	Husnabad	08.04	10.17	02.13		B/D(INSULATOR FAIL)	-
10		Thotapally	Mallampally	11KV	Husnabad	14.28	16.35	02.07		B/D(TREE BRANCHES FALLEN ON THE LINR)	-
11		Akunoor	Akunoor Agl	11KV	Husnabad	06.00	12.00	06.00		B/D(INSULATOR FAIL)	-
12		Marmamula	Marmamula	11KV	Husnabad	01.00	09.32	09.32		B/D(INSULATOR FAIL)	-
13		GOWRARAM	PATHOOR	11KV	Gajwel	17.00	18.30	01.30		THE TREE BROKE & FELL DOWN ON THE LINE	-
14		PRAGNAPUR	INDUSTRIAL	11KV	Gajwel	2:57	3:50	0:53		TRIPPING BY E/L	-
15			INDUSTRIAL	11KV	Gajwel	4:15	6:20	2:05		TRIPPING BY E/L & O/L	-
16		DAMARAKUNTA	DAMARAKUNTA	11KV	Gajwel	06:00	10:00	4:00		2Nos DISK FAILED	-
17		ERRAVALLY	11KVA LIFT IRIGATION & POLICE STATION	11KV	Gajwel	9:15	15:25	6:11		2Nos DISK FAILED	-
18		ERRAVALLY	ERRAVALLY Town	11KV	Gajwel	9:15	9:45	0:30		DISK FAILED	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Jeedimetla-III	Pipe line Road	11KV	Jeedimetla	12.05	13.55	01.50	BD	Tree Fallen the 11kv line at Subash nagar	-
2		Kistapur	IDA Hanuman	11KV	Medchal	00.10	01.25	01.15	BD	Tree fallen on the 11KV Line at near Ravlakole Common	-
3		ICICI	Bharath Bio Tech	11KV	Medchal	00.02	00.52	00.50	BD	HG fuses Cut and replaced at Unicon Company	-
4		Kandlakoya	Kandlakoya	11KV	Medchal	02.50	03.55	01.05	BD	Tree fallen on the 11KV Line at Pochamma Temple	-
1	RR E	Chakripuram	Ayyappa Colony	11KV	Keesara	00.45	02.15	01.30		11KV Pin Insulator failed at Ayyappa Colony	-
2		Aushapur	NFC Nagar	11KV	Keesara	01.20	04.00	02.40		11KV Disc failed at Maisamma Gutta & Tree branches fallen on 11kv line near Krishna Poultry Firm	-
3		Singapur	RGK	11KV	Keesara	05.35	08.20	02.45		11KV Disc failed at Maisamma Gutta	-
4		Aushapur	NFC Nagar	11KV	Keesara	19.40	20.50	01.10		11KV Disc failed at CHR Garden	-
1	HYD N	Kalyan Nagar	Vengal Rao Nagar	11KV	X	00.43	01.59	01.16	EL,OL-Rph	RMU fault at V.R.Nagar	Arranged B/F on 11KV A.G.Colony fdr
2		Hakimpet	Allenby Lines	11KV	C-VI	01.43	02.53	01.10	A/R tripped	No Visible Fault	-
3		Hakimpet	Allenby Lines	11KV	C-VI	04.45	06.25	01.40	EL	Pin Insulator flash over at Telephone Bhavan	-----
4		Yousufguda	Hylam Colony	11KV	X	05.05	06.55	01.50	EL	AB Cable fault	Arranged B/F on 11KV Venkatagiri fdr
5		Road No.12	N.B.T Nagar	11KV	X	05.58	07.32	01.34	EL	Pin Insulator flash over at NBT Nagar	-----
6		Marredpally	Military Hospital	11KV	C-VI	07.20	08.50	01.30	EL,OL-Bph	HT Line snapped at Dental Hospital	-----
7		Chilkaiguda	Rajya Laxmi Housing Society	11KV	V	08.40	10.10	01.30	EL,OL-Rph	Faulty loads of 11KV Pragatools fdr	-----
8		I.D.P.L	Shivalayam	11KV	VI	10.15	11.19	01.04	OL-Bph	No Visible Fault	Arranged B/F on 11KV SIFCO fdr
9		MLA Colony	Cine Ghar	11KV	X	23.45	02.10	02.25	EL,OL-Y&Bph	Pole damaged at Road No.12, near Jana Reddy's House	
10		H.A.L	Sri Rama	11KV	VI	11.13	12.52	01.39	EL	No Visible Fault	Arranged B/F on 11KV Indian Rubber fdr
1	HYD S	Gosha Mahal	Gyanbagh Colony	11KV	IX	23.40	01.15	01.35	EL,OL-Bph	Disc Insulator flash over at Gosha Mahal	-
2		Exhibiton	Seetharampet	11KV	IX	23.25	01.10	01.45	All Indication	UG Cable fault at Sevak Nagar	At 00:20Hrs partial fdr charged
1	HYD C	Lake View	Dilkusha	11KV	I	00.10	02.52	02.42	EL,OL	RMU problem at Villa Marry College	-
2		Jawahar Nagar	Anjaiah Bhavan	11KV	I	03.45	05.05	01.20	All Indication	No Visible Fault	-
3		Indira Park	Gagan Mahal	11KV	I	19.11	20.50	01.39	A/R tripped	Bat fallen on Sectionlizar at Gagan Mahal	Arranged B/F on 11KV Indian Express fdr
4		Hyderguda	Hyderguda	11KV	I	22.15	23.23	01.08	OL-Rph	Cat fallen on DTR at Hyderguda	-----
5		Jawahar Nagar	Anjaiah Bhavan	11KV	I	23.55	01.06	01.11	All Indication	Tree branches fallen on lines at Hanuman Temple	-
6		Mothi Mahal	M.D.Lines	11KV	VII	23.56	03.35	03.39	EL	No Visible Fault	At 01:10Hrs partial fdr charged