

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		10		10		10			
6	RR(N)	54	550		16		16		16			
7	RR(E)	168	403		14		14		14			
8	Hyd	194	1044		38		38		38			
	Total	606	3055	0	78	0	78	0	78	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988	1	12	1	12	1	12			
3	MDK	107	933	2	1	2	1	2	1			
4	SDPT			2	26	2	26	2	26			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	41	7	41	7	41	0	0	
	Grand Total	1082	6468	7	119	7	119	7	119	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	Mitta Doddi	33KV	Gadwal	04.30	10.40	06.10	O/L	Tree cutting near Balgera	Mitta Doddi	-
2		Sri Rangapur	Chouder Gudem	33KV	Shadnagar	17.50	18.45	00.55	E/L	Tree Fallen on the Line	Chouder Gudem	-
1	NLG	Mattampally	Peddaveedu	33KV	Huzurnagar	12.30	16.15	03.45	EL	Insuletor Failed		-
1	MDK	Bollaram	Coca Cola	33KV	Patancheru	13.15	17.35	04.20		B/D Due to tree Branch fallen on the line		-
2		Narayankhed	Kalher	33KV	Jogipet	18.05	06.10	12.05		B/D Due to tree Branch fallen on the line & Insulator failed		-
1	SDP	Nangunoor	Baddipadaga	33KV	Siddipet	06.15	09.10	02.55		B/D Lighting Arrester fail	Baddipadaga	-
2		Mustyala	Komuravelly	33KV	Husnabad	01.15	10.40	09.25		B/D Jumper Snaped	Komuravelly	-

Circle-wise 11KV Breakdowns

Date: 15.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
1	MBNR	Vemula	Vemula	11KV	Jadcherla	03.05	06.50	03.45		11Kv Jumper Cut Near Vemula (Vi)	-	
2		Nawabpet	Rudraram	11KV	Jadcherla	07.50	12.45	04.55		11Kv Disc Failure Near Rukkampally (Vi)	-	
1	NLG	Koppolu	Bhemaram	11KV	Nalgonda	09.27	10.30	01.03	EL	Insuletor Failed	-	
2		Thurkapally	Thurkapally	11KV	Nalgonda	10.58	11.30	00.32	EL	Jumper Cut	-	
3		Palem	Palem	11KV	Nalgonda	15.20	16.45	01.25	EL	Insuletor Failed	-	
4		Bibigudem	Chivvema Agl	11KV	Suryapet	06.50	10.14	03.24	EL	Disk failed	-	
5		D Nagaram	D Kothapally	11KV	Suryapet	12.00	14.30	02.30	EL	Insulator flashover	-	
6		Raigir	Raigir AGL	11KV	Bhongir	02.50	08.00	05.10	EL	11KV Disc failed	-	
7		Nemaragommula	Jameelapet	11KV	Bhongir	13.50	14.52	01.02	EL	Insuletor Failed	-	
8		Addagudur	Addagudur	11KV	Bhongir	05.30	11.00	05.30	EL	Insuletor Failed	-	
9		Jublakpally	Jublakpally	11KV	Choutuppal	05.48	09.56	04.08	EL	11KV Disc failed	-	
10		Peddaravulapally	Indriyaia	11KV	Choutuppal	09.10	12.45	03.35	EL	11KV Disc failed	-	
11		Golanpally	Golanpally	11KV	Choutuppal	00.00	06.30	06.30	EL	Insuletor Failed	-	
12		Vemulakonda	Goparajupally	11KV	Choutuppal	05.30	08.20	02.50	EL	Insuletor Failed	-	
1	MDK	Dundigal	Jinnaram	11KV	Patancheru	00.00	05.00	05.00		B/D Due to Jumper Cut	-	
1	SDP	Anksapur	Nagarajpally	11KV	Siddipet	18.00	20.00	02.00		B/D Disk Fail	-	
2		Mittapally	Mittapally	11KV	Siddipet	00.00	07.00	07.00		B/D Tree Banches Fall in 11 KV line	-	
3		Thornala	Appanapally	11KV	Siddipet	06.42	11.20	04.38		B/D Tree Banches Fall in 11 KV line	-	
4		Gonepally	Gonepally	11KV	Siddipet	10.05	11.50	01.45		B/D Singal phase DTR problem Lcno.20689	-	
5		Chittapur	Chowderpally	11KV	Siddipet	06.10	10.20	04.10		B/D Disk Fail	-	
6		Chittapur	Mothey	11KV	Siddipet	07.50	08.15	00.25		B/D Disk Fail	-	
7		Mordoddy	Andhey	11KV	Siddipet	12.36	13.00	00.24		B/D Insulator Fail Lcno.24176	-	
8		Potharam	Potharam Rural	11KV	Husnabad	00.00	11.15	11.15		Pole damged, line snapped	-	
9		Thotapally	Mallampally	11KV	Husnabad	10.00	12.00	02.00		Tree branched fallen on line	-	
10		Thotapally	Industrial	11KV	Husnabad	09.30	16.30	07.00		Pole damage	-	
11		Shanigaram	Gundareddypally	11KV	Husnabad	04.40	16.40	12.00		Poles damage	-	
12		Marmamula	Marmamula	11KV	Husnabad	14.54	17.15	02.21		Insulator failure	-	
13		JAGADEVPUR	ALLIRAJAPETA AGL	11KV	Gajwel	23.40	11.55	12.15			11KVA CONDUCTOR STEENING	-
14		GOWRARAM	GOWRARAM Town-1 & PAMULAPARTHI	11KV	Gajwel	14.28	16.20	01.52			THE TREE BROKE & FELL DOWN ON THE LINE	-
15		PRAGNAPUR	INDUSTRIAL	11KV	Gajwel	14.24	18.57	04.33			PRASAD SEEDS JUMPER OPEN	-
16		PRAGNAPUR	GUNDANNAPALLY AGL	11KV	Gajwel	13.55	17.51	03.56			BREAKDOWN POLE DAMMAGE	-
17		PRAGNAPUR	PRAGNAPUR Town	11KV	Gajwel	17.21	17.52	00.31			SUPPLY CORESSING PURPOSE	-
18		DAMARAKUNTA	KASHIREDDYPALLY	11KV	Gajwel	13.00	14.50	01.50			11KVA INSULATOR FAILED	-
19		ERRAVALLY	11KVA LIFT IRIGATION & POLICE STATION	11KV	Gajwel	13.22	13.55	00.33			11KVA DISK FAILED	-
20		KARKAPATLA	GLOBIN INDUSTRIAL	11KV	Gajwel	04.10	09.12	05.02			Lighting Arestor failed & Pin Insulator failed	-
21		MULUGU	MULUGU AGL	11KV	Gajwel	19.05	06.00	10.55			No visible fault	-
22		THUNIKI BOLLARAM	NARSAPUR	11KV	Gajwel	20.00	07.20	11.20			Tree branches fallen on line	-
23		Gouravelly	Gubaddi	11KV	Husnabad	15.00	09.00	18.00			S-Ph OK, 3-Ph BD	-
24		Thotapally	Dacharam	11KV	Husnabad	09.05	11.00	01.55			Pole damged	-
25		Thotapally	Thotapally Rural	11KV	Husnabad	09.05	11.00	01.55			Pole damged	-
26		Gagillapur	Gagillapur Agl	11KV	Husnabad	19.00	08.30	13.30			Disc failed	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	L&T	PJR nagar	11KV	Gachibowli	00.24	03.26	03.02		Pole fallen on 25kv DTR at RTTC,Outer ring road	-
2		IIIT	JV Colony	11KV	Gachibowli	01.45	03.55	02.10		11kv Cable endkit failed at 7th Block, Kendriya vihar	-
3		Nanakramguda	Gowlidoddi	11KV	Gachibowli	04.46	06.25	01.39		11kv LABS Open at Naib (S V Krishna reddy line problem)	-
4		Nanakramguda	TNGO'S Colony	11KV	Gachibowli	04.49	08.00	03.11		11kv Pin Insulator failed at Alai balai chowrsta	-
5		ESCI	Nanakramguda	11KV	Gachibowli	05.55	07.45	01.50		11kv Ploe damage at Ratnadeep super market, Khajaguda	-
6		Madinaguda	Hafeezpet	11KV	Gachibowli	09.20	10.25	01.50		Tree Branchaces on 11KV line at Madinaguda	-
7		Gachibowli	Gopanpally	11KV	Gachibowli	07.30	08.30	01.50		11 KV Disk fail at Neetajinagar	-
8		Kothaguda	Raghavendra Colony	11KV	Kondapur	08.20	10.00	01.40		11 KV AB Cable fail at Raghavendra Colony	-
9		Kothaguda	SHL	11KV	Kondapur	08.30	10.00	01.30		HP CT PT HG Fuse file at SHL	-
10		Kothaguda	Anjaiah Nagar	11KV	Kondapur	08.30	09.50	01.20		11kv Pin Insulator failed at Anjaiah Nagar	-
1	RR N	Aleap	Madhuranagar	11KV	Kukatpally	08.25	09.40	01.15		11kv line LABS post Of Insulater failed at Manjeera Water pump,Pragathinagar	-
2		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	02.30	03.30	01.00		T/F HG Fuse failed at Phase-IV , {Due To Rain }	-
3		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	08.00	09.20	01.20		{Due To Rain }	-
4		Jeedimetla-II	Kompally Pharma	11KV	Jeedimetla	08.35	10.00	01.25		Tree branchesh Fallen the 11kv line at Phase-III	-
5		Dppally	Gagillapur	11KV	Jeedimetla	08.00	11.00	03.00		Tree branchesh Fallen the 11kv line at Gagillpur Nagaloor	-
6		Dppally	IDA	11KV	Jeedimetla	17.30	19.05	01.35		11kv line PinInsulater failed at Sanali Trackter Showroom,Narasapur Road	-
7		Subhash Nagar	Meenakshi	11KV	Medchal	06.30	07.30	01.00		11KV Pin Insulator failed at Srikara Apartment	-
8		Petbasheerabad	Balaji Hospital	11KV	Medchal	23.35	01.05	01.30		11KV Pin Insulator failed at Sri Avenue Apartments	-
9		Kompally	Aparna	11KV	Medchal	17.24	18.17	00.53		Line AB Switch opened Aparna farm house(Internal Problem)	-
10		HMT	Quthbullapur	11KV	Medchal	17.05	18.25	01.20		Tree Branches fallen on the 11KV Line at Municipal Office	-
11		Kandlakoya	KV Reddy Nagar	11KV	Medchal	08.40	09.50	01.10		Tree Branches fallen on the 11KV Line at Kandlakoya Main road	-
12		Devarayamjal	DMC	11KV	Medchal	03.30	08.50	05.20		11KV Pin Insulator failed at Ringroad	-
13		Thumkunta	Thumkunta	11KV	Medchal	10.20	11.45	01.25		11KV Disc failed at Ashramam, Thumkunta	-
14		Aliabad	HBL	11KV	Medchal	07.40	08.50	01.10		Tree Fallen on 11KV Line at Sangeeth Function Hall	-
15		Bandamadaram	Rock Sand	11KV	Medchal	11.20	12.15	00.55		11KV Jumper opened at Tails Company (1 No DTR off)(11KV Pole fallen)	-
16		Rajabollaram	Harshath Foultry	11KV	Medchal	15.10	18.00	02.50		Tree fallen on the 11KV Line at Rajabollaram thanda	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Uppal	Ghatkesar	11KV	Habsiguda	04.30	05.50	01.20		11KV Pole Damaged & removed at Kaveri Nagar	-
2		Uppal	Chilaka Nagar	11KV	Habsiguda	05.20	07.00	01.40		11KV Disc failed near Srinivasa Heights at Adarsha Nagar	-
3		St.No.08	Ravindra Nagar	11KV	Habsiguda	05.13	08.28	03.15		11KV Post of Insulator failed at Sneha Sumathi Apartment, 11KV Pin Insulator failed & HG Fuse Insulator failed at Ravindra Nagar Community Hall	-
4		St.No.08	Green Hills	11KV	Habsiguda	06.06	07.23	01.17		11KV Pin Insulator failed at Sri Chaithanya School & AB Switch opened at Sri Chaithanya School	-
5		Nacharam	Nagarjuna	11KV	Habsiguda	08.09	09.06	00.57		11KV Pin Insulator failed near Sifco Company & 11KV Incoming side Jumper cut at Sterling Shoes Company	-
6		NGRI	HMT Nagar	11KV	Habsiguda	05.11	07.52	02.41		Line Patrolling & 11KV Pin Insulator failed near SS Yard at Kalyanipuri Road & Back feeding supply taken from 11KV CCMB Feeder	-
7		Nacharam	Durga Nagar	11KV	Habsiguda	08.45	09.35	00.50		11KV Jumper cut at Deepak Galvanising Company & Tree fallen on 11KV Line near Road No.18 at IDA Nacharam	-
8		Mallapur	Noma	11KV	Habsiguda	07.20	08.10	00.50		11KV 2Nos Disc failed at Baba Nagar T/F & Temporary Back feeding from 11KV Surya Nagar feeder & Load normalised at 9:25	-
9		Mallapur	IDA	11KV	Habsiguda	08.35	09.10	00.35		11KV 3Nos HG Fuse failed Samporna Ice Company & Samporna Ice Compnay HT service AB Switch opened	-
10		Kushaiguda	Kushaiguda	11KV	Sainikpuri	00.40	02.25	01.45		11Kv AB Switch opened at Vasundhra College Due to DTR problem (AE)	-
11		Vasanthapuri	Raja Nagar	11KV	Sainikpuri	01.58	03.18	01.20		Pin Insulator failed at Indu Sagar Apt SS Back Sside (AE)	-
12		Sainikpuri	Saipuri	11KV	Sainikpuri	05.50	06.40	00.50		Tree branches fallen on 11Kv line at Hasthinapuri (AE)	-
13		Aushapur	Bokkenguda	11KV	Keesara	01.10	05.20	04.10		Pin insulator fail at Mother teresa collage	-
14		P&T colony	Medipally	11KV	Keesara	02.05	02.50	00.45		insulator fail at panchavathi colony	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Chilkaiguda	New Boiguda	11KV	V	00.05	02.00	01.55	EL,OL-Yph	HT Jumper cut at Opp: Gandhi Hospital	-----
2		Pragatools	L & T	11KV	VI	04.45	06.15	01.30	EL,OL-Rph	Tree branches fallen on lines	Arranged B/F on 11KV Indo Swing feeder
3		Tirumalagiri	Kiran Talkies	11KV	C-VI	05.05	06.45	01.40	EL,OL	No Visible Fault	-----
4		Pragatools	Asbestos Colony	11KV	VI	07.15	08.55	01.40	EL	Disc Insulator flash over at A.B Colony	-----
5		H.A.L	Lokesh Machine	11KV	VI	07.43	10.58	03.15	EL,OL-Rph	Tree branches fallen on lines at TIE Bala Nagar	-----
6		Road No.2	Shabdalya	11KV	X	08.12	09.15	01.03	EL	R.M.U Lugs cut at Road No.2	-----
7		Kalyan Nagar	A.G Colony	11KV	X	09.53	13.02	03.09	EL	Tree branches fallen on lines at Old Water Tank PT, Jumper cut at New Water Tank PT & Jumper cut on 1st Line AB Switch	-----
8		Ayyappa Society	Hitech Theater	11KV	X	10.40	12.00	01.20	EL	Sparking O/G AB Switch at SS	Arranged B/F on 11KV Image Garden fdr
9		New Bowenpally	Reliance Villa	11KV	VI	10.42	12.09	01.27	EL,OL	DTR fault at Bata Show Room	-----
10		Tirumalagiri	Kiran Talkies	11KV	C-VI	10.50	12.20	01.30	EL	Pin Insulator flash over at Alwal Janaki Nagar	(At 11:50 Hrs partial fdr charged)
11		Kalyan Nagar	Rehamath Nagar	11KV	X	11.46	13.08	01.22	EL	Sparking line AB Switch at Rehamath Nagar X-Roads	-----
12		Sanjeevaiah Park	Police Line	11KV	C-VI	13.45	15.10	01.25	All Indication	RMU Moisture at Polce Lines	Arranged B/F on 11KV My Fair Complex fdr
13		Sanjeevaiah Park	Police Line	11KV	C-VI	13.45	18.20	04.35	EL,OL-Y&Bph	CT/PT fault at Ever Ready Water Works	Added partial loads on 11KV My Fair Complex fdr
14		Zamistanpur	Sanjeevapuram	11KV	V	19.12	20.35	01.23	EL,OL-Rph	Disc Insulator flash over at S.R Hospital	-----
15		Yellareddyguda	Akbar Farm	11KV	X	18.18	21.45	03.27	EL	Pin Insulator flash over at Akber Farm	20:30 Hrs 70% feeder charged
16		Marredpally	A.O.C	11KV	C-VI	22.30	23.45	01.15	EL	Tree branches fallen on lines	-----
1	HYD S	Attapur	Kishanbagh UG	11KV	III	02.46	05.35	02.49	EL,OL-R&Bph	Disc Insulator flash & 2No. Pin Insulators over at Kishanbagh	-----
2		Malakpet B-Block	LIC Colony	11KV	VIII	05.14	07.14	02.00	OL-R&Yph	Cable fault (2No. DTR's Kept Off)	-----
3		E.N.T	Jambagh	11KV	IX	05.20	07.20	02.00	All Indication	-----	Arranged B/F on 11KV M.J Market fdr
4		Asmangadh	GA Bank Colony	11KV	VIII	05.40	07.55	02.15	EL	Disc Insulator flash over at Padmavathi Colony DTR	-----
5		Falaknuma	Chatrinaka	11KV	III	09.20	10.28	01.08	OL-Rph	Twisted HT lines at Gowlipura	-----
6		Falaknuma	Chatrinaka	11KV	III	13.40	15.05	01.25	EL,OL	2no's Jumper cut at SS & 3way RMU fault at Chatrinaka	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD C	A.S.R Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	00.03	06.22	06.19	EL,OL	Disc Insulator flash over at Chandana Apts	-----
2		Langer House	Nethaji Nagar	11KV	VII	00.20	01.57	01.37	EL,OL-Bph	Tree branches fallen on lines near Shivalayam Temple	-----
3		Asif Nagar	Jyothi Nagar	11KV	VII	01.55	02.57	01.02	All Indication	Faulty loads of 11KV M.D Lines fdr	-----
4		I.T.I Mallepally	Anjuman	11KV	VII	02.15	08.29	06.14	EL,OL	-----	Arranged B/F on 11KV Sri Ram Nagar fdr
5		Nampally	Bada Masjid	11KV	VII	05.11	06.27	01.16	EL	No Visible Fault	-----
6		Langer House	Nethaji Nagar	11KV	VII	05.31	07.55	02.24	All Indication	Tree branches fallen on lines at 7 Temple (2No. DTR's Kept Off)	-----
7		Nampally	Bada Masjid	11KV	VII	06.31	08.15	01.44	EL	AB Cable failed at Quli Qutub Shai Masjid (1No. DTR Kept Off)	-----
8		Vittalwadi	Gandhi Kuteer	11KV	II	07.45	08.50	01.05	EL,OL-Rph	No Visible Fault (4No. DTR's Kept Off)	-----
9		Asif Nagar	Military	11KV	VII	08.59	10.28	01.29	EL	Tree branches fallen on lines at Military Area	-----
10		Mothi Mahal	M.D Lines	11KV	VII	10.43	13.10	02.27	EL,OL-R&Bph	Tree branches fallen on lines & Pin Insulator flash over at Military Wall	-----
11		S.D Hospital	Crescent Hospital	11KV	VII	12.20	13.52	01.32	EL	R.M.U fault at N.M.D.C	-----
12		Nampally	FACCI	11KV	VII	15.44	17.07	01.23	AR	Auto Reclouser problem near SS	Arranged B/F on 11KV Red Hills fdr
13		Asif Nagar	Jyothi Nagar	11KV	VII	16.06	17.48	01.42	EL	Tree branches on lines at Militray Area & faulty loads of 11KV Kakatiya Nagar feeder	-----
14		Asif Nagar	Kakatiya Nagar	11KV	VII	16.06	17.48	01.42	EL	No Visible fault	Loads normalised
15		Asif Nagar	Kakatiya Nagar	11KV	VII	18.05	19.40	01.35	EL	Cable fault at Park View Apartment	1no DTR kept off
16		Zamistanpur	Balaji Nagar	11KV	II	21.24	23.04	01.40	All Indication	Cable Fault	Arranged B/F on 11KV Jamai Osmania fdr