

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		12		12		12			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044	0	7	0	7	0	7			
	Total	606	3055	0	26	0	26	0	26	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	4	7	4	7			
2	NLG	144	988		10		16		16			
3	MDK	107	933	2	9	1	7	1	7			
4	SDPT			3	22	1	3	1	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	43	6	33	6	33	0	0	
	Grand Total	1082	6468	6	69	6	59	6	59	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Ghanapur	Lattupally	33KV	Wanaparthu	10.41	11.45	01.04	EL	33KV due to Lighting Arrester failed		-
1	MDK	Bollaram	Meenakshi	33KV	Patancheru	03.55	07.50	03.55		BD due to Lighting Arrester failed and 33KV bus bar leads cut.		-
2		Bollaram	DRL-II	33KV	Patancheru	12.10	19.30	07.20		BD due to heavy Spark at 132 KV SS		-
1	SDPT	Siddipet	Rangadampally	33KV	Siddipet	16.15	16.45	00.30		B/D Disk fail		-
2		Chandlapur	Vittalapur	33KV	Siddipet	09.20	09.40	00.20		B/D Disk fail		-
3		Siddipet	Mittapally	33KV	Siddipet	05.15	07.10	01.55		B/D Pole Damgae		-

Circle-wise 11KV Breakdowns											
S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Farpally	Malkapur	11KV	Mahabubnagar	04.00	09.33	05.33		11KV Disk Failure at Malkapur	-
2		Machanpally	Pothanpally	11KV	Mahabubnagar	10.01	12.10	02.09		11KV Tree fallen On Conductor at Pothanpally	-
1	NLG	Cheruvugattu	Gummalabai	11KV	Nalgonda	04.25	07.20	02.55	E/L	Jumper cut	-
2		Faleem	Faleem	11KV	Nalgonda	00.00	09.50	09.50	E/L	Insulator failure	-
3		Nakkalipally	Shappally	11KV	Nalgonda	05.52	10.13	04.21	E/L	Jumper cut	-
4		Shaligouraram	Gurajata	11KV	Nalgonda	04.20	10.13	05.53	E/L	Insulator failure	-
5		S.V College	Synicpuri	11KV	Suryapet	05.40	07.30	01.50	E/L	Disc Failed	-
6		Nuthankal	Polumalla	11KV	Suryapet	02.30	06.40	04.10	E/L	Insulator failed	-
7		Ravulapally	Thurugudem	11KV	Suryapet	00.05	05.00	04.55	E/L	Insulator failed	-
8		IDA	Singannagudem	11KV	Bhongir	02.00	08.00	06.00	EL/OL	11kv Disc Failed near Teachers Colony Bhongir town	-
9		Raigir	Raigir Agl	11KV	Bhongir	06.00	14.30	07.30	EL/OL	2 no's 11 kv Disc failed & 2 no's 11 kv insulator failed near Raigir (V)	-
10		Ramannapet	Dubbaka	11KV	Choutuppal	05.00	12.50	07.50	EL/OL	11 kv disc failed at Canal near Dubbaka (V)	-
1	MDK	Bollaram - I	Kythan	11KV	Patancheru	13.15	18.30	05.15		BD due to Conductor snapped	-
2		Salgutti		11KV	Patancheru	13.10	18.30	05.20		BD due to Disk failed	-
3		Arobindo		11KV	Patancheru	13.00	15.45	02.45		BD due to Conductor snapped	-
4		Kotlam		11KV	Patancheru	01.00	02.30	01.10		BD due to Disk failed	-
5				11KV	Patancheru	02.40	05.30	02.50		BD due to Insulator failed	-
6				11KV	Patancheru	12.50	15.20	02.30		BD due to Conductor snapped	-
7		Vipla		11KV	Patancheru	12.55	14.50	01.55		BD due to Jumper cut	-
8		Masavidatta		11KV	Patancheru	12.55	14.15	01.20		BD due to Insulator failed	-
9		Rupa		11KV	Patancheru	12.55	15.20	02.25		BD due to Jumper cut	-
1	SDPT	KOHEDA	SRIRAMULAPALLY	11KV	Husanabad	10.30	13.25	02.55		HEAVY RAIN 11 KV POLE DAMAGED	-
2		Guruvannapet	Guruvannapet	11KV	Husanabad	14.40	17.20	02.40		HEAVY RAIN LINE PROBLEM	-
3		Ponnala	Ponnala	11KV	Siddipet	06.30	23.59	17.29		B/D	-
4		Chinnamadka	Machapur	11KV	Siddipet	08.10	09.10	04.00		B/D Disk fail	-
5		Guralagondi	Maljala	11KV	Siddipet	12.05	13.27	01.22		B/D Disk fail & LC.No.16632	-
6		Thimmapur	Padmanabampally	11KV	Siddipet	10.28	11.55	01.27		B/D Disk fail & LC.No.12488	-
7		Thimmapur	Padmanabampally	11KV	Siddipet	12.16	14.02	01.46		B/D Disk fail & LC.No.12489	-
8		Chittapur	Mothey	11KV	Siddipet	06.40	08.30	01.50		B/D 11 KV Line cut & LC.No.12579	-
9		Dharamajipet	Lachapet	11KV	Siddipet	14.50	15.52	01.02		B/D Tree branches fall on the line & LC.No.22364	-
10		Jangapally	Jangapally	11KV	Siddipet	00.00	13.15	13.15		B/D Insulator fail & LC.No.3712	-
11		Jangapally	Veerareddyally	11KV	Siddipet	00.00	12.20	12.20		B/D Disk fail & LC.No.3713	-
12		Mirdoddy	Andhey	11KV	Siddipet	00.00	23.59	23.59		B/D	-
13		Komalcheru	Water works	11KV	Siddipet	04.20	10.00	05.40		B/D Pole Damage	-
14		Peddakodur	Chinnakodur Mhq	11KV	Siddipet	11.10	12.40	01.30		B/D Disk fail	-
15	SDPT	DOULTHABAD	DEEPAYAMPALLY (LC.NO.3149 / DUBBAIAH LM)	11KV	Gajwel	07.00	08.30	01.30		JUMPER CUT	-
16		NEMTUR	JABBAPUR (LC.NO. / CL SWAMY)	11KV	Gajwel	00.10	07.15	07.05		JUMPER CUT	-
17		GOWRARAM	MAILARAM (LC.NO.40339 / KISTIAH LM)	11KV	Gajwel	01.00	09.00	08.00		DIC FAIL	-
18		NACHARAM	NACHARAM AGL (LC.NO.19066 / PASHA LI)	11KV	Gajwel	04.40	14.55	10.15		INSULATOR FAIL	-
19		KODAKANDLA	KUKUNOORPALLY (LC.NO.9570 / SATYANARAYANA LM)	11KV	Gajwel	11.32	12.40	01.08		JUMPER CUT	-
20		KODAKANDLA	KUKUNOORPALLY (LC.NO.9573 / SATYANARAYANA LM)	11KV	Gajwel	08.58	19.50	10.52		JUMPER CUT	-
21		FAMULAPARTHY	FAMULAPARTHY AGL (LC.NO.25388 / CHANDRAM CL)	11KV	Gajwel	08.00	09.50	01.50		DIC FAIL	-
22	TUNIKI BOLLARAM	TUNIKI BOLLARAM (LC.NO.2258 / BABU CL)	11KV	Gajwel	14.55	15.25	00.30		INSULATOR FAIL	-	
1	RR N	Subhash Nagar	Saibaba Nagar	11KV	Medchal	01.16	03.02	01.46	BD	11KV Pin Insulator failed at MN Reddy Nagar	-
2		Subhash Nagar	Ramaraj Nagar	11KV	Medchal	01.03	02.50	01.47	BD	11KV Pin Insulator failed at Mahendra Show Room	-
3		Dulapally	IDA-II	11KV	Medchal	06.54	08.10	01.16	BD	Nat Cable touched on the 11KV Line at Siddi Vinayaka Industry	-
4		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	02.50	04.35	01.45	BD	Tree Branch fallen on the 11KV Line Anand Reddy Godom	-
5		Nuthankal	Grip	11KV	Medchal	05.40	08.50	03.10	BD	2 Nos. Pin Insulators failed at Rice Mill	-
6		Vikas	Volvo	11KV	Kukatpally	16.55	18.40	01.45	BD	11KV AB Cable failure near KJR kanta	-
7		KPHB	Gowthami nagar	11KV	Kukatpally	14.02	15.02	01.00	BD	11KV AB Cable damaged More back side.given back feeding from Prashanth nagar feeder	-
8		Jeedimetla SS I	Maheshwari	11KV	Jeedimetla	10.40	12.20	01.40	BD	RMV out going cable failure at Depak Nightraite	-
9		Jeedimetla SS I	Shubhash nagar	11KV	Jeedimetla	09.10	10.14	01.04	BD	11kv jumper cut at Tirumala kanta	-
10		Jeedimetla SS II	Phase V	11KV	Jeedimetla	07.57	09.10	01.13	BD	11KV Brass patti snapped & touched the channel at Phase V	-
11		Jeedimetla SS II	Uthambisculte	11KV	Jeedimetla	09.04	11.45	02.41	BD	11kv CTBT failure & pin insulator fail at Phase V	-
12		Jeedimetla SS II	Excell	11KV	Jeedimetla	10.35	13.10	02.35	BD	11KV AB Cable failure at Phase III	-
1	RR E	Cherlapally-III	Gail	11KV	Sainikpuri	01.24	04.21	02.57		11KV Pin Insulator fail on 2 Compony 3HG fuse fail near Gail (AE)	-
2		Cherlapally-III	Danmed	11KV	Sainikpuri	01.27	04.34	03.07		11KV Pin Insulator fail at Ramesh Industry (AE)	-
3		Moula-Ali	Moula-Ali	11KV	Sainikpuri	04.10	05.15	01.05		11KV line cut at near SS Opp (Artisan/Narsimha Reddy)	-
4		Malkajigiri	Dayanand Nagar	11KV	Sainikpuri	11.11	12.20	01.09		Tree fallen on 11kv line at Vani Nagar Stree No.4 Malleshwari Appartment Opposite (due to line AB Switch Open at RK Nagar)	-
5		Polytechnic	Srinivasapuram	11KV	Habsiguda	09.37	11.40	02.03		Disk fail at Babu rao Hospital	-
6		Jppal	Bank colony	11KV	Habsiguda	09.00	09.50	00.50		Tree branches fallen on 11kvline at Prashanthi nagar	-
7		Peerzathiguda	Shankar nagar	11KV	Keesara	14.58	15.44	00.46		Insulator fail at Road no 4	-
1	HYD N	Kalyan Nagar	A.G.Colony	11KV	X	07.35	10.20	02.45	All Indication	HG fuse burntout & DTR fault at Vikasuri	-
2		Kalyan Nagar	Laxmi Nagar	11KV	X	08.30	10.15	01.45	EL,OL-Rph	No Visible Fault	-
1	HYD S	E.N.T	Gurudwara	11KV	IX	12.45	16.01	03.16	EL	Breaker fault at SS	Arranged B/F on 11KV Puniti Bowli feeder
1	HYD C	Golconda	Brindavan Colony	11KV	VII	02.20	03.25	01.05	EL,OL-Bph	No Visible Fault	Arranged B/F on 11KV Hakimsha fdr
2		Asif Nagar	NSF Colony	11KV	VII	05.16	06.58	01.42	EL,OL-Rph	Line AB Switch Jumper cut & Pin Insulator flash over at Chikkaiah PT	-
3		Vittalwadi	Taj Mahal	11KV	I	13.35	15.15	01.40	All Indication	RMU burnt out at Taj Mahal Hotel	-
4		Langer House	Fathe Darwaja	11KV	VII	13.41	14.42	01.01	EL,OL-Bph	Tree branches fallen on lines at Fathe Darwaja	-