

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044	0	8		8		8			
	Total	606	3055	0	14	0	14	0	14	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	8	1	8	1	8			
2	NLG	144	988		4		4		4			
3	MDK	107	933		2		2		2			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	21	1	21	1	21	0	0	
	Grand Total	1082	6468	1	35	1	35	1	35	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanapet	16.55	19.35	02.40	O/L	Pin Insulator Failed Near Yerragunta Thanda	Vepoor	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 18.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Parpally	Malkapur	11KV	Mahabubnagar	07.10	10.05	02.55		11KV Tree fallen On Conductor at Malkapur	-
2		Kosgi	Sampally	11KV	Narayanapet	11.04	15.30	04.26		Due to Tree Branches fallen on 11KV Line	-
3		Kosgi	Kosgi	11KV	Narayanapet	15.10	15.20	00.10		Due to 11KV Disc failure	-
4		Maddur	Pallerla	11KV	Narayanapet	05.00	06.15	01.15		Due to Jumper cut	-
5		Maddur	Dorepally	11KV	Narayanapet	05.05	05.45	00.40		Due to 11 KV Wire Cut	-
6		Salkarpet SS	Rangareddypally	11KV	Narayanapet	09.39	13.45	04.06		Due to 11KV Disc failure	-
7		Marikal	P.C Kunta	11KV	Narayanapet	07.30	12.30	05.00		Due to 11KV Disc failure	-
8		Marikal	Gunmukla	11KV	Narayanapet	13.15	16.15	03.00		Due to 11KV Disc failure	-
1	NLG	Bopparam	M.Kothagudem	11KV	Suryapet	10.25	12.45	02.20	E/L	Conductor snapped	-
2		A D PALLY	VEERLAPALEM	11KV	Miryalaguda	07.30	10.30	03.00	E/L	11KV PIN INSULATOR FAILED NEAR VILLAGE	-
3		KAMAREDDY GUEM	BURNDAVANAPUR AM	11KV	Miryalaguda	05.00	07.10	02.10	E/L	DUE TO WIND, CONDUCTOR TOUCHED PHASE TO PHASE (MELTING)	-
4		Nemaragommula	Nemaragommula	11KV	Bhongir	08.28	10.45	02.17	EL/OL	11 kv insulator failed at Begala. Anjaiah well near Nemaragommula village	-
1	MDK	Patancheru Town	Kanjarla	11KV	Patancheru	06.20	07.50	01.30		BD due to Tree fallen on line	-
2		Bollaram - II	Vasavidatta	11KV	Patancheru	20.03	20.33	00.30		BD due to Insulator failed	-
1	SDP	Pandilla	Pandilla Express	11KV	Husnabad	06.00	06.30	00.30		11 Kv Line Fault	-
2		Komuravelly	Gourapally	11KV	Husnabad	09.10	13.25	04.15		Insulator Replaced	-
3		THOGUTA	THOGUTA AGL	11KV	Gajwel	11.25	13.25	02.00		INSULATOR FAIL	-
4		CHATLAPALLY	ANTHAIGUDA	11KV	Gajwel	12.45	18.51	06.06		DTR BRUST	-
5		GOWRARAM	GOWRARAM AGL	11KV	Gajwel	12.30	14.00	01.30		JUMPER CUT	-
6		AHMEDIPUR	KOLGUR	11KV	Gajwel	14.20	15.30	01.10		DISC FAIL	-
7		KODAKANDLA	KUKUNOORPALLY	11KV	Gajwel	11.05	11.55	00.50		DISC FAIL	-
1	RR S	Puppalaguda	Puppalaguda	11KV	Ibrahimbagh	14.30	14.55	01.25	BD	11kv Cable failed at BRC Apartment	-
1	RR N	Medicity	IDA	11KV	Medchal	09.50	11.05	01.15	BD	11KV Line Cut & replaced at Pump House, Medicity Road	-
2		Devarayamjal	DMC	11KV	Medchal	02.05	04.00	01.55	BD	HG fuse set Damaged at Arkalaguda	-
1	RR E	Street no 8	ISI	11KV	Habsiguda	22.21	00.05	01.44		11KV Post of Insulator failed & replased at East Home Apartment	-
2		Chengicherla	Chengicherla	11KV	Keesara	13.05	13.54	00.49		11KV Copper patti cut at Krishnaiah Yadav T/F	-
3		Narapally	Prathap Singaram	11KV	Keesara	18.40	19.10	00.30		Tree fallen on 11KV line at Korremula Village	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	N.I.M.S	Panjagutta	11KV	X	22.27	23.35	01.08	EL	Pin Insulator flash over at Road No.1	-
2		Hakeempet	Risala Bazar	11KV	C-VI	22.45	00.25	01.40	EL,OL-Bph	Pin Insulator flash over at Sri Sai Siddi Apts -II	-
1	HYD S	C.R.P.F	Balapur	11KV	III	00.20	02.15	01.55	EL	Cable fault at Barkas	Arranged B/F on 11KV Omar Colony fdr & 11KV Baba Nagar fdr
1	HYD C	Nampally	Red Hills	11KV	VII	06.31	07.45	01.14	EL,OL	Cable Jumper cut at Himalaya Book Depot	-----
2		Golconda	Mothi Mahal	11KV	VII	10.40	12.03	01.23	All Indication	Cable fault	Arranged B/F on 11KV M.D.Lines fdr
3		Golconda	Aditya Nagar OH	11KV	VII	15.25	16.30	01.05	EL,OL-Bph	AB Cable fault at Toilet PT (DTR Kept off)	-----
4		Vittalwadi	Basanth Colony	11KV	II	21.35	23.15	01.40	EL	Pin Insulator flash over at Basanth Colony	-----
5		Jawahar Nagar	J.N Home	11KV	I	22.25	23.35	01.10	EL	Pin Insulator flash over at Siddam Setty Apts	-----