

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		12		12		12			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		13		13		13			
	Total	606	3055	0	28	0	28	0	28	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	5	2	5	2	5			
2	NLG	144	988		25		25		25			
3	MDK	107	933	2	6	2	6	2	6			
4	SDPT			1	27	1	27	1	27			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	63	5	63	5	63	0	0	
	Grand Total	1082	6468	5	91	5	91	5	91	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Chinnamaroor	33KV	Wanaparthi	19.15	20.35	01.20	O/L	Tree Branch Fallen on the Line Near Sri Rangapur SS		-
2		Maddur	Vepoor	33KV	Narayanpet	15.10	17.30	02.20	E/L	Due to Insulator Failed		-
1	MDK	Bollaram	Meenakshi	33KV	Patancheru	01.00	02.30	01.30		B/D due to Jumper cut		-
2		Bollaram	Bollaram-II	33KV	Patancheru	16.23	22.40	06.17		B/D due to Jumper cut		-
3	SDPT	Musthyala	Komuravelly	33KV	Husnabad	16.30	18.25	01.55		Not found any fault ,some tree branches are trimmed		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 20.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Alwanpally	11KV	Jadcherla	00.00	07.30	07.30		11KV Insulator Failed Near SS	-
2		Midjil	Veljal	11KV	Jadcherla	00.00	06.40	06.40		11KV Insulator Failed Near SS	-
3		Lokirew	Lokirew	11KV	Jadcherla	00.00	11.20	11.20		Tree Fallen on the Line Near Lokirew	-
4		Kosgi	Kosgi	11KV	Narayanapet	21.15	21.35	00.20		Due to Heavy Gale and Wind	-
5		Kotakonda	Bandagunda	11KV	Narayanapet	12.00	14.00	02.00		Due to 11 KV Disc Failed	-
1	NLG	Aitipamula	Gangadevigudam	11KV	Nalgonda	01.00	09.00	08.00	E/L	11Kv Insulater Failed	-
2		Nakkalapally	Shapally	11KV	Nalgonda	04.40	09.00	04.20	E/L	11Kv Jumper Cut	
3		Aregudam	Aregudam	11KV	Nalgonda	08.15	13.00	04.45	E/L	11Kv Conductor Snapped	
4		Pamanagundla	Erasanigudam	11KV	Nalgonda	01.00	09.30	08.30	E/L	11Kv Insulater Failed	
5		Pamulapad	Poreddy gudem	11KV	Miryalaguda	03.00	11.00	08.00	E/L	11 KV Disc failed	
6		Pamulapad	Kalwalapalem	11KV	Miryalaguda	03.30	11.00	07.30	E/L	11 KV AB switch problem	
7		P D Pally	Gajalapuram	11KV	Miryalaguda	10.03	12.22	02.19	E/L	11KV insulator failed	
8		A D Pally	Veerlapalem Agl	11KV	Miryalaguda	08.10	13.00	04.50	E/L	11 KV conductor snapped	
9		Nandipad	Nandipad	11KV	Miryalaguda	00.00	01.40	01.40	E/L	11 KV Disc failed	
10		Matoor	Matoor	11KV	Miryalaguda	13.40	16.10	02.30	E/L	11 KV conductor snapped	
11		Mupparam	Vootkur	11KV	Miryalaguda	11.50	15.40	03.50	E/L	11 KV Disc failed	
12		Ravulapally	Manapuram	11KV	Suryapet	04.30	08.20	03.50	E/L	Insulator failed	
13		Veluguapally	Pasnooru	11KV	Suryapet	10.40	12.35	01.55	E/L	Disc failed	
14		Aipoor	Kotapahad	11KV	Suryapet	04.30	08.50	04.20	E/L	Disc failed	
15		Sirikonda	Balluthanda	11KV	Huzurnagar	05.20	07.10	01.50	E/L	Line Snapped	
16		Repala	Kalakova	11KV	Huzurnagar	05.10	07.30	02.25	E/L	Line Snapped	
17		MR.Gudem	Gangasanipally	11KV	Bhongir	04.50	11.00	06.10	E/L	11kv Insulator Failed	
18		Alair	Ch.Kandukur	11KV	Bhongir	08.10	14.30	06.20	E/L	11kv Line sanpped	-
19		Datherpally	Datherpally	11KV	Bhongir	23.31	09.46	10.27	E/L	2 no's 11 Poles dammages	-
20		Chada	Kondapuram	11KV	Bhongir	02.10	13.40	11.30	E/L	11kv Disc Failed	-
21		Thummalagudem	Siripuram	11KV	Choutuppal	23.46	03.05	03.19	E/L	11 kv Insulator failed	-
22		Thummalagudem	Siripuram	11KV	Choutuppal	03.26	08.35	05.09	E/L	11 kv Insulator failed	-
23		Laxmapuram	Laxmapuram	11KV	Choutuppal	09.30	11.15	01.45	E/L	1phase DTR Failed	-
24		Sarvel	Nagavarigudem	11KV	Choutuppal	04.00	10.00	06.00	E/L	11 kv Insulator failed	-
25		Golanpally	Express Indl	11KV	Choutuppal	10.30	11.50	01.20	E/L	11kv Insulator Failed	-
1	MDK	Cheryal	Kandi	11KV	Sangareddy	09.16	15.00	05.44		B/D due to Disk Failure	-
2		Sangareddy Rural	Kalabgur	11KV	Sangareddy	15.32	18.34	03.02		B/D due to Tree branches fallen on the line	-
3		Anrich Bollaram	Town-II	11KV	Patancheru	10.29	12.04	01.35		B/D Due to Insulator Failure	-
4		Kistareddypet	Patelguda	11KV	Patancheru	07.35	08.05	00.30		B/D Due to Insulator Failure	-
5		Ameenpur	Ameenpur	11KV	Patancheru	20.15	21.05	00.50		B/D due to Jumper cut	-
6		Zaheerabad Town	Town-III	11KV	Zaheerabad	13.35	14.30	00.55		B/D due to Tree branches fallen on the line	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Komaticharuvu	Housing Board	11KV	Siddipet	11.15	12.00	00.45		B/D for Tree branches fall at 11KV	-
2		Komaticharuvu	Kushal Nagar	11KV	Siddipet	11.05	11.40	00.35		B/D for Tree branches fall at 11KV	
3		Ponnal	CP Office	11KV	Siddipet	22.00	22.20	00.20		B/D for Insulator fail LC No.19293	
4		Nangunoor	Nagarajupally	11KV	Siddipet	05.10	14.48	09.38		B/D for Insulator fail LC No.3093	
5		Pullur	Bandacherlapally	11KV	Siddipet	11.19	12.01	00.42		B/D for Disk fail	
6		Pullur	Bandacherlapally	11KV	Siddipet	16.16	16.48	00.32		B/D for Insulator fail	
7		Dubbak IPDS	Chervapur	11KV	Siddipet	13.46	15.45	01.59		B/D for Tree branches fall at 11KV	
8		Ragothampally	Ragothampally	11KV	Siddipet	10.46	12.00	01.14		B/D for EL Tripping	
9		Chittapur	Chittapur	11KV	Siddipet	10.00	10.39	00.39		B/D for Disk fail	
10		Rudraram	Mallupally	11KV	Siddipet	08.30	17.30	09.00		B/D for Insulator fail	
11		RAIPOLE	INDUSTRIAL	11KV	Gajwel	12.55	14.00	01.05		TREE BRANCH FALL OVER 11 KV	
12		KONDAPAKA	VISHWANATHPALLY	11KV	Gajwel	13:20	16:20	03:00		DISC FAIL	
13		THIMMAREDDYPALLY	THIMMAREDDYPALLY	11KV	Gajwel	08.30	09.45	01.15		INSULATOR FAIL	
14		KISTAPUR	KISTAPUR AGL	11KV	Gajwel	13.05	14.05	01.00		POLE DAMAGED	
15		DR PALLY	GIRIPALLY	11KV	Gajwel	09.13	10.13	01:00		LT LINE SNAPPED	
16		JAGADEVPUR	JAGADEVPUR AGL	11KV	Gajwel	09.55	12.20	02.25		INSULATOR FAIL	
17			DOULAPUR AGL	11KV	Gajwel	12.50	13.55	01.05		DISC FAIL	
18		NACHARAM	NACHARAM AGL	11KV	Gajwel	15.00	16.45	01.45		INSULATOR FAIL	
19		PREGNAPUR	INDUSTRIAL	11KV	Gajwel	09.50	11.41	00.51		INSULATOR FAIL	
20		SINGATAM	SINGATAM AGL	11KV	Gajwel	17.30	18.00	00.30		INSULATOR	
21		PAMULAPARTHY	EPPALAGUDEM	11KV	Gajwel	12.10	12.25	00.15		INSULATOR FAIL	
22		PAMULAPARTHY	INDIRANAGAR	11KV	Gajwel	12.55	13.44	00.49		JUMPER CUT	
23		KARKAPATLA	KARKAPATLA AGL	11KV	Gajwel	12.18	13.05	00.47		TREE BRANCH FALL OVER 11 KV	
24		PAMULAPARTHY	EXPRESS	11KV	Gajwel	12:00	12:40	0:40		INSULATOR FAIL	
25		Nagapuri	Pothireddypally	11KV	Husnabad	03.45	08.40	04.55		11 kv pole damaged	
26		Dharmaram	Nandram	11KV	Husnabad	03.15	10.12	06.57		Insulator failed	-
27		Regulapally	Mallamcheruvu	11KV	Husnabad	09.30	14.20	04.50		Insulator failed	-
1	RR N	Jeedimetla SS III	Ramreddy nagar	11KV	Jeedimetla	14.40	15.45	01.05	BD	11KV Pin insulator failure opp Ganesh Temple	-
2		Petbasheerabad	Satyam Enclave	11KV	Medchal	00.20	01.35	01.15	BD	11KV Pin Insulator Failed at near by Suraksha Hospital	-
3		HMT	Manikya Nagar	11KV	Medchal	05.40	06.30	00.50	BD	11KV Pin Insulator Failed at Venkateshwara Nagar	-
4		Subhash Nagar	Padma Nagar	11KV	Medchal	01.40	02.10	00.30	BD	11KV Pin Insulator Failed at Choice Company	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
5	RR N	Kompally	Jaibheri	11KV	Medchal	06.50	07.55	01.05	BD	11KV Cable endkit failed at BSNL Apartment	-
6		GP Pally	GP Pally	11KV	Medchal	13.15	18.45	05.30	BD	No Fault	-
7		ICICI	Bharath Bio Tech	11KV	Medchal	12.35	16.40	04.05	BD	11KV Pin Insulator failed at Geno Tech Company	
8		Kandlakoya	Saigeetha Asaramam	11KV	Medchal	00.00	01.50	01.50	BD	Tree Branch fallen on 11KV Line at Bommala Bavi	
9		Shameerpet	Nalsar	11KV	Medchal	04.10	06.00	01.50	BD	Tree fallen on the 11KV Line at Celebraty Club	
10		Laxmapur	Laxmapur	11KV	Medchal	07.30	09.10	01.40	BD	11KV Line AB Switch Opened at Delar Bavi,Laxmapur	-
11		Nuthankal	Bharathi	11KV	Medchal	00.40	02.05	01.25	BD	Bird fallen on the 11KV Line at Nuthankal Village	-
12		Devarayamjal	Kottapet	11KV	Medchal	15.15	16.25	01.10	BD	Tree Branch fallen on the 11KV Line at VRL Godom, Devarayamjal	-
1	RR E	Cherlapally-I	Nagaram	11KV	Sainikpuri	15.23	16.15	00.52		Ground Petrolling done No Visible Fout Found	-
2		NGRI	Kalyanipuri	11KV	Habsiguda	08.19	09.19	01.00		Tree fallen on 11KV line at Survey Of India	-
3		P&T Colony	Canara Nagar	11KV	Keesara	03.00	03.30	00.30		11KV Insulator failed at Canara Nagar	-
1	HYD N	Bhudevi Nagar	Ram Raj Nagar	11KV	VI	00.18	02.52	02.34	EL,OL	CT PT fault at St.Andrews School & Pin Insulator flash over at Ram Reddy Nagar	-
2		Road No.12	N.B.T Nagar	11KV	X	01.05	02.10	01.05	All Indication	Moisture formed in RMU near SS	-
3		Clock Tower	St.Mary's	11KV	V	02.35	03.35	01.00	EL,OL-Bph	DTR fault at Barrela PT	-
4		Yousufguda	Pleasant Value	11KV	X	05.05	06.13	01.08	EL	Pin Insulator flash over at CRPF Gate	-
5		Sanjeevaiah Park	Police Lines	11KV	C-VI	11.39	13.28	01.49	EL,OL-Bph	Disc Insulator flash over at Indiramma Ngr	-
6		Nehru Nagar	Hari Hara Kala Bhavan	11KV	V	11.59	14.55	02.56	All Indication	Big tree fallen on lines at Yashoda Hospital	-
7		I.I.C.T	Dall Mill	11KV	V	14.24	16.16	01.52	EL	Tree branches fallen on lines & Faulty loads of 11KV Nagarjuna Nagar feeder	-
1	HYD C	Zamistanpur	Dayara Market	11KV	II	00.23	01.43	01.20	EL,OL	No Visible Fault	-
2		Golconda	Darga OH	11KV	VII	01.30	03.20	01.50	EL,OL-Bph	Pin Insulator flash over at PT Darga	-
3		Fever Hospital	C.C.Shroof Hospital	11KV	II	08.20	09.25	01.05	EL,OL-Rph	Pin Insulator flash over at Chappal Bazar	-
4		A.C.Guards	N.M.D.C	11KV	VII	08.59	10.33	01.34	EL	No Visible Fault	Arranged B/F on 11KV Cresent Hospital fdr
5		Zamistanpur	Jamai Osmania	11KV	II	11.48	12.58	01.10	EL,OL-Bph	Cable fault at Suprabath Market	-
6		Erramanzil	Red Rose	11KV	I	21.00	22.25	01.25	EL,OL-Yph	Cable fault at SS	Arranged B/F on 11KV Kapadiya Lane fdr