

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		10		10		10			
3	MDK	107	933	3		3		3				
4	SDPT				12		12		12			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	22	5	22	5	22	0	0	
	Grand Total	1082	6468	5	29	5	29	5	29	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G.R Cable	33KV	Jadcherla	00.30	03.20	02.50		Tree Fallen on the Line near Rangareddy Guda	G.R Cable	-
2		Nagarkurnool	Bijinapally	33KV	Nagarkurnool	05.10	06.30	01.20	E/L	33KV Line Phase to Phase at Bondalapally	Bijinapally	-
1	MDK	Gummadidala	GPSS-1	33KV	Patancheru	04.10	06.50	02.40		BD due to Tree fallen on the line & Disk failed	GPSS-1	-
2		Gummadidala	GPSS-1	33KV	Patancheru	09.45	12.20	02.35		BD due to Tree fallen on the line & Disk failed	GPSS-1	-
3		Gummadidala	AFA	33KV	Patancheru	05.50	06.50	01.00		BD due to Disk failed	AFA	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 21.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mallaram	Bollepally	11KV	Nalgonda	12.45	13.25	00.40	E/L	11 KV Line Jumpet Cut	-
2		Nidamanoor	Bankapuram	11KV	Miryalguda	05.30	10.40	05.10	E/L	11 KV Disc failed	-
3		Pulicharla	Pulicharla	11KV	Miryalguda	16.10	17.47	01.37	E/L	S-Ph DTR Failed (DTR Jumper out)	-
4		Mukundapuram	Chandupatla	11KV	Suryapet	02.30	06.40	04.10	E/L	11Kv Disc failed	-
5		Thatipamula	Nandapuram	11KV	Suryapet	01.30	06.00	04.30	E/L	11Kv Insulator flashover	-
6		Dircincharla	Somaram	11KV	Huzurnagar	04.00	07.10	03.10	E/L	11Kv Line Snapped	-
7		Munagala	K-2	11KV	Huzurnagar	03.30	07.30	04.00	E/L	11Kv Line Snapped	-
8		Venkatapuram	Venkatapuram	11KV	Bhongir	06.00	10.20	04.20	EL/OL	11kv Disc failed near Venkatapuram (V)	-
9		Alair	Ch.Kandukur	11KV	Bhongir	00.40	07.40	07.00	EL/OL	11kv Insulator failed near Kammagudem (V)	-
10		Bondugula	Bondugula Agl	11KV	Bhongir	01.00	08.45	07.45	EL/OL	11kv Insulator failed near Bondugula (V)	-
1	SDP	DOULTHABAD	MD SHAPUR	11KV	Gajwel	16.25	17.40	01.15		JUMPER CUT	-
2		DUDEEDA	DUDEEDA	11KV	Gajwel	11.35	13.20	01.45		DISC FAIL	-
3		DUDEEDA	KONDAPAKA	11KV	Gajwel	14.00	15.00	01.00		DISC FAIL	-
4		DUDEEDA	KONDAPAKA	11KV	Gajwel	09.25	12.45	03.20		DISC FAIL	-
5		GOWRARAM	TUNIKI KALASA	11KV	Gajwel	05.35	06.50	01.15		INSULATOR FAIL	-
6		PREGNAPUR	SINGATAM	11KV	Gajwel	09.40	13.16	03.36		DISC FAIL	-
7		Bejanki	Baswapur Rural	11KV	Husnabad	15.15	18.00	02.45		Jumper cutting	-
8		Dhoolmitta	Arjunpatla	11KV	Husnabad	01.00	11.25	10.25		Insulator Fail	-
9		Raghavapur	Raghavapur	11KV	Siddipet	05.50	17.50	12.00		B/D LC For 11 KV Wire cutting	-
10		Pothareddypet	Rameshwarampally	11KV	Siddipet	09.25	11.00	01.35		B/D Disk fail	-
11		Jangapally	Veerareddypally	11KV	Siddipet	08.50	10.30	01.40		B/D DTR Fail	-
12		Mirdoddy	Anday	11KV	Siddipet	11.00	11.40	00.40		B/D for Disk fail	-
1	RR N	GP Pally	GP Pally	11KV	Medchal	01.40	03.20	01.40		11KV Pin Insulator failed at Terlling Homes	-
2		Medchal	IDA-I	11KV	Medchal	15.10	16.30	01.20		Tree fallen on the 11KV Line at REVL Backside	-
3		Subhash Nagar	Jairam Nagar	11KV	Medchal	02.03	04.40	02.37		11KV Pin Insulator failed at Godavari Homes & 11KV Line Jumper Cut at SBI Bank	-
4		Dulapally	Dulapally Village	11KV	Medchal	03.10	04.00	00.50		11KV Disc failed at Krishna Nagar Park	-
1	RR E	Nagaram	SN colony	11KV	Keesara	17.02	18.27	01.25		Insulator fail at Shakthi nagar	-
2		Chengicherla	My villas	11KV	Keesara	01.25	02.30	01.05		Disk fail at AV construction	-
1	HYD N	Yousufguda	Police Lines	11KV	X	15.11	16.18	01.07	Opened AR	Tree branches fallen on lines at Police Lines	-