

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		3		3		3			
3	MDK	107	933	1		1		1				
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	9	2	9	2	9	0	0	
	Grand Total	1082	6468	2	16	2	16	2	16	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.08.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanapet	07.10	09.30	02.20	E/L	Tree Fallen on the Line Near 132KV SS Maddur	Vepoor	No
1	MDK	Zaheerabad	Jharasangam	33KV	Zaheerabad	0:02	10:55	10:53		Jumpercut	Jharasangam	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Serivenkatapur	Suraram	11KV	Mahabubnagar	15.10	16.10	01.00		11KV Tree fallen On Conductor at Malkapur	No
2		Kodur	Zamestapur	11KV	Mahabubnagar	10.50	13.00	02.10		11KV Conductor cut at Zamistapur	No
1	NLG	Veluguapally	Veluguapally	11KV	Suryapet	9:10	11:25	2:15	E/L	Bird fallen on the line	No
2		Chilukur	R C Nagar	11KV	Huzurnagar	13.20	15.00	01.40	EL	11 KV JUMPER CUT	No
3		Venkatapuram	Dathaipally	11KV	Bhongir	04.00	09.00	05.00	EL/OL	11kv Insulator Failed near Dattaipally Village	No
1	SDPT	Tunikalsa	Amberpeta Agl.	11KV	Gajwel	12:35	13:25	0:45		Tree branch fallen on the line	No
2		Gowraram	Pathur	11KV	Gajwel	12.43	13.43	01.00		Disc failed	No
3		Ramancha	Gangapur	11KV	Siddipet	09.00	11.00	02.00		11KV Wire cut	No
4		Chittapur	Mothey	11KV	Siddipet	09.15	09.40	00.25		Insulator failed	No
1	RR N	Thurkapally	Thurkapally	11KV	Medchal	8:50	9:25	0:35	EL	Bird fallen on the 11KV Line at Bharath Petrol Pump	No
2		GP Pally	GP Pally	11KV	Medchal	14.25	15.10	00.45	EL/OL	Tree fallen on the 11KV Line at Ayodya Chowrasta	No
3		Aliabad	HBL	11KV	Medchal	00.20	05.55	05.35	EL	11KV Disc failed and 11KV Line cut and Tree fallen on the 11KV Line at Nadigadda	No
1	RR E	St.No.08	Laxmi Nagar	11KV	Habsiguda	23:12	0:29	1:17		Car dashed to 11KV Pole at Ganesh Nagar	No
2		Saketh	Jawahar Nagar	11KV	Keesara	15.32	16.20	00.48		11KV Jumper cut at BJR Nagar	No
1	HYD C	Fever Hospital	C.C Shroff Hospital	11KV	II	08.44	10.20	01.36	All Indication	R.M.U Lugs burntout at C.C Shroff Hospital	No
2		A.S.R Raju Nagar	Golla Basti	11KV	VII	10.10	11.25	01.15	OL	HT Line touching to Pole at Saber Nagar	No