

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		5		5		5			
3	MDK	107	933		2		2		2			
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	19	1	19	1	19	0	0	
	Grand Total	1082	6468	1	27	1	27	1	27	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.08.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanapet	19.20	21.00	01.40	E/L	for Due to Rain ,Jumpers open at Mominapur		No

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 23.08.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kandoor	Komireddypally	11KV	Jadcherla	06.30	10.05	03.35		Tree fallen the line near Komireddypally	-
2		Annasagar	Town	11KV	Jadcherla	11.32	13.05	01.33		Phase to Phase near Annasagar	-
3		Kuchur	Ippatur	11KV	Jadcherla	12.47	14.22	01.35		Phase to Phase near Ippatur	-
1	NLG	Mallaram	Mallaram	11KV	Nalgonda	09.00	10.30	01.30	EL	11 KV Line Jumpet Cut	-
2		Kattangur	Kalmera	11KV	Nalgonda	11.00	12.00	01.00	EL	Insulator failed	-
3		Thadakamalla	Molkapatnam	11KV	Miryalaguda	00.02	08.10	08.08	EL	No fault found	-
4		Penpahad	S.R Palem	11KV	Suryapet	15.50	17.20	01.30	EL	Bird fallen on the line	-
5		Bondugula	Parupally	11KV	Bhongir	14.05	16.20	02.15	EL	11 KV Insulator failed	-
1	MDK	Pati	Pati	11KV	Sangareddy	14.30	16.45	02.15		B/D Due to Conductor Snapped	-
2		Pati	Ionnex	11KV	Sangareddy	07.30	08.25	00.55		B/D Due to Jumper Cut	-
1	SDPT	Husnabad-II	Husnabad Town-4	11KV	HUSNABAD	07.10	07.40	00.30		Insulator failed, same rectified	-
2		Cherial Town	Sundarayyanagar Agl	11KV	HUSNABAD	11.50	17.55	06.05		Insulator failed, same rectified	-
3		Komuravelly	Komuravelly Agl	11KV	HUSNABAD	14.43	16.10	01.27		Line snapped, same rectified	-
4		Komuravelly	Gouraipally	11KV	HUSNABAD	10.05	11.25	01.20		Insulator failed, same rectified	-
5		Erravally SS	11 KV Narsannapet Feeder LC : 26366(Laxman LM)	11KV	GAJWEL	13.24	14.58	01.34		11 KV Disk Fail	-
6		Mulugu SS	Mulugu AGL LC: 14055 (Dhanpal Reddy)	11KV	GAJWEL	14.00	15.46	01.46		Insulater Fail	-
7		Mubarasapur SS	Thirmalapur Feder	11KV	GAJWEL	01.28	07.37	06.09		DTR Fail	-
8		Ramancha	Gangapur	11KV	SIDDIPET	09.00	11.00	02.00		B/D - 11KV wire cut	-
9		Chittapur	Mothey	11KV	SIDDIPET	09.15	09.40	00.25		B/D - Insulator fail, LC No. 12587	-
1	RR N	HMT	Gandhi Nagar	11KV	Medchal	13.30	14.25	00.55	EI	Tree Branches fallen on the 11KV Line at Gandhi Nagar	-
2		Laxmapur	Narayanpur	11KV	Medchal	06.20	07.35	01.15	EL	Tree Branches fallen on the 11KV Line at Narasimha Reddy Poultry	-
3		Medicity	Munirabad	11KV	Medchal	09.50	11.30	01.40	EL/OL	11KV Pin Insulator & Tree Branch fallen on the 11KV Line at Crusher	-
1	RR E	Tech park	Haryana still	11KV	HBg	21:22	23:11	1:49		HU Fuse Failed at Multi Steels Fedeer & Sai Export company Pin Insulator Failed	-
1	HYD N	Tolichowki	Hanuman Temple	11KV	X	21.10	22.35	01.25	EL,OL-Bph	Tree branches fallen on lines at Vijaya Shanthi House	-
2		Yellareddyguda	Akber Form	11KV	X	21.40	23.25	01.45	EL	Disc Insulator flash over at Judge PT	-
3		Nehru Nagar	L.I.C	11KV	C-VI	23.05	00.25	01.20	All Indication	Cable fault at Court	Arranged B/F on 11KV Picket for
1	HYD C	Zamistanpur	Dayar Market	11KV	II	21.18	23.52	02.34	EL,OL-Bph	Tree branches fallen on lines & Pin Insulator flash over at Mirja Shiving Mechine	-