

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT			2	5	2	5	2	5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	12	4	12	4	12	0	0	
	Grand Total	1082	6468	4	19	4	19	4	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.08.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Halia	Yacharam	33KV	Miryalaguda	15:15	16:00	0:45	EL	33 KV Disc failed	Yacharam	No
1	MDK	Bollaram	Coca Cola	33KV	Patancheru	19:20	22:00	2:40		Jumper cut	Coca Cola	No
1	SDPT	Thukkapur	Mettu	33KV	Gajwel	1:00	7:00	6:00		33KV Jumper cut	Mettu	No
2		Thunkibollaram	Thunkibollaram	33KV	Gajwel	23.10	23.50	00.40		33KV Jumper cut	Thunkibollaram	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Moosapet	11KV	Jadcherla	06.00	08.30	02.30		11 KV jumper cut near at Moosapet village.	No
2		Appakpally	Boinpally	11KV	Narayanapet	13.00	13.24	00.24		LT Line Fault	No
3		Kotakonda	Bommanpad	11KV	Narayanapet	13.33	14.40	01.07		11KV Conductor snapped and cut	No
1	NLG	Thadakamalla	Salkanoor	11KV	Miryalaguda	10:22	12:00	1:38	EL	Phase to Phase	No
2		Penpahad	Annaram	11KV	Suryapet	04.30	07.35	03.05	EL	Insulator failed	No
3		Mukundapuram	Somaram	11KV	Huzurnagar	14.00	15.20	01.20	EL	11KV Line snapped	No
1	MDK	Pati	Pati	11KV	Patancheru	3:35	6:10	2:35		Jumper cut	No
1	SDPT	Pandilla	Pandilla Rural	11KV	Husnabad	0:00	8:20	8:20		Jumper cut	No
2		MARKOOK	Erravally Agl	11KV	Gajwel	14.55	15.30	00.35		DTR Failed	No
3		MARKOOK	Erravally Agl	11KV	Gajwel	12.20	13.01	00.41		Coper Patty Burning	No
4		MARKOOK	Damarakunta Town	11KV	Gajwel	15.15	16.50	01.35		AB Switch repaired	No
5		MARKOOK	Damarakunta	11KV	Gajwel	18.44	23.59	05.15		No visible fault	No
1	RR N	Jeedimetla-IV	Tagorea	11KV	Jeedimetla	15:30	16:35	1:05		11kv AB cable Failure At Tagore Company	No
2		Petbasheerabad	Satyam Enclave	11KV	Medchal	14.00	15.00	01.00		HT/LT line Snapped at Bloom Hospital	No
3		Dulapally	IDA-II	11KV	Medchal	17.47	19.10	01.23		Tree Branches fallen on 11KV Line at Nagendara Engineering works	No
1	HYD N	R.P.Nilayam	Naga Devatha	11KV	C-VI	09.55	11.25	01.30	EL	Cable fault at MCC Army	No
2		Gunrock	Lal Bazar	11KV	C-VI	22:45	0:12	1:27	EL	AB Switch Insulator flash over, Disc Insulator flash over at Easy Bye Shop & 2nd Line AB Switch Jumper cut	No
1	HYD C	Golnaka	Shivalayam	11KV	II	13.05	14.50	01.45	EL,OL	Post type Insulator flash over at Balaji Apts, Tilak Nagar	No
2		Asif Nagar	Toli Chowki	11KV	VII	05.23	09.15	03.52	EL,OL-Bph	UG Cable fault at Toli Chowki	No