

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	3	1	3	1	3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	1	10	1	10	1	10	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	19	0	19	0	19	0	0	
	Grand Total	1082	6468	1	29	1	29	1	29	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.08.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Malkaram	Shameerpet	33KV	Medchal	12:30	14:37	2:07	EL/OL	No visible fault	Shameerpet	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Vitlapur	11KV	Narayanapet	03.20	05.30	02.10		11KV Conductor melt and replaced	No
2		Salkarpet	Pagdiyal	11KV	Narayanapet	06.00	07.15	01.15		11 KV Disc failed	No
3		Marikal	Madhwar	11KV	Narayanapet	21.30	21.45	00.15		Cable cut	No
4		Narayanapet	VIP	11KV	Narayanapet	21:05	21:54	0:49		Tree branch fallan on the 11 KV line	No
1	NLG	Narayanpur	Kotthagudem	11KV	Choutuppal	13:45	16:30	2:45	E/L	SS-22 11kv Disc Failed	No
2		Phanigiri	Etoor	11KV	Suryapet	06.40	10.28	03.48	E/L	11Kv Insulator failed	No
3		Pamanagundla	Pittampally	11KV	Nalgonda	09.01	12.50	03.49	E/L	Copper Patti Cut and Fallen on 11 KV X Arms	No
4		Madgulapally	Dacharam	11KV	Nalgonda	02.40	08.00	05.20	E/L	11Kv Jumper Cut	No
5		Madgulapally	Madgulapally	11KV	Nalgonda	02.40	08.00	05.20	E/L	11Kv Jumper Cut	No
6		Kattangur	Mallaram	11KV	Nalgonda	8:00	9:20	1:20	E/L	11Kv Jumper Cut	No
1	SDPT	Thadkapally	Venkatapur	11KV	Siddipet	11:30	15:30	4:00		11KV Wire cut and touch the DTR	No
2		Thornala	Thornala	11KV	Siddipet	00.00	07.30	07.30		11KV Insulator failed	No
3		Pothareddypet	Rameshwarampally	11KV	Siddipet	04.04	14.30	10.26		11KV Wire cut	No
4		Gajwel SS	Jaligama	11KV	Gajwel	15:05	16:30	01.25		11KV Line cut	No
5		Ahmedipur SS	Kolgur Feeder	11KV	Gajwel	13.00	14.45	01.45		Coper patty cut	No
6		Medinipur SS	Mathpally	11KV	Gajwel	09.00	14.25	05.25		Insulator failed	No
7		Guruvannapet	Guruvannapet	11KV	Husnabad	11.25	13.15	01.50		Tree fallen on the line	No
8		Komuravelly	Goutraipally	11KV	Husnabad	10.40	12.35	01.55		Tree fallen on the line	No
9		Komuravelly	Inapur	11KV	Husnabad	7:40	13:40	6:00		Conductor snapped	No
1	RR S	IIIT	Jayabheri	11KV	Gachibowli	3:34	4:37	1:03		11KV AB Cable End kit failed near Police House at APHB Colony	No
1	RR N	Kompally	Kompally	11KV	Medchal	11:14	11:50	0:36	EL	No visible fault	No
2		Subhash Nagar	Padma Nagar	11KV	Medchal	14.05	14.40	00.35	EL/OL	11KV Pin Insulator failed at VK Residency	No
3		Thumkunta	Thumkunta	11KV	Medchal	13.30	14.52	01.22	EL	11KV Disc failed at Thumkunta	No
1	RR E	Ramanthapur	Venkat Reddy Nagar	11KV	Habsiguda	1:05	2:45	1:40		11KV Line snapped	No
1	HYD N	Ayyappa Society	Kummari Basti	11KV	X	03.50	05.25	01.35	EL,OL-Bph	AB Cable Jumper touching to OH Line at Venkateshwara Colony (3Nos. DTR's kept Off)	No
1	HYD S	Hyderguda	Hyderguda	11KV	III	03.40	04.40	01.00	EL,OL	2Nos. Pin Insulators flash over at Doctors Colony	No
2		Miralam	Ansari Road	11KV	III	7:05	9:35	2:30	EL,OL	Electrical accident occurred at Idli Hotel due to accidentally touching to 11KV Water Works for line	No
1	HYD C	Narayanguda	Preventive Medicine	11KV	II	13.53	15.35	01.42	EL,OL	Tree branches fallen on lines at Sundaraiah Park	No
2		Nampally	Nampally Hospital	11KV	VII	03.41	05.00	01.19	EL	HT Jumper cut at backside Nampally Hospital	No