

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933	1		1		1				
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	6	1	6	1	6	0	0	
	Grand Total	1082	6468	1	6	1	6	1	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 31.08.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	Kalher	33KV	Jogipet	1:00	6:00	5:00		Insulator failed	Kalher	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Marror	Maroor	11KV	Nalgonda	6:00	7:15	1:15	E/L	Tree branch fallen on the line	No
2		Narkatpally	Mandra	11KV	Nalgonda	10.00	11.45	01.45	E/L	11KV Jumper cut	No
3		Golankonda	Vanchyagudem	11KV	Bhongir	06.10	08.30	02.20	E/L	11 kv Line snapped	No
4		D.Nagaram	D.Nagaram Agl	11KV	Choutuppal	13.55	15.55	02.00	E/L	11KV Insulator failed	No
1	SDPT	Pamulaparathi ss	pathure	11KV	Gajwel	6:10	7:06	0:56		Bird fallen on the line	No
2		Vantimamidi ss	singaipaly	11KV	Gajwel	17.13	18.05	00.53		LT Wire cut	No