

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT			1	5	1	5	1	5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	9	1	9	1	9	0	0	
	Grand Total	1082	6468	1	13	1	13	1	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.12.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD N	SDPT	Rebarthy	33kv	Husnabad	06.42	08.15	01.33		BD due to Jumper Cut	Rebarthy	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 02.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Gunmukla	11kv	Narayanpet	05.53	08.45	02.52		HT/LT Crossing due to wind and gale	-
2		Kothamolgara	Kothamolgara	11kv	Jadcherla	05.30	08.00	02.30		Tree Fallen on 11 KV line near Pathamolgara	-
1	NLG	Gondiryala	Chimiryala	11kv	Huzurnagar	03.50	07.30	03.40	EL	11 KV LINE SNAPPED	-
2		Addagudur	Dharmaram	11kv	Bhongiri	14.00	14.50	00.50	EL	100KVA DTR Failed Near Dharmaram Village	-
1	SDPT	Chellapur	Chellapur	11kv	Siddipet	08.20	10.12	01.52		B/D-LT wire cut	-
2		Singatm SS	Dacharam	11kv	Gajwel	05.10	07.05	01.55		11 Kv Cunductor Cut	-
3		Duddeda SS	Rampally Feeder	11kv	Gajwel	05.30	09.25	03.55		Reason Not found	-
4		Doulthabad SS	Deepayampally	11kv	Gajwel	12.45	16.17	03.32		DTR copper Patti Cut	-
5		Koheda	Cannal	11kv	Husnabad	10.10	10.50	00.40		11 kv wire cut	-
1	RR N	Kompally	Petbasheerabad	11kv	Medchal	13.55	16.25	02.30	EL	11KV Cable End Kit failed at AVR Garden Opposite	-
2		Kistapur	IDA Hanuman	11kv	Medchal	12.50	14.30	01.40	EL	11KV Line Cut & Replaced at Ravalkole Vaagu	-
1	RR E	Nacharam	Stallion Tyres	11kv	Habsiguda	12.35	14.02	01.27		11KV UG Cable fault at Stallion Tyres Company	-
1	HYD N	MLA Colony	Cancer Hospital	11kv	X	01.16	02.40	01.24	EL,OL-Rph	No Visible Fault	