

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.12.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Date: 05.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	MOGALMADKA	MOGALMADKA RURAL	11KV	Narayanapet	14.15	15.45	01.30		DUE TO SQUIRREL FALLEN ON THE LINE	No
1	NLG	CH.Annaram	Annaram	11KV	Nalgonda	6:00	7:00	1:00	EL	Insulator failed	No
2		Kandagatla	Guttakinda	11KV	Suryapet	04.00	07.30	03.30	EL	Insulator failed	No
3		Dirsincherla	Somaram	11KV	Huzurnagar	13.30	14.35	01.05	EL	11 KV LINE SNAPPED	No
1	SDPT	Narayanraopet	Beerappa gudi	11KV	Siddipet	14:00	18:16	4:16		DTR Problem	No
2		Pragnapur	Akkaram	11KV	Gajwel	18.02	18.20	00.18		Line cut	No
1	RR E	RGK	RGK	11KV	Keesara	8:56	9:40	0:44		11KV Jumper cut at RGK-103 Block	No
2		P&T Colony	Medipally	11KV	Keesara	13.40	14.45	01.05		Lizard fallen on 11KV line at Vinayak Nagar	No
1	HYD C	Industrial Area	Mother Dairy	11KV	II	22.05	23.10	01.05	EL,OL	Kept off 1No DTR due to Cable failed near Mother School	No