

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	8	1	8	1	8	0	0	
	Grand Total	1082	6468	1	11	1	11	1	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.12.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Gopalpet	33KV	Wanaparthi	15.58	18.26	02.28	LV's Pull Out	Due to Lv's Pull Out & Feeder Breaker Problem	Gopalpet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 10.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Bhogaram	11kv	Narayanapet	08.30	10.55	02.25		11KV Conductor cut at Bhogaram (V)	-
2		Dhanwada	Mandipally	11kv	Narayanapet	11.00	11.40	00.40		Jumper touched to the Pole	-
3		Hemajipur	Koilakunta Tanda	11kv	Jadcherla	02.45	11.10	08.25		11Kv line Cut Near Near Koilakunta Thanda Side	-
1	NLG	Urlugonda	Sarvaram	11kv	Huzurnagar	05.15	07.30	02.15	EL	11 KV LINE SNAPPED	-
2		Jai kesaram	Assonigudem	11kv	Choutuppal	07.18	09.10	01.52	EL/OL	100 KVA DTR failed near Assonigudem village	-
1	SDPT	Mustabad X Road	Kotilingalu	11kv	Siddipet	14.35	15.20	00.45		B/D DTR Fuse wir cut	-
2		Chittapur	Chowdarpally	11kv	Siddipet	08.52	09.39	00.47		B/D Jumper cut	-
3		RAIPOLE	INDUSTRIAL	11kv	Gajwel	13:05	14:00	00.55	B/D	B/D	-
1	RR N	Aleap	RGK	11kv	Jeedimetla	15.10	18.30	03.20		11KV AB Cable failure at Aleap small gate	-
2		Jeedimetla SS III	Fox sagar	11kv	Jeedimetla	11.15	12.50	01.35		11KV AB Cable failure at Kantha Rubbar Company	-
1	RR E	Moula ali	Spectra	11kv	Sainikpuri	17.37	18.20	00.43		Squarrel fallen on 11Kv line near Hyderabad Package (Artisian Kistopher)	-