

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				8		8		8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	15	0	15	0	15	0	0	
	Grand Total	1082	6468	0	19	0	19	0	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.12.2020

33 KV BREAKDOWNS

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.12.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Utkoor	NIDUGURTHY	11kv	Narayanpet	09.40	14.10	04.30		Due to tree branch fallen on 11KV line	-
2		MARIKAL	ELIGANDLA	11kv	Narayanpet	10.35	11.45	01.10		BREAKDOWN DUE TO 11KV LINE CUT	-
3		MARIKAL	ELIGANDLA	11kv	Narayanpet	10.35	11.45	01.10		BREAKDOWN DUE TO 11KV LINE CUT	-
1	NLG	Agamothkur	Bommakal	11kv	Miryalaguda	14.02	14.52	00.50	E/L	11 KV line snap	-
2		Chedella	Nelamarri	11kv	Suryapet	05.00	08.40	03.40	E/L	11Kv Conductor snapped	-
3		Paladugu	Dathappagudem	11kv	Bhongir	04.00	09.00	05.00	EL/OL	100KVA DTR Failed near Bokka Gudem	-
4		Pallerla	Kurella	11kv	Bhongir	07.30	10.00	02.30	EL/OL	11kv Insulator Failed near Pullaya Gudem	-
1	SDPT	Gandipally	Ramavaram	11kv	Husnabad	11.30	12.10	00.40		INSULATOR FAILURE	-
2		Guruvannapet	Guruvannapet	11kv	Husnabad	18.20	19.20	01.00		INSULATOR FAILURE	-
3		Arjunpatla	Arjunpatla (T)	11kv	Husnabad	12.40	15.00	02.20		INSULATOR FAILURE	-
4		Nangnoor	Narmetta	11kv	Siddipet	13.26	16.50	03.24		Jumper cut	-
5		Markook SS	Markook Agl Feeder	11kv	Gajwel	17.58	19.15	01.17		Jumper Open	-
6		Ganeshpally SS	Angadikistapur	11kv	Gajwel	15.00	16.10	01.10		HT line to LT line Touching	-
7		Marpadaga SS	Sirsinagandla AGL	11kv	Gajwel	18.20	19.50	01.30		Disk Fail	-
8		Marpadaga SS	Marpadaga AGL II	11kv	Gajwel	18.00	23.59	05.59		Reason Not found	-
1	RR N	Subhash Nagar	Pragha Tools	11kv	Medchal	17.15	17.40	00.25	EL	11KV Line AB Switch Opened at Mayuri bar(11KV Cable endkit Failed)	-
2		Kistapur	Suma Biscuits	11kv	Medchal	10.00	12.40	02.40	EL	Stick Fallen on 11KV Line at Etukala Company	-
1	HYD N	Chilkaiguda	P.R Nagar	11kv	V	22.30	00.50	02.20	EL	Cable fault at Gandhi Medical College (1No. DTR Kept off)	
1	HYD C	Asif Nagar	Market Yard	11kv	VII	02.58	04.03	01.05	EL,OL	Cable fault (2No. DTRs kept off)	